

Pumping Station Noise Emissions - Equations Used

Internal Noise Calculation

$$(i) \text{ Surface Area (SA)} = 2(l \times w + l \times h + w \times h)$$

$$(ii) \text{ Room Constant (Rc)} = \frac{SA \times \bar{\alpha}}{(1 - \bar{\alpha})}$$

where $\bar{\alpha}$ = average absorption coefficient

$$(iii) \text{ SPL}_{(\text{inside})} = \text{SWL} + 10 \log \left[\frac{Q}{4\pi r^2} + \frac{4}{Rc} \right] \text{dB(A)}$$

External Noise Calculations

$$(i) \text{ SPL}_{(\text{outside louvre})} = \text{SPL}_{(\text{inside})} - R_{(\text{louvre})} - 6 \text{ dB(A)}$$

where $R_{(\text{louvre})}$ is the sound reduction index of the louvre

$$(ii) \text{ SPL}_{(\text{NSR})} = \text{SPL}_{(\text{inside})} - R_{av} + 10 \log(S) - 20 \log(r) - 14 + 3 \text{ dB(A)}$$

where R_{av} is the average sound reduction index of the radiating surface

S is the surface area of the radiating surface

r is the distance between the source and NSR

$$(iii) R_{av} = 10 \log \left(\frac{1}{\tau_{av}} \right)$$

$$\text{where } \tau_{av} = \frac{\tau_1 S_1 + \tau_2 S_2 + \dots}{S}$$

$$\text{where } \tau_1 = 10^{(-R_1/10)} \quad R_1 \text{ is the sound reduction index for material 1}$$

S_1 = surface area of material 1

$$(iv) \text{ Total SPL}_{(\text{NSR})} = \sum \text{SPL}_{(\text{wall 1})} + \text{SPL}_{(\text{wall 2})} + \dots + \text{SPL}_{(\text{roof})} \text{ dB(A)}$$

Pumping Station Noise Emissions - Unmitigated

Assumptions

SWL (4 * 104 dB(A))	110	Assume hemispherical Radiation (ie $2(\pi)^2$)
Q (Directivity)		
length, m	42	
height, m	3	
width, m	24	
S (surface area), m ²	2412	
Rc (Room Constant)	1034	
alpha (absorption coefficient)	0.3	

Calculations

$$\begin{aligned} \text{SPL(inside louvre), dB(A)} &= 107.0 \\ \text{SPL(outside louvre), dB(A)} &= 96.0 \end{aligned}$$

Source	Surface Area, m ²			Sound Reduction Index, R (dB(A))			Interim Calculations			(dB(A))	
	Total	Concrete	Louvre	Concrete	Louvre	Tau'Area (concrete)	Tau'Area (louvre)	Tau*Area (total)	Rav	Directivity correction	SPL (NSR)
Wall 1	126	122	4	25	5	0.386	1.265	1.651	18.8	0	47.6
Wall 2	126	126	0	25	5	0.398	0.000	0.398	25.0	-10	31.4
Wall 3	72	72	0	25	5	0.228	0.000	0.228	25.0	-5	34.0
Wall 4	72	72	0	25	5	0.228	0.000	0.228	25.0	-5	34.0
Roof	1008	1008	0	25	5	3.188	0.000	3.188	25.0	-5	45.4
Total	1404	1400	4						Total	49.9	

Results	
SPL(at 1 m)	96 dB(A)
SPL(NSR)	50 dB(A)

Pumping Station Noise Emissions - Mitigated

Assumptions

SWL (4 * 98 dB(A))	104	Assume hemispherical Radiation (ie $2(\Pi)r^2$)
Q (Directivity)		
length, m	42	
height, m	3	
width, m	24	
S (surface area), m ²	2412	
Rc (Room Constant)	1034	
alpha (absorption coefficient)	0.3	

Calculations

SPL(inside louvre), dB(A)
SPL(outside louvre), dB(A)

101.0
90.0

Source	Surface Area, m ²			Sound Reduction Index, R (dB(A))			Interim Calculations			(dB(A))	
	Total	Concrete	Louvre	Concrete	Louvre	Tau*Area (concrete)	Tau*Area (louvre)	Tau*Area (total)	Rav	Directivity correction	SPL (NSR)
Wall 1	126	122	4	25	5	0.386	1.265	1.651	18.8	0	41.6
Wall 2	126	126	0	25	5	0.398	0.000	0.398	25.0	-10	25.4
Wall 3	72	72	0	25	5	0.228	0.000	0.228	25.0	-5	28.0
Wall 4	72	72	0	25	5	0.228	0.000	0.228	25.0	-5	28.0
Roof	1008	1008	0	25	5	3.188	0.000	3.188	25.0	-5	39.4
Total	1404	1400	4						Total		43.9

Results

SPL(at 1 m)	90 dB(A)
SPL(NSR)	44 dB(A)