



香港電燈有限公司
The Hongkong Electric Co., Ltd.



ENVIRONMENTAL IMPACT ASSESSMENT (EIA) ORDINANCE, CAP. 499

ENVIRONMENTAL PERMIT NO. EP-083/2000

**LAMMA POWER STATION
CONVERSION OF TWO EXISTING GAS TURBINES (GT5 & GT7) INTO A
COMBINED CYCLE UNIT
ENVIRONMENTAL MONITORING & AUDIT PROGRAMME
AT OPERATIONAL PHASE**

Report Title	<u>Monthly EM&A Report (June 2009)</u>
Date	<u>13 July 2009</u>
Certified by	<u></u> (Mr. CHAN Kwok-Fai, Environmental Team Leader)
Verified by	<u></u> (Nature & Technologies (HK) Ltd, Independent Environmental Checker)

1. AIR AND WATER QUALITY MONITORING FOR GT57 OPERATION IN JUNE 2009

This is the June 2009 Environmental Monitoring and Audit (EM&A) report for the Project "Operation of GT57 Combined Cycle Unit" prepared by the Environmental Team (ET). GT57 was not operated in the reporting month. In this regard, no air quality and water quality monitoring pertinent to GT57 was carried out in the reporting month.

2. IMPLEMENTATION STATUS ON THERMAL PLUME SURVEYS

No thermal plume survey was carried out in the reporting month. The survey would only be conducted under the conditions stipulated in the proposal on the programme and methodologies for thermal plume survey attached in the EM&A manual (Operational Phase).

3. FUTURE KEY ISSUES

3.1 Outage Plan for the coming 3 months

The major outage plan for the next 3 months is shown below:

Date	Remark
01/09/2009 to 31/12/2009	Overhaul and reliability upgrading work for GT57

3.2 Key issues for the coming month

Key issues to be considered in the coming month include:

Air Impact

- To monitor the water injection rate continuously while GT57 is operating.
- To monitor the sulphur content of the LGO if the combined cycle unit is run on LGO.

Water Impact

- To carry out water quality monitoring while GT57 is operating as required by the EM&A manual (Operational phase).

~ End ~