

Sun Creation Engineering Limited Calibration and Testing Laboratory

Certificate No.: C045685

Certificate of Calibration

This is to certify that the equipment

Description: Precision Integrating Sound Level Meter

Manufacturer: ONO SOKKI

Model No.: LA-5110

Serial No.: 72700154

has been calibrated for the specific items and ranges. The results are shown in the Calibration Report No. C045685.

The equipment is supplied by

Co. Name: Atkins China Limited

Address: 15/F, Miramar Tower, 132 Nathan Road, Tsim Sha Tsui, Kowloon

Date of Issue: 30 December 2004

Certified by:



Sun Creation Engineering Limited Calibration and Testing Laboratory

Report No.: C045685

Calibration Report

ITEM TESTED

DESCRIPTION

: Precision Integrating Sound Level Meter

MANUFACTURER:

ONO SOKKI

MODEL NO.

: LA-5110

SERIAL NO.

72700154

TEST CONDITIONS

AMBIENT TEMPERATURE : (23 ± 2)°C

RELATIVE HUMIDITY: $(55 \pm 15)\%$

LINE VOLTAGE

TEST SPECIFICATIONS

Calibration check

DATE OF TEST: 29 December 2004

JOB NO.: IC04-3635

TEST RESULTS

The results apply to the particular unit-under-test only. All calibration points are within manufacturer's specification. The results are detailed in the subsequent page(s).

The test equipment used for calibration are traceable to National Standards via:

- The Brüel & Kjær Calibration Laboratory, Denmark

Date: 30 December 2004



Sun Creation Engineering Limited Calibration and Testing Laboratory

Report No.: C045685

Calibration Report

- 1. The unit-under-test (UUT) was allowed to stabilize in the laboratory for over 24 hours, and switched on to warm up for over 10 minutes before the commencement of the test.
- 2. Self-calibration was performed before the test.
- 3. The results presented are the mean of 3 measurements at each calibration point.
- 4. Test equipment:

Equipment ID CL281

<u>Description</u>
Multifunction Acoustic Calibrator

Certificate No. 12909

- 5. Test procedure: MA101N.
- 6. Results:
- 6.1 Sound Pressure Level

6.1.1 Reference Sound Pressure Level

| UUT Setting | | | | Applied Value | | UUT | IEC 651 Type I |
|---------------|------|-----------|----------|---------------|----------------|-----------------|----------------|
| Range (dB) | Mode | Weighting | Response | Level (dB) | Freq. (kHz) | Reading (dB) | Spec. |
| 40 - 100 | Lp | A | Fast | 94.00 | 1 | 94.0 | ± 0.7 |

6.1.2 Linearity

| | UUʻ | T Setting | | Applied Value | | UUT | |
|---------------|------|-----------|----------|---------------|----------------|-----------------|--|
| Range (dB) | Mode | Weighting | Response | Level (dB) | Freq. (kHz) | Reading (dB) | |
| 60 - 120 | Lp | A | Fast | 94.00 | 1 | 94.0 (Ref.) | |
| | | | | 104.00 | | 104.0 | |
| | | | | 114.00 | | 114.0 | |

IEC 651 Type 1 Spec. : ±0.4 dB per 10 dB step and ±0.7 dB for overall different.

6.2 Time Weighting

| * | UUT Setting | | | Applied Value | | UUT | IEC 651 Type 1 | |
|-----------------------|-------------|---|-----------|---------------|-------|-------|----------------|-------|
| | Range | Mode | Weighting | Response | Level | Freq. | Reading | Spec. |
| į | (dB) | *************************************** | | | (dB) | (kHz) | (dB) | (dB) |
| - | 40 - 100 | Lp | A | Fast | 94.00 | 1 | 94.0 | Ref. |
| to Parke State of Bit | | | | Slow | | | 94.0 | ± 0.1 |
| 1 | | | | Imp | | | 94.0 | ± 0.1 |



Sun Creation Engineering Limited Calibration and Testing Laboratory

Report No.: C045685

Calibration Report

Frequency Weighting

6.3.1 A-Weighting

| | UU | T Setting | | Applied Value | | UUT | IEC 651 Type I | | | | | | |
|---------------|------|-----------|-----------------|---------------|---------------|-----------------|---|---|--|--|-----|------|------|
| Range (dB) | Mode | Weighting | Response | Level (dB) | Freq. (Hz) | Reading (dB) | Spec. (dB) | | | | | | |
| 40 - 100 | Lp | A | Fast | 94.00 | 31.5 | 55.0 | -39.4 ± 1.5 | | | | | | |
| | | 7 | | 63 | 67.7 | -26.2 ± 1.5 | | | | | | | |
| | | | | | 125 | 77.8 | -16.1 ± 1.0 | | | | | | |
| | | | SECULAR PARTIES | | 500 | 90.7 | -3.2 ± 1.0 | | | | | | |
| | | | | | | | *************************************** | *************************************** | | | 1 k | 94.0 | Ref. |
| | | | - | | 2 k | 95.2 | $+1.2 \pm 1.0$ | | | | | | |

6.3.2 C-Weighting

| | UU | T Setting | | Applied Value | | UUT | IEC 651 Type 1 |
|---------------|------|-----------|----------|---------------|---------------|--------------|----------------|
| Range (dB) | Mode | Weighting | Response | Level (dB) | Freq. (Hz) | Reading (dB) | Spec. (dB) |
| 40 - 100 | Lp | С | Fast | 94.00 | 31.5 | 90.8 | -3.0 ± 1.5 |
| | | | 1 | | 63 | 93.1 | -0.8 ± 1.5 |
| | | | | | 125 | 93.9 | -0.2 ± 1.0 |
| | | | | | 500 | 94.0 | 0.0 ± 1.0 |
| | | | | | Ιk | 94.0 | Ref. |
| | | | | | 2 k | 93.8 | -0.2 ± 1.0 |

Remarks: - Mfr's Spec.: IEC651 Type 1

- Uncertainties of Applied Value: 94 dB : 31.5 Hz - 125 Hz : $\pm 0.35 \text{ dB}$

500 Hz $\pm 0.30 \, dB$ l kHz $\pm 0.20 \text{ dB}$ 2 kHz $\pm 0.35 \, dB$

104 dB : 1 kHz $\pm 0.30 \, dB$ 114 dB: 11 kHz $\pm 0.30 \text{ dB}$

- The uncertainties are for a confidence probability of not less than 95 %.

The values given in this Calibration Report only relate to the values measured at the time of the test and any uncertainties quoted will not include allowance for the equipment long term drift, variations with environment changes, vibration and shock during transportation, overloading, mis-handling, or the capability of any other laboratory to repeat the measurement. Sun Creation Engineering Limited shall not be liable for any loss or damage resulting from the use of the equipment.



Sun Creation Engineering Limited Calibration and Testing Laboratory

Certificate No.: C045684

Certificate of Calibration

This is to certify that the equipment

Description: Sound Calibrator (P022X0077701)

Manufacturer: ONO SOKKI

Model No.: SC-2110

Serial No.: 00461

has been calibrated for the specific items and ranges. The results are shown in the Calibration Report No. C045684.

The equipment is supplied by

Co. Name: Atkins China Limited

Address: 15/F, Miramar Tower, 132 Nathan Road, Tsim Sha Tsui, Kowloon

Date of Issue: 30 December 2004

Certified by :



Sun Creation Engineering Limited Calibration and Testing Laboratory

Report No.: C045684

Calibration Report

ITEM TESTED

DESCRIPTION

: Sound Calibrator (P022X0077701)

MANUFACTURER :

ONO SOKKI

MODEL NO.

SC-2110

SERIAL NO.

: 00461

TEST CONDITIONS

AMBIENT TEMPERATURE : $(23 \pm 2)^{\circ}$ C

RELATIVE HUMIDITY: $(55 \pm 15)\%$

LINE VOLTAGE

TEST SPECIFICATIONS

Calibration check

DATE OF TEST: 29 December 2004

JOB NO.: IC04-3641

TEST RESULTS

The results apply to the particular unit-under-test only. All calibration points are within user's specification. The results are detailed in the subsequent page(s).

The test equipment used for calibration are traceable to National Standards via:

- The Government of The Hong Kong Special Administrative Region Standard & Calibration Laboratory
- The Brüel & Kjær Calibration Laboratory, Denmark

Date: 30 December 2004

The test equipment used for calibration are traceable to the National Standards as specified in this report, This report shall not be reproduced except in full and with prior written approval from this laboratory.

Tel: 2927 2606

Fax: 2744 8986

E-mail: callab@suncreation.com

Website; www.suncreation.com

1 of 2



Sun Creation Engineering Limited Calibration and Testing Laboratory

Report No.: C045684

Calibration Report

- 1. The unit-under-test (UUT) was allowed to stabilize in the laboratory for over 24 hours before the commencement of the test.
- 2. The results presented are the mean of 3 measurements at each calibration point,
- 3. Test equipment:

Equipment ID CL126 CL130 CL281

Description Sound Level Meter Universal Counter Multifunction Acoustic Calibrator Certificate No. C043496 C042857 12909

- Test procedure: MA100N.
- 5. Results:

5.1 Sound Level Accuracy

| UUT | Measured Value | User's Spec. | Uncertainty of Measured Value |
|---------------|----------------|--------------|-------------------------------|
| Nominal Value | (dB) | (dB) | (dB) |
| 94 dB, l kHz | 94.0 | ± 0.5 | ± 0.2 |

5.2 Frequency Accuracy

| UUT Nominal Value | Measured Value | User's Spec. | Uncertainty of Measured Value |
|-------------------|----------------|--------------|-------------------------------|
| (kHz) | (Hz) | | (Hz) |
| 1 | 999.2 | 1 kHz ± 1 % | ± 0.1 |

Remark: - The uncertainties are for a confidence probability of not less than 95 %.

Note:

The values given in this Calibration Report only relate to the values measured at the time of the test and any uncertainties quoted will not include allowance for the equipment long term drift, variations with environment changes, vibration and shock during transportation, overloading, mis-handling, or the capability of any other laboratory to repeat the measurement. Sun Creation Engineering Limited shall not be liable for any loss or damage resulting from the use of the equipment.