

***Appendix 3.5***

---

***Calculation of Portal Emission and Ventilation Building***





Appendix 3.5 Calculation of Portal Emission and Emission of Ventilation Building

Scenario: Year 2031 - Year 2039

Road ID	Height (m)	Width (m)	Base Height (m)	Source ID	X	Y	Daily Emission Factor (QS) (g/s)						total NO	total NO2	total FSP	total RSP	
							NO	NO2	FSP	RSP	HS	SY					SZ
A	5	8.3	35	A1	816234.5	833053.2	1.284E-02	4.652E-03	7.048E-04	7.657E-04	2.50	3.86	2.33				
	"	"	"	A2	816242.5	833051.1	1.284E-02	4.652E-03	7.048E-04	7.657E-04	2.50	3.86	2.33				
	"	"	"	A3	816250.6	833049.0	1.284E-02	4.652E-03	7.048E-04	7.657E-04	2.50	3.86	2.33				
	"	"	"	A4	816258.6	833047.0	1.284E-02	4.652E-03	7.048E-04	7.657E-04	2.50	3.86	2.33				
	"	"	"	A5	816266.7	833044.9	1.284E-02	4.652E-03	7.048E-04	7.657E-04	2.50	3.86	2.33				
	"	"	"	A6	816274.7	833042.8	1.284E-02	4.652E-03	7.048E-04	7.657E-04	2.50	3.86	2.33				
	"	"	"	A7	816282.7	833040.7	1.284E-02	4.652E-03	7.048E-04	7.657E-04	2.50	3.86	2.33				
	"	"	"	A8	816290.8	833038.6	6.418E-03	2.326E-03	3.524E-04	3.829E-04	2.50	3.86	2.33				
	"	"	"	A9	816298.8	833036.6	6.418E-03	2.326E-03	3.524E-04	3.829E-04	2.50	3.86	2.33				
	"	"	"	A10	816306.8	833034.5	6.418E-03	2.326E-03	3.524E-04	3.829E-04	2.50	3.86	2.33				
	"	"	"	A11	816314.9	833032.4	6.418E-03	2.326E-03	3.524E-04	3.829E-04	2.50	3.86	2.33				
	"	"	"	A12	816322.9	833030.3	6.418E-03	2.326E-03	3.524E-04	3.829E-04	2.50	3.86	2.33				
	"	"	"	A13	816330.9	833028.2	6.418E-03	2.326E-03	3.524E-04	3.829E-04	2.50	3.86	2.33				
	"	"	"	A14	816339.0	833026.1	6.418E-03	2.326E-03	3.524E-04	3.829E-04	2.50	3.86	2.33	1.348E-01	4.885E-02	7.401E-03	8.040E-03

Source ID	X	Y	Base Height (m)	Daily Emission Factor (QS) (g/s)				Height (m) <sup>1</sup>	Release Height (HS) (m) <sup>1</sup>	Exit Temperature (TS) (K) <sup>1</sup>	Exit Velocity (VS) (m/s) <sup>1</sup>	Stack Diameter (DS) (m) <sup>1</sup>	
				NO	NO2	FSP	RSP						
Ventilation Building Stack 1 (90% from VB)	V1	816230.5	833054.2	49.50	1.21297055	0.43961842	0.06660742	0.07236193	7.00	56.50	303.00	4.00	8.97

Remark:  
 1. Stack parameters of TMWB are adopted from Tuen Mun Chek Lap Kok Link EIA, including stack height of 7m, exhaust volume of 252.9 m<sup>3</sup>/s at exit velocity of 4 m/s with stack diameter 8.97 m, expected temperature is 5C higher than ambient temperature.

Appendix 3.5 Calculation of Portal Emission and Emission of Ventilation Building

Scenario: Year 2031 - Year 2039

Hourly Profile for Portals


Hour	Link 502 (Eastbound)			
	NO	NO2	FSP	RSP
Hour 1	0.0130	0.0120	0.0131	0.0130
Hour 2	0.0085	0.0078	0.0086	0.0085
Hour 3	0.0063	0.0058	0.0063	0.0063
Hour 4	0.0085	0.0089	0.0086	0.0086
Hour 5	0.0051	0.0049	0.0047	0.0047
Hour 6	0.0072	0.0069	0.0066	0.0066
Hour 7	0.0170	0.0163	0.0157	0.0157
Hour 8	0.0469	0.0449	0.0433	0.0433
Hour 9	0.0753	0.0712	0.0576	0.0576
Hour 10	0.0532	0.0516	0.0507	0.0507
Hour 11	0.0517	0.0512	0.0512	0.0513
Hour 12	0.0490	0.0485	0.0485	0.0486
Hour 13	0.0415	0.0403	0.0403	0.0403
Hour 14	0.0678	0.0718	0.0739	0.0740
Hour 15	0.0706	0.0744	0.0770	0.0771
Hour 16	0.0742	0.0780	0.0805	0.0805
Hour 17	0.0786	0.0830	0.0834	0.0835
Hour 18	0.0751	0.0778	0.0792	0.0792
Hour 19	0.0752	0.0753	0.0745	0.0745
Hour 20	0.0557	0.0551	0.0559	0.0558
Hour 21	0.0407	0.0398	0.0409	0.0409
Hour 22	0.0336	0.0326	0.0340	0.0340
Hour 23	0.0251	0.0231	0.0252	0.0252
Hour 24	0.0202	0.0186	0.0203	0.0202

Appendix 3.5 Calculation of Portal Emission and Emission of Ventilation Building

Scenario: Year 2031 - Year 2039

**Hourly Profile for Ventilation Buildings**

Hour	V1			
	NO	NO2	FSP	RSP
Hour 1	0.0130	0.0120	0.0131	0.0130
Hour 2	0.0085	0.0078	0.0086	0.0085
Hour 3	0.0063	0.0058	0.0063	0.0063
Hour 4	0.0085	0.0089	0.0086	0.0086
Hour 5	0.0051	0.0049	0.0047	0.0047
Hour 6	0.0072	0.0069	0.0066	0.0066
Hour 7	0.0170	0.0163	0.0157	0.0157
Hour 8	0.0469	0.0449	0.0433	0.0433
Hour 9	0.0753	0.0712	0.0576	0.0576
Hour 10	0.0532	0.0516	0.0507	0.0507
Hour 11	0.0517	0.0512	0.0512	0.0513
Hour 12	0.0490	0.0485	0.0485	0.0486
Hour 13	0.0415	0.0403	0.0403	0.0403
Hour 14	0.0678	0.0718	0.0739	0.0740
Hour 15	0.0706	0.0744	0.0770	0.0771
Hour 16	0.0742	0.0780	0.0805	0.0805
Hour 17	0.0786	0.0830	0.0834	0.0835
Hour 18	0.0751	0.0778	0.0792	0.0792
Hour 19	0.0752	0.0753	0.0745	0.0745
Hour 20	0.0557	0.0551	0.0559	0.0558
Hour 21	0.0407	0.0398	0.0409	0.0409
Hour 22	0.0336	0.0326	0.0340	0.0340
Hour 23	0.0251	0.0231	0.0252	0.0252
Hour 24	0.0202	0.0186	0.0203	0.0202



LEGEND:

- - - PROJECT BOUNDARY
- - - PORTAL EMISSION (VOLUME SOURCE)
- VENTILATION BUILDING (POINT SOURCE)



**PROJECT**  
**HUNG SHUI KIU NEW DEVELOPMENT AREA PLANNING AND ENGINEERING STUDY - INVESTIGATION**

**CLIENT**  
**土木工程拓展署**  
 Civil Engineering and Development Department  
**規劃署**  
 Planning Department

**CONSULTANT**  
 AECOM Asia Company Ltd.  
 www.aecom.com

**SUB-CONSULTANTS**  
 分判工程顧問公司


**ISSUE/REVISION**

IR	DATE	DESCRIPTION	CHK.
號	日期	內容摘要	號

**STATUS**

**SCALE**                      **DIMENSION UNIT**  
 比例                              尺寸單位  
 A3 1 : 2000                      METRES

**KEY PLAN**



**PROJECT NO.**                      **AGREEMENT NO.**  
 項目編號                              協議編號  
 60222570                              CE2/2011 (CE)

**SHEET TITLE**  
 圖紙名稱  
 LOCATIONS OF PORTAL EMISSION AND VENTILATION BUILDING

**SHEET NUMBER**  
 圖紙號碼  
 60222570/TR19A/APPENDIX 3.5.1

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as required by law. AECOM accepts no responsibility, and denies any liability whatsoever, to any party, for uses or reliance on this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.

