

本署檔號
OUR REF: (20) in EP2/N5/F/70
來函檔號
YOUR REF:
電話
TEL. NO.: 2835 1868
圖文傳真
FAX NO.: 2591 0558
電子郵件
E-MAIL:
網址
HOMEPAGE: <http://www.epd.gov.hk>

Environmental Protection Department
Branch Office
28th Floor, Southorn Centre,
130 Hennessy Road,
Wan Chai, Hong Kong.



環境保護署分處
香港灣仔
軒尼詩道
一百三十號
修頓中心廿八樓

24 January 2018

Drainage Services Department,

Environmental Impact Assessment (EIA) Ordinance, Cap.499
Application for Permission to Apply Directly for Environmental Permit

Project Title: Upgrading of Sewage Pumping Stations and Sewerage along
Ting Kok Road
(Application No. DIR-258/2017)

I refer to your above application received on 13 December 2017 for permission to apply directly for environmental permit under Section 5(1)(b) of the EIA Ordinance.

With the consent of the Secretary for the Environment under Section 5(11) of the EIA Ordinance, I now permit you to apply directly for environmental permit subject to the attached conditions.

Under Section 15 of the EIA Ordinance, the decision on the application will be placed on the EIA Ordinance Register. It will also be placed on the EIA Ordinance website (<http://www.epd.gov.hk/eia/>).

Please note that if you are aggrieved by any of the conditions imposed in this permission, you may appeal under Section 17 of the EIA Ordinance within 30 days of receipt of this permission.

Should you have any queries on the above application, please contact my colleague Mr. Steve Li at 2835 1142.

Yours sincerely,

(Raymond W.M. WONG)

Principal Environmental Protection Officer
for Director of Environmental Protection

Environmental Impact Assessment (EIA) Ordinance, Cap. 499
Application for Permission to Apply Directly for Environmental Permit

Project Title: Upgrading of Sewage Pumping Stations and Sewerage along
Ting Kok Road
(Application No. DIR-258/2017)

Conditions Imposed under Section 5(12) of the Ordinance
for Permission to Apply Directly for Environmental Permit

1. All measures described in the Project Profile (PP-560/2017) submitted with the application of 13 December 2017 shall be fully implemented, in particular:
 - (i) all facilities and areas with potential odour emission such as wet wells, inlet chamber and screen chambers shall be fully enclosed and the exhausted air shall be conveyed to a Deodorizing (DO) Unit with odour removal efficiency of at least 99.5% for treatment before discharge to the environment; and
 - (ii) the section of gravity sewer within Plover Cove Country Park shall be constructed using trenchless method to minimise any construction noise and dust nuisance.

2. A pre-construction Condition Survey on the Graded Historic Buildings and structures identified in the Project Profile (PP-560/2017) shall be carried out and a Condition Survey Report (the Report) shall be submitted to the Director for approval. The Report shall contain detailed description, professional appraisal of existing condition and identification of fragile elements of the above-mentioned buildings and structures. The Report shall also include building settlement, tilting and vibration monitoring proposals such as the monitoring criteria, schedule and working methods, as well as precautionary measures, event action plan, contingency measures and reporting mechanism. The proposal in the approved Report shall be fully and properly implemented prior to commencement of construction of the Project, and shall be carried out throughout the entire construction period; and

3. An Independent Environmental Checker (IEC) shall be employed to audit the implementation of all mitigation measures recommended in the Project Profile and in the above Conditions to confirm full compliance through an Audit Report to the Director within one month upon completion of construction works.

- END -