

Area No.	Domestic											Hotel		Commercial and Institutional				Type of Facilities	Unit Flow of Facilities	Total AWF
	CDA	G/IC	PRH	HOS	Private R1	Private R2	Private R3	Private R4	Private RR4	Modern Village (V)	Total	Hotel Employee <sup>(2)</sup>	Total	Commercial Employee <sup>(3)</sup>	School Student	Visitors	Total		(m³/d)	(m³/d)
	0.37	0.19	0.19	0.19	0.19	0.27	0.37	0.37	0.37	0.27		1.58		0.28	0.04	0.08				
From Development Parameters Presented in RODP																				
A1-2			7,944											566	202					1,676
A1-4					1,986									433	202					507
A1-5	4,075													876	202					1,761
A1-6					4,524									969	202					1,139
A1-8				4,225										734	202					1,016
A1-9						5,715								0						1,543
A1-10														2						1
A2-2			16,903											1,200	404					3,564
A2-4				4,435										620	202					1,024
A2-5					2,203									467						549
A2-7			6,021											943	202					1,416
A2-9						5,150								0						1,391
A2-11														50	765					45
A2-12														50	765					45
A2-13														82	1,200					71
A3-1														50	765					45
A3-2														82	1,200					71
A3-3			21,573											1,556	606					4,559
A3-4														50	765					45
A3-6						3,917								0						1,058
A3-7									52					0						19
B2-2														2,581						723
B2-5														50	765					45
B2-6														82	1,200					71
B2-7														50	765					45
B2-8														80						22
B2-10	827													1,765						800
B2-12														2,420						678
B3-2														3,822						1,070
B3-5														2,534						710
B3-8												123		10						197
B3-12														4,177						1,170
B3-15														19						5
C1-3	141													0						52
C1-4										435				0						117
C1-6										40				0						11
C2-2										30				0						8
D1-5								119						0						44
D1-7						7,098								0						1,917
D1-9										2,236				0						604
D1-11						5,005								0						1,351
E1-1														2						1
E1-2														50	765					45
E1-3		891												450						295
E1-4														82	1,200					71
E1-5														20						6
E1-6														100						28
E1-7														2						1
F1-1														10						3
F1-3														4,076						1,141
																		Sub-total		32,771
Others																				
B1-7														10				Plant for District Cooling System	58.5	61
B3-16															210			Visitor Centre		17
C1-9														90		200		Long Valley Core Area, Area for Wetland Enhancement Works and		41
C1-11														200				Area for Facilities Supporting the Nature Park		56
D1-12		58												8		458		Reprovision Site of Kwu Tung Vegetable Marketing and Credit Co-operative Society		50
D1-13		82												12		642		Potential Activity Centre		70
D1-14														419				Potential Activity Centre		117
F1-4		50																Government Reserve		
G1-1														270				Disused School (Potential for Eco-tourism Education Centre, Holiday Camping or Other		10
G1-2																		Recreational Uses); please refer to Note (4)		76
G1-6														30				Lo Wu Firing Range		8
G1-7														30				Lo Wu Firing Range		8
G1-8		1,400												554		85		Lo Wu Saddle Club		8
																		Lo Wu Saddle Club		428
																		Lo Wu Correctional Institution		
																		Sub-total		951
Total pop. <sup>(4)</sup>	5,043	891	52,441	8,660	8,714	26,886	0	119	52	2,740	105,545	123	123	31,112	12,579	0	43,691			
Total flow <sup>(4)</sup>	1,866	169	9,964	1,645	1,656	7,259	0	44	19	740	23,362	194	194	8,711	503	0	9,215	Total Flow		33,722

Total residential population	=	105,545	person
Total domestic AWF	=	23,362	m³/d
Total hotel population	=	123	person
Total hotel AFW	=	194	m³/d
Total commercial population (excluding no. of students)	=	31,112	person
Total commercial AWF (including AWF of students)	=	9,215	m³/d
Total other population	=	N.A.	person
Total other AWF	=	951	m³/d
Total population	=	136,780	person
Total AWF	=	33,722	m³/d

NOTES:  
(1) total UFF for industrial employee = UFF of employee + UFF of industrial activity = 0.08 + 0.56 where 0.56 is for general-territorial average UFF  
(2) total UFF for hotel employee = UFF of employee + UFF of hotel activity = 0.08 + 1.50 where 1.50 is for restaurant and hotel average UFF  
(3) total UFF for commercial employee = UFF of employee + UFF of commercial activity = 0.08 + 0.2 where 0.2 is for general-territorial average UFF  
(4) population and flow from "Others" are not taken into account

Area No.	Domestic										Hotel		Commercial and Institutional				Type of Facilities	Unit Flow of Facilities (m <sup>3</sup> /d)	Total AWF (m <sup>3</sup> /d)
	CDA	G/I/C	PRH	HOS	Private R1	Private R2	Private R3	Private R4	Private RR4	Modern Village (V)	Total	Hotel Employee <sup>(2)</sup>	Total	Commercial Employee <sup>(3)</sup>	School Student	Visitors			
	0.37	0.19	0.19	0.19	0.19	0.27	0.37	0.37	0.37	0.27		1.58		0.28	0.04	0.08			
From Development Parameters Presented in RODP																			
A1-3										77				0					21
A1-9										44				0					12
B1-7						2,079								0					561
B1-8								24						0					9
B1-9							435							0					161
B2-6			4,326											0				1.08	823
B2-7			3,422											551	210			0.75	814
B2-11			4,294											0				1.07	817
B2-12			3,237											520				0.71	761
B3-2			1,939											0				0.49	369
B3-3			2,592											425				0.57	612
B3-4														49	765				44
B3-5														49	765				44
B3-6						829								366	210				335
B3-7						1,171								0					316
B3-9						1,183								0					319
B3-10														76	1,200				69
B3-12														49	765				44
C2-5														60					17
C2-6														50					14
C2-7														51	765				45
C2-8														2					1
C2-9														76	1,200				69
D2-2				3,721										0					707
D2-4						2,996								0					809
D2-6			3,244											0				0.71	617
D2-9			13,492											983	420			2.63	2,858
D2-12						2,220								0					599
D3-1a					2,047									0					389
D3-1c				3,442										0					654
D3-1c					2,791									579	210			0.84	702
D3-3					1,786									371				0.54	444
D3-4					2,407									521	210			0.72	612
D3-6					2,382									516	210			0.71	605
D3-7					2,236									464				0.67	555
D3-8			5,035											632	210			0.88	1,143
D3-11														76	1,200				69
D3-12														49	765				44
Sub-total																			17,086
Others																			
A1-8														73					20
A1-11														90					25
A2-3														20					6
B2-2														203					57
B2-4														764					220
														1,000					280
														176					49
														149					42
D2-15														40					11
D2-16																			
Sub-total																			710
Total pop. <sup>(4)</sup>	0	0	41,580	7,164	13,648	10,478	435	24	0	121	73,450	0	0	6,514	9,105	0	15,619		
Total flow <sup>(4)</sup>	0	0	7,900	1,361	2,593	2,829	161	9	0	33	14,886	0	0	1,824	364	0	2,188		17,796
Total Flow																			

NOTES:  
 (1) total UFF for industrial employee = UFF of employee + UFF of industrial activity = 0.08 + 0.56 where 0.56 is for general-territorial average UFF  
 (2) total UFF for hotel employee = UFF of employee + UFF of hotel activity = 0.08 + 1.50 where 1.50 is for restaurant and hotel average UFF  
 (3) total UFF for commercial employee = UFF of employee + UFF of commercial activity = 0.08 + 0.2 where 0.2 is for general-territorial average UFF  
 (4) population and flow from "Others" are not taken into account