



Tai Shue Wan Development at Ocean Park

Noise Audit Report

August 2021

Mott MacDonald
3/F International Trade
Tower
348 Kwun Tong Road
Kowloon
Hong Kong

T +852 2828 5757
F +852 2827 1823
mottmac.hk

Ocean Park Corporation
180 Wong Chuk Hang Road
Aberdeen
Hong Kong

Tai Shue Wan Development at Ocean Park

Noise Audit Report

August 2021

Pursuant to Condition 2.14 of Environmental Permit No. EP-487/2014/A, this Noise Audit Report has been reviewed and certified by the Environmental Team Leader (ETL) and verified by the Independent Environmental Checker (IEC).

Certified by:



Gary Chow
Environmental Team Leader (ETL)
Mott MacDonald Hong Kong Limited

Date:

26 Aug 2021

Verified by:



Sam Tsot
Independent Environmental Checker (IEC)
Ove Arup & Partners Hong Kong Limited

Date:

31 August 21

Issue and Revision Record

| Revision | Date | Originator | Checker | Approver | Description |
|----------|----------|------------|-------------|-----------|----------------------------|
| A | Jul 2021 | Various | Henry Leung | Gary Chow | 1 st Submission |
| B | Aug 2021 | Various | Henry Leung | Gary Chow | 2 nd Submission |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

Document reference: 415089 | 0404 | B

Information class: Standard

This document is issued for the party which commissioned it and for specific purposes connected with the above-captioned project only. It should not be relied upon by any other party or used for any other purpose.

We accept no responsibility for the consequences of this document being relied upon by any other party, or being used for any other purpose, or containing any error or omission which is due to an error or omission in data supplied to us by other parties.

This document contains confidential information and proprietary intellectual property. It should not be shown to other parties without consent from us and from the party which commissioned it.

Contents

| | | |
|-----|--|----|
| 1 | Introduction | 1 |
| 1.1 | Background | 1 |
| 1.2 | Objectives of the Noise Audit Report | 1 |
| 2 | Updated Information Based on the Latest Design | 3 |
| 2.1 | Latest Building Layout Plan and Information of Fixed Noise Sources | 3 |
| 2.2 | Noise Mitigation Measures | 3 |
| 3 | Details of Noise Measurement | 4 |
| 3.1 | Measurement Date and Time | 4 |
| 3.2 | Measurement Equipment | 4 |
| 3.3 | Measurement Methodology | 4 |
| 3.4 | Summary of Noise Measurement Results | 5 |
| 4 | Fixed Noise Impact Assessment | 7 |
| 4.1 | Identification of Noise Sensitive Receivers | 7 |
| 4.2 | Fixed Noise Criteria | 7 |
| 4.3 | Assessment Methodology | 8 |
| 4.4 | Evaluation of Noise Impacts | 8 |
| 5 | Conclusion | 10 |
| | Appendices | 11 |
| | Appendix A Calibration Certificates | 12 |
| | Appendix B Photographs of Noise Measurement / Representative NSRs | 13 |
| | Appendix C Noise Measurement Results | 14 |
| | Appendix D Information from Ocean Park Corporation | 15 |
| | Appendix E Fixed Noise Impact Assessment | 16 |
| | Figures | 17 |

List of Tables

| | | |
|-----------|--|---|
| Table 3-1 | Details of Noise Measurement | 4 |
| Table 3-2 | Noise Measurement Equipment | 4 |
| Table 3-3 | Summary of Measured Noise Levels for Fixed Noise Sources | 5 |
| Table 4-1 | Representative Noise Sensitive Receivers | 7 |
| Table 4-2 | Noise Criteria for Fixed Noise Sources | 8 |
| Table 4-3 | Predicted Fixed Noise Levels at Representative Noise Sensitive Receivers | 9 |

List of Figures

| | |
|------------|---|
| Figure 1.1 | Location of the Project |
| Figure 2.1 | Locations of Fixed Noise Sources |
| Figure 3.1 | Locations of Representative Noise Sensitive Receivers |
| Figure 3.2 | Locations of Fixed Noise Sources from Concurrent Projects |

1 Introduction

1.1 Background

- 1.1.1 Under the Environmental Impact Assessment (EIA) Ordinance, the EIA Report and the Environmental Monitoring and Audit (EM&A) Manual (Register No.: AEIAR-184/2014) prepared for the “Tai Shue Wan Development at Ocean Park” (the Project) have been approved by the Environmental Protection Department (EPD) on 27 August 2014. The Environmental Permit (EP) has been subject to variation and the current Permit No. is EP-487/2014/A issued on 10 January 2018.
- 1.1.2 As stipulated in the Condition 2.14 of the current EP, the Permit Holder shall, no later than one month before commencement of operation of the Project, carry out noise audit work for the fixed noise sources including open air entertainment activities of the Project in accordance with standard acoustical principles and practices, and deposit with the Director four hard copies and one electronic copy of a Noise Audit Report showing the locations of the noise sources, implemented mitigation measures and the noise audit results complying with the maximum sound power levels specified in the approved EIA report or showing that based on the noise audit results, the sound pressure level criteria at all the representative Noise Sensitive Receivers (NSRs) are complied with.
- 1.1.3 Mott MacDonald Hong Kong Limited (MMHK) has been commissioned by the Ocean Park Corporation to prepare and submit the Noise Audit Report to meet Condition 2.14 of the EP. The location of the Project is shown in **Figure 1.1**.
- 1.1.4 The Noise Audit Report has been certified by the Environmental Team (ET) Leader and verified by the Independent Environmental Checker (IEC) as conforming to the information and recommendations contained in the approved EIA report before submission to the Director of Environmental Protection (DEP).

1.2 Objectives of the Noise Audit Report

- 1.2.1 The objective of establishing the Noise Audit Report is to demonstrate that the noise audit results complying with the maximum sound power levels specified in the approved EIA report or showing that based on the noise audit results, the sound pressure level criteria at all the representative NSRs are complied with in accordance with the updated locations of the noise sources and mitigation measures.
- 1.2.2 Since the types and locations of noise sources are substantially different from that in the approved EIA Report, the maximum sound power levels cannot be comparable. As such, the noise levels and all the representative NSRs are assessed based on the noise audits results comparing against the relevant fixed noise criteria in the approved EIA report.
- 1.2.3 The Noise Audit Report shall contain:

- a. The updated information of all fixed noise sources of the Project from the Ocean Park Corporation (including but not limited to open air entertainment activities) and implemented noise mitigation measures; and
- b. Updated prediction of fixed noise levels at representative NSRs in accordance with the updated information and noise mitigation measures in place.

2 Updated Information Based on the Latest Design

2.1 Latest Building Layout Plan and Information of Fixed Noise Sources

- 2.1.1 The building footprint and locations of fixed noise sources have been changed from the approved EIA report. The latest detailed information of all fixed noise sources of the Project was provided by the Ocean Park Corporation. A plan view of the development with locations of the identified fixed noise sources are shown in **Figure 2.1**.

2.2 Noise Mitigation Measures

Fixed Plant Noise

- 2.2.1 As recommended in the approved EIA report, the following noise mitigation measures have been adopted during design stage for the fixed plant of the Project:
- choose quiet plant such as those which have been effectively silenced;
 - include noise levels specification when ordering new plant (including chiller and E&M equipment);
 - locate fixed plant / louvre away from any NSRs as far as practicable;
 - locate fixed plant in walled plant rooms or in specially designed enclosures;
 - locate noisy machine in a basement or a completely separate building;
 - install direct noise mitigation measures including silencers, acoustic louvres and acoustic enclosure where necessary; and
 - develop and implement a regularly scheduled plant maintenance programme so that equipment is properly operated and serviced in order to maintain a controlled level of noise.

Open Air Entertainment Noise

- 2.2.2 As recommended in the approved EIA report, the following measures have been adopted during design stage for the Public Address (PA) system / loudspeaker of the Project:
- use small clusters of small power loudspeakers rather than a few large power loudspeakers; and
 - loudspeakers pointed away from nearby NSRs as far as practicable.
- 2.2.3 As confirmed by the Ocean Park Corporation, all the above-mentioned noise mitigation measures for fixed plant noise and open air entertainment noise as recommended in the approved EIA report has been implemented in the proposed development.

3 Details of Noise Measurement

3.1 Measurement Date and Time

3.1.1 Noise measurement in the form L_{eq} level was conducted during daytime period on normal weekday at the project area. Details of the noise measurement date and time are shown in **Table 3-1**.

Table 3-1 Details of Noise Measurement

| Measurement Location | Date | Measurement Period | Weather Condition |
|----------------------|-------------|--------------------|-------------------|
| Within Project Area | 2 July 2021 | 10:00 – 17:15 | Cloudy |

3.2 Measurement Equipment

3.2.1 Noise measurement was performed using sound level meter at each designated measurement station. The sound level meter deployed comply with the International Electrotechnical Commission Publications 651:1979 (Type 1) and 804:1985 (Type 1) specifications. Acoustic calibrator was used to check the sound level meter by a known sound pressure level for field measurement. Details of equipment used in the Measurement period are given in **Table 3-2**.

Table 3-2 Noise Measurement Equipment

| Equipment | Brand and Model | Last Calibration Date |
|------------------------------|--|-----------------------|
| Integrated Sound Level Meter | Rion NL-52 (Serial No. 00643039) | 4 June 2021 |
| Acoustic Calibrator | LARSON DAVIS CAL200 (Serial No. 16172) | 21 November 2020 |

3.2.2 Prior to and after each series of noise measurements, the meter was calibrated using the acoustic calibrator. If the difference in the calibration level before and after measurement was more than 1.0 dB(A), the measurement would be considered invalid and repeat of noise measurement would be required after re-calibration or repair of the equipment.

3.2.3 The sound level meter and calibrator were sent to the supplier or laboratory accredited under Hong Kong Laboratory Accreditation Scheme (HOKLAS) to check and calibrate at yearly intervals. The calibration certificates are shown in **Appendix A**.

3.3 Measurement Methodology

3.3.1 Noise measurements to obtain the noise levels of the fixed plants, PA systems and loudspeakers were carried out by qualified persons possessing at least 7 years of noise control experience and a corporate member of Hong Kong Institute of Acoustics or equivalent. The measurement method can be summarised as follows:

- The microphone was positioned at the perpendicular distance d away from the centre of the intake / exhaust louvre / noise source, where d is at least two times the largest dimension b of the louvre or plant and rounded up to integer, i.e.: $d \geq 2b$.
- The microphone was pointing toward the centre of the louvre / noise source and three measurements with 1-minute sampling period were taken when the noise source was switched ON under typical operating conditions as agreed by the operator. The highest measured noise level of the three sets measurement is adopted for conservative approach.
- Background noise have been included in the noise measurement for conservative consideration.
- For the PA system / loudspeaker, soundtrack (with highest volume section) adopted in typical operating conditions, as agreed with the operator, was repeated in approx. 1-minute interval during the measurements so that the worst-case scenario has been captured.
- For the PA system / loudspeaker, based on the site observation, the units selected for noise measurement can represent the other units within that type of equipment.

3.4 Summary of Noise Measurement Results

3.4.1 Summary of the on-site noise measurement results are presented in **Table 3-3**. Photographs showing the examples of noise measurement for the fixed noise sources are shown in **Appendix B**. Details of the noise measurement results are shown in **Appendix C**.

Table 3-3 Summary of Measured Noise Levels for Fixed Noise Sources

| Fixed Noise Sources | ID | Measurement Distance (m) | Maximum Measured SPL, dB(A), L_{eq} (1 min) |
|---------------------------------------|------------------|--------------------------|---|
| Emergency Generator Set (Intake) | N1-1*, N2-1 | 6 | 76.2 |
| Emergency Generator Set (Discharge) | N1-2*, N2-2 | 12 | 58.9 |
| Electricity Substation (High Voltage) | N3^, N4 | 6 | 62.5 |
| Cooling Tower (Discharge) | N5-1-1 to N5-6-1 | 5 | 82.5 – 87.0 |
| Cooling Tower (Intake) | N5-1-2 to N5-6-2 | 6 | 76.2 – 78.7 |
| Chiller Room | N6 | 6 | 71.4 |
| Low Voltage Substation | N7 | 5 | 69.1 |
| Pump Room and Wave Generator | N8 | 6 | 69.7 |
| PA system / loudspeakers | A1 to A6 | 2 | 70.5 |
| PA system / loudspeakers | B1 to B4 | 2 | 72.4 |
| PA system / loudspeakers | C1 to C24 | 3 | 75.6 |
| PA system / loudspeakers | D1 to D4 | 2 | 74.4 |
| PA system / loudspeakers | E1 to E8 | 2 | 73.5 |
| PA system / loudspeakers | F1 to F3 | 4 | 74.2 |
| PA system / loudspeakers | G1 to G2 | 2 | 73.8 |
| PA system / loudspeakers | H1 to H10 | 2 | 75.0 |
| PA system / loudspeakers | I1 to I7 | 2 | 74.3 |
| PA system / loudspeakers | J1 to J7 | 2 | 71.8 |
| PA system / loudspeakers | K1 to K4 | 2 | 75.5 |
| PA system / loudspeakers | L1 to L3 | 2 | 77.4 |

| Fixed Noise Sources | ID | Measurement Distance (m) | Maximum Measured SPL, dB(A), L _{eq} (1 min) |
|--------------------------|-----------|--------------------------|--|
| PA system / loudspeakers | M1 to M7 | 2 | 68.5 |
| PA system / loudspeakers | N1 to N3 | 2 | 69.0 |
| PA system / loudspeakers | O1 to O3 | 2 | 69.6 |
| PA system / loudspeakers | P1 to P5 | 2 | 77.6 |
| PA system / loudspeakers | Q1 to Q2 | 3 | 75.8 |
| PA system / loudspeakers | R1 to R2 | 2 | 77.6 |
| PA system / loudspeakers | S1 to S3 | 2 | 79.2 |
| PA system / loudspeakers | T1 to T4 | 2 | 75.5 |
| PA system / loudspeakers | U1 to U16 | 3 | 79.7 |
| PA system / loudspeakers | V1 to V8 | 2 | 74.9 |
| PA system / loudspeakers | W1 to W3 | 2 | 67.8 |
| PA system / loudspeakers | X1 to X3 | 2 | 76.7 |
| PA system / loudspeakers | Y1 to Y4 | 2 | 72.4 |
| PA system / loudspeakers | Z1 to Z4 | 2 | 76.4 |

Remarks:

- (*) Since the emergency generator set N1 cannot be operated during the noise measurement, the measured noise levels at a similar emergency generator set N2 were adopted in the fixed noise impact assessment.
- (^) Since the electricity substation N3 cannot be operated during the noise measurement, the measured noise levels at a similar electricity substation N4 were adopted in the fixed noise impact assessment.

3.4.2 The directivity characteristic of the identified major fixed plants was not obvious by the site observation. No impulsive and intermittency characteristics of the identified fixed noise sources were observed during the noise measurements. Since all identified fixed noise sources are outside 300m from all representative NSRs, tonality characteristic at the NSRs is expected insignificant and hence no correction for tonality is applied in this study.

4 Fixed Noise Impact Assessment

4.1 Identification of Noise Sensitive Receivers

- 4.1.1 Existing, planned/committed noise sensitive developments and relevant uses on the relevant Outline Zoning Plans, Development Permission Area Plans, Outline Development Plans, Layout Plans and other relevant published land use plans, including plans and drawings published by Lands Department were also reviewed. There are no NSRs (rely on opened windows for ventilation) in accordance with Annex 13 of the EIAO-TM within the 300 m assessment area. In consistent with the approved EIA report, for the purpose of noise assessment, NSRs over 300m from the Project have been included in noise impact assessment in this study.
- 4.1.2 The assessment points identified in the approved EIA report for fixed noise impact assessment remain valid as no new representative NSRs are identified. The assessment points for fixed noise impact assessment are shown in **Figure 3.1** and summarized in **Table 4-1** below. Photographs of the representative NSRs are shown in **Appendix B**.

Table 4-1 Representative Noise Sensitive Receivers

| NSR ID | Description | Existing / Planned | Land Use | No. of Stories | Area Sensitivity Rating* |
|--------|--------------------------------|--------------------|-------------|----------------|--------------------------|
| VSA | Victoria Shanghai Academy | Existing | Residential | 7 | C |
| HKJCC | Hong Kong Juvenile Care Centre | Existing | Residential | 4 | B |

Notes:

(*) NSR "VSA" is within 100m of a zone designated as "Industrial" and NSR "HKJCC" is between 100 m and 250 m from "Industrial" zone. The Area Sensitivity Ratings assumed in this report are only indicative and they are used for assessment only. It shall not prejudice the Authority's decision on enforcement based on contemporary conditions.

The new hotel near the Tai Shue Wan Development have been installed with sealed glazing and provided with central air-conditioning, the use does not rely on opened windows for ventilation and adverse noise impact is not expected. As a result, no assessment point is proposed for the hotel under the fixed noise impact assessment.

4.2 Fixed Noise Criteria

- 4.2.1 As stipulated in Annex 5 of the EIAO-TM, the noise standards for planning fixed noise source are (a) 5 dB(A) below the appropriate ANL as stipulated in the IND-TM, or (b) the prevailing background noise levels (for quiet areas with level 5 dB(A) below the ANL).
- 4.2.2 Further to review of the existing environment in the vicinity of the representative NSRs by site observation, the existing noise environment in the approved EIA report remain unchanged. Hence, the fixed noise criteria stated in Section 5.2 of the approved EIA report remain applicable as follows: -

Table 4-2 Noise Criteria for Fixed Noise Sources

| NSR ID | Description | Time Period | Area Sensitivity Rating | ANL-5, dB(A) | Background Noise Level, dB(A)^ | Fixed Noise Criteria |
|--------|--------------------------------|------------------------------------|-------------------------|--------------|--------------------------------|----------------------|
| VSA | Victoria Shanghai Academy | Daytime (0700 to 1900) | C | 65 | 55 | 55 |
| HKJCC | Hong Kong Juvenile Care Centre | Daytime and Evening (0700 to 2300) | B | 60 | 50 - 53 | 50 |

Notes:

(^) Background noise measurement result refers to the approved TSW EIA report Table 5.5.

4.3 Assessment Methodology

- 4.3.1 The noise levels at representative NSRs from the fixed noise sources of the Project are predicted from the on-site noise measurement results based on basic acoustics equation and compared against the relevant fixed noise criteria in the approved EIA report.
- 4.3.2 A screening correction of -10dB(A) has been applied (as in the approved EIA report) where the representative NSRs are being screened with no direct line of sight by buildings or natural terrains.
- 4.3.3 A façade correction of +3dB(A) has been considered (as in the approved EIA report) at the representative NSRs in order to account for the façade reflection effect.
- 4.3.4 As mentioned in **Section 3.4.2**, no correction for tonality, impulsiveness and intermittency is deemed necessary in the study.
- 4.3.5 The shortest horizontal distances between the representative NSRs and the noise sources have been adopted for the fixed noise impact assessment for conservative approach.
- 4.3.6 Cumulative noise impact from outdoor E&M facility (i.e. cooling towers) of nearby new hotel and special events show / attractions at Ocean Park have been considered in the fixed noise impact assessment. Sound pressure levels of the cooling towers of nearby new hotel are provided by Ocean Park Corporation as shown in **Appendix D**. Sound power levels of the special events show / attractions at Ocean Park are referred to the approved EIA report.

4.4 Evaluation of Noise Impacts

- 4.4.1 With the measured noise levels of the noise sources of this Project and noise data of the concurrent projects, the predicted cumulative fixed noise levels at the representative NSRs are summarized in **Table 4-3** below. Detailed calculations please refer to **Appendix E**.

Table 4-3 Predicted Fixed Noise Levels at Representative Noise Sensitive Receivers

| NSR ID | Predicted Noise Levels at Representative NSRs, dB(A) | | | | | Noise Criteria, dB(A) | Compliance? (Y/N) |
|--------|--|--|---------------------------------|---|--|-----------------------|-------------------|
| | Fixed Plant Noise Level (1) | Entertainment Noise level from Loudspeaker (2) | Noise from nearby New Hotel (3) | Noise from Concurrent Special Events (The Summit) (4) | Cumulative Noise Level (5) = (1) + (2) + (3) + (4) | | |
| VSA | 44.5 | 43.8 | 27.5 | 36.3 | 48 | 55 | Y |
| HKJCC | 44.5 | 44.0 | 26.9 | 36.8 | 48 | 50 | Y |

4.4.2 Based on the fixed noise impact assessment results, the predicted cumulative fixed noise levels at all representative NSRs are complied with the relevant fixed noise criteria. Therefore, adverse noise impact to nearby NSRs due to operation of the proposed development is not anticipated.

5 Conclusion

- 5.1.1 The fixed noise impact assessment has been conducted based on the updated information and on-site noise measurement results. The recommended noise mitigation measures as mentioned in the approved EIA report have been adopted for the fixed noise sources of the Project to minimize the fixed noise impact. Based on the fixed noise impact assessment results, the predicted cumulative fixed noise levels at all representative NSRs are complied with the relevant fixed noise criteria. Therefore, adverse noise impact to nearby NSRs due to operation of the proposed development is not anticipated.

Appendices

| | | |
|------------|--|----|
| Appendix A | Calibration Certificates | 12 |
| Appendix B | Photographs of Noise Measurement / Representative NSRs | 13 |
| Appendix C | Noise Measurement Results | 14 |
| Appendix D | Information from Ocean Park Corporation | 15 |
| Appendix E | Fixed Noise Impact Assessment | 16 |
| Figures | | 17 |

Appendix A Calibration Certificates



輝創工程有限公司

Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration

校正證書

Certificate No. : C213254

證書編號

ITEM TESTED / 送檢項目 (Job No. / 序引編號 : IC21-1006)

Date of Receipt / 收件日期 : 21 May 2021

Description / 儀器名稱 : Sound Level Meter

Manufacturer / 製造商 : Rion

Model No. / 型號 : NL-52

Serial No. / 編號 : 00643039

Supplied By / 委託者 : Envirotech Services Co.

Room 113, 1/F, My Loft, 9 Hoi Wing Road, Tuen Mun,
New Territories, Hong Kong

TEST CONDITIONS / 測試條件

Temperature / 溫度 : $(23 \pm 2)^{\circ}\text{C}$

Relative Humidity / 相對濕度 : $(50 \pm 25)\%$

Line Voltage / 電壓 : ---

TEST SPECIFICATIONS / 測試規範

Calibration

DATE OF TEST / 測試日期 : 4 June 2021

TEST RESULTS / 測試結果

The results apply to the particular unit-under-test only.

The results do not exceed manufacturer's specification. (after adjustment)

The results are detailed in the subsequent page(s).

The test equipment used for calibration are traceable to National Standards via :

- The Government of The Hong Kong Special Administrative Region Standard & Calibration Laboratory
- Agilent Technologies / Keysight Technologies
- Fluke Everett Service Center, USA

Tested By
測試

:

Chenk

K P Cheuk
Project Engineer

Certified By
核證

:

K C Lee
K C Lee
Engineer

Date of Issue
簽發日期

:

7 June 2021

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗室所書面批准。

Sun Creation Engineering Limited - Calibration & Testing Laboratory

c/o 4/F, 1 Hing On Lane, Tuen Mun, New Territories, Hong Kong

輝創工程有限公司 - 校正及檢測實驗室

c/o 香港新界屯門興安里一號四樓

Tel/電話: (852) 2927 2606

Fax/傳真: (852) 2744 8986

E-mail/電郵: callab@suncreation.com

Website/網址: www.suncreation.com

Certificate of Calibration

校正證書

Certificate No. : C213254
證書編號

1. The unit-under-test (UUT) was allowed to stabilize in the laboratory for over 12 hours, and switched on to warm up for over 10 minutes before the commencement of the test.
2. Self-calibration using the internal standard (After Adjustment) was performed before the test 6.1.1.2 to 6.3.2.
3. The results presented are the mean of 3 measurements at each calibration point.
4. Test equipment :

| Equipment ID | Description | Certificate No. |
|--------------|-------------------------------------|-----------------|
| CL280 | 40 MHz Arbitrary Waveform Generator | C210084 |
| CL281 | Multifunction Acoustic Calibrator | AV210017 |

5. Test procedure : MA101N.

6. Results :

- 6.1 Sound Pressure Level

- 6.1.1 Reference Sound Pressure Level

- 6.1.1.1 Before Adjustment

| UUT Setting | | | | Applied Value | | UUT Reading (dB) | IEC 61672 Class 1 Spec. (dB) |
|-------------|----------------|---------------------|----------------|---------------|-------------|------------------|------------------------------|
| Range (dB) | Function | Frequency Weighting | Time Weighting | Level (dB) | Freq. (kHz) | | |
| 30 - 130 | L _A | A | Fast | 94.00 | 1 | * 91.7 | ± 1.1 |

* Out of IEC 61672 Class 1 Spec.

- 6.1.1.2 After Adjustment

| UUT Setting | | | | Applied Value | | UUT Reading (dB) | IEC 61672 Class 1 Spec. (dB) |
|-------------|----------------|---------------------|----------------|---------------|-------------|------------------|------------------------------|
| Range (dB) | Function | Frequency Weighting | Time Weighting | Level (dB) | Freq. (kHz) | | |
| 30 - 130 | L _A | A | Fast | 94.00 | 1 | 94.0 | ± 1.1 |

- 6.1.2 Linearity

| UUT Setting | | | | Applied Value | | UUT Reading (dB) |
|-------------|----------------|---------------------|----------------|---------------|-------------|------------------|
| Range (dB) | Function | Frequency Weighting | Time Weighting | Level (dB) | Freq. (kHz) | |
| 30 - 130 | L _A | A | Fast | 94.00 | 1 | 94.0 (Ref.) |
| | | | | 104.00 | | 104.0 |
| | | | | 114.00 | | 114.0 |

IEC 61672 Class 1 Spec. : ± 0.6 dB per 10 dB step and ± 1.1 dB for overall different.

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗室書面批准。

Certificate of Calibration

校正證書

Certificate No. : C213254

證書編號

6.2 Time Weighting

| UUT Setting | | | | Applied Value | | UUT Reading (dB) | IEC 61672 Class 1 Spec. (dB) |
|-------------|----------------|---------------------|----------------|---------------|-------------|------------------|------------------------------|
| Range (dB) | Function | Frequency Weighting | Time Weighting | Level (dB) | Freq. (kHz) | | |
| 30 - 130 | L _A | A | Fast | 94.00 | 1 | 94.0 | Ref. |
| | | | Slow | | | 94.0 | ± 0.3 |

6.3 Frequency Weighting

6.3.1 A-Weighting

| UUT Setting | | | | Applied Value | | UUT Reading (dB) | IEC 61672 Class 1 Spec. (dB) |
|-------------|----------------|---------------------|----------------|---------------|--------|------------------|------------------------------|
| Range (dB) | Function | Frequency Weighting | Time Weighting | Level (dB) | Freq. | | |
| 30 - 130 | L _A | A | Fast | 94.00 | 63 Hz | 67.7 | -26.2 ± 1.5 |
| | | | | | 125 Hz | 77.8 | -16.1 ± 1.5 |
| | | | | | 250 Hz | 85.3 | -8.6 ± 1.4 |
| | | | | | 500 Hz | 90.7 | -3.2 ± 1.4 |
| | | | | | 1 kHz | 94.0 | Ref. |
| | | | | | 2 kHz | 95.2 | +1.2 ± 1.6 |
| | | | | | 4 kHz | 95.0 | +1.0 ± 1.6 |
| | | | | | 8 kHz | 92.9 | -1.1 (+2.1 ; -3.1) |
| | | | | | 16 kHz | 86.0 | -6.6 (+3.5 ; -17.0) |

6.3.2 C-Weighting

| UUT Setting | | | | Applied Value | | UUT Reading (dB) | IEC 61672 Class 1 Spec. (dB) |
|-------------|----------------|---------------------|----------------|---------------|--------|------------------|------------------------------|
| Range (dB) | Function | Frequency Weighting | Time Weighting | Level (dB) | Freq. | | |
| 30 - 130 | L _C | C | Fast | 94.00 | 63 Hz | 93.2 | -0.8 ± 1.5 |
| | | | | | 125 Hz | 93.8 | -0.2 ± 1.5 |
| | | | | | 250 Hz | 94.0 | 0.0 ± 1.4 |
| | | | | | 500 Hz | 94.0 | 0.0 ± 1.4 |
| | | | | | 1 kHz | 94.0 | Ref. |
| | | | | | 2 kHz | 93.8 | -0.2 ± 1.6 |
| | | | | | 4 kHz | 93.2 | -0.8 ± 1.6 |
| | | | | | 8 kHz | 91.0 | -3.0 (+2.1 ; -3.1) |
| | | | | | 16 kHz | 84.1 | -8.5 (+3.5 ; -17.0) |

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗室書面批准。



輝創工程有限公司

Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration

校正證書

Certificate No. : C213254
證書編號

Remarks : - UUT Microphone Model No. : UC-59 & S/N : 10990

- Mfr's Spec. : IEC 61672 Class 1

- Uncertainties of Applied Value :

| | | |
|--------|------------------|--------------------------|
| 94 dB | : 63 Hz - 125 Hz | : ± 0.35 dB |
| | 250 Hz - 500 Hz | : ± 0.30 dB |
| | 1 kHz | : ± 0.20 dB |
| | 2 kHz - 4 kHz | : ± 0.35 dB |
| | 8 kHz | : ± 0.45 dB |
| | 16 kHz | : ± 0.70 dB |
| 104 dB | : 1 kHz | : ± 0.10 dB (Ref. 94 dB) |
| 114 dB | : 1 kHz | : ± 0.10 dB (Ref. 94 dB) |

- The uncertainties are for a confidence probability of not less than 95 %.

Note :

Only the original copy or the laboratory's certified true copy is valid.

The values given in this Certificate only relate to the values measured at the time of the test and any uncertainties quoted will not include allowance for the equipment long term drift, variations with environment changes, vibration and shock during transportation, overloading, mis-handling, or the capability of any other laboratory to repeat the measurement. Sun Creation Engineering Limited shall not be liable for any loss or damage resulting from the use of the equipment.

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗室書面批准。

Sun Creation Engineering Limited – Calibration & Testing Laboratory

c/o 4/F, 1 Hing On Lane, Tuen Mun, New Territories, Hong Kong

輝創工程有限公司 - 校正及檢測實驗室

c/o 香港新界屯門興安里一號四樓

Tel/電話: (852) 2927 2606

Fax/傳真: (852) 2744 8986

E-mail/電郵: callab@suncreation.com

Website/網址: www.suncreation.com

Page 4 of 4



輝創工程有限公司

Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration

校正證書

Certificate No. : C206427

證書編號

ITEM TESTED / 送檢項目 (Job No. / 序引編號 : IC20-2353) Date of Receipt / 收件日期 : 3 November 2020

Description / 儀器名稱 : Precision Acoustic Calibrator
Manufacturer / 製造商 : LARSON DAVIS
Model No. / 型號 : CAL200
Serial No. / 編號 : 16172
Supplied By / 委託者 : Envirotech Services Co.
Room 113, 1/F, My Loft, 9 Hoi Wing Road, Tuen Mun,
New Territories, Hong Kong

TEST CONDITIONS / 測試條件

Temperature / 溫度 : $(23 \pm 2)^{\circ}\text{C}$ Relative Humidity / 相對濕度 : $(50 \pm 25)\%$
Line Voltage / 電壓 : ---

TEST SPECIFICATIONS / 測試規範

Calibration check

DATE OF TEST / 測試日期 : 21 November 2020


TEST RESULTS / 測試結果

The results apply to the particular unit-under-test only.
The results do not exceed manufacturer's specification.
The results are detailed in the subsequent page(s).

The test equipment used for calibration are traceable to National Standards via :

- The Government of The Hong Kong Special Administrative Region Standard & Calibration Laboratory
- The Bruel & Kjaer Calibration Laboratory, Denmark
- Agilent Technologies / Keysight Technologies
- Fluke Everett Service Center, USA

Tested By : 
測試 : K C Lee
Engineer

Certified By : 
核證 : H C Chan
Engineer

Date of Issue : 24 November 2020
簽發日期

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。

Sun Creation Engineering Limited - Calibration & Testing Laboratory

c/o 4/F, 1 Hing On Lane, Tuen Mun, New Territories, Hong Kong

輝創工程有限公司 - 校正及檢測實驗室

c/o 香港新界屯門興安里一號四樓

Tel/電話: (852) 2927 2606

Fax/傳真: (852) 2744 8986

E-mail/電郵: callab@suncreation.com

Website/網址: www.suncreation.com



輝創工程有限公司

Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C206427

證書編號

- The unit-under-test (UUT) was allowed to stabilize in the laboratory for over 12 hours before the commencement of the test.
- The results presented are the mean of 3 measurements at each calibration point.
- Test equipment :

| <u>Equipment ID</u> | <u>Description</u> | <u>Certificate No.</u> |
|---------------------|-----------------------------------|------------------------|
| CL130 | Universal Counter | C203952 |
| CL281 | Multifunction Acoustic Calibrator | CDK1806821 |
| TST150A | Measuring Amplifier | C201309 |

- Test procedure : MA100N.

- Results :

5.1 Sound Level Accuracy

| UUT Nominal Value | Measured Value (dB) | Mfr's Spec. (dB) | Uncertainty of Measured Value (dB) |
|----------------------|------------------------|---------------------|---------------------------------------|
| 94 dB, 1 kHz | 93.9 | ± 0.2 | ± 0.2 |
| 114 dB, 1 kHz | 113.9 | | |

5.2 Frequency Accuracy

| UUT Nominal Value (kHz) | Measured Value (kHz) | Mfr's Spec. | Uncertainty of Measured Value (Hz) |
|----------------------------|-------------------------|----------------|---------------------------------------|
| 1 | 1.000 | 1 kHz ± 1 % | ± 1 |

Remark : The uncertainties are for a confidence probability of not less than 95 %.

Note :

Only the original copy or the laboratory's certified true copy is valid.

The values given in this Certificate only relate to the values measured at the time of the test and any uncertainties quoted will not include allowance for the equipment long term drift, variations with environment changes, vibration and shock during transportation, overloading, mis-handling, or the capability of any other laboratory to repeat the measurement. Sun Creation Engineering Limited shall not be liable for any loss or damage resulting from the use of the equipment.

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗室書面批准。

Sun Creation Engineering Limited - Calibration & Testing Laboratory

c/o 4/F, 1 Hing On Lane, Tuen Mun, New Territories, Hong Kong

輝創工程有限公司 - 校正及檢測實驗室

c/o 香港新界屯門興安里一號四樓

Tel/電話: (852) 2927 2606

Fax/傳真: (852) 2744 8986

E-mail/電郵: callab@suncreation.com

Website/網址: www.suncreation.com

Appendix B Photographs of Noise Measurement / Representative NSRs

Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

Major Fixed Plants

N2-1*



N2-2*



N4^



N5 (Cooling Tower Discharge)



Remark:

(*) Since the emergency generator set N1 cannot be operated during the noise measurement, the measured noise levels at a similar emergency generator set N2 were adopted in the fixed noise impact assessment.

(^) Since the electricity substation N3 cannot be operated during the noise measurement, the measured noise levels at a similar electricity substation N4 were adopted in the fixed noise impact assessment.

Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

N5 (Cooling Tower Intake)



N6



N7



N8



Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

PA System / Loudspeaker

Loudspeaker Type A



Loudspeaker Type B



Loudspeaker Type C



Loudspeaker Type D



Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

Loudspeaker Type E



Loudspeaker Type F



Loudspeaker Type G



Loudspeaker Type H



Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

Loudspeaker Type I



Loudspeaker Type J



Loudspeaker Type K



Loudspeaker Type L



Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

Loudspeaker Type M



Loudspeaker Type N



Loudspeaker Type O



Loudspeaker Type P



Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

Loudspeaker Type Q



Loudspeaker Type R



Loudspeaker Type S



Loudspeaker Type T



Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

Loudspeaker Type U



Loudspeaker Type V



Loudspeaker Type W



Loudspeaker Type X



Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

Loudspeaker Type Y



Loudspeaker Type Z



Appendix B – Photographs of Noise Measurement / Representative Noise Sensitive Receivers

Representative Noise Sensitive Receivers

Victoria Shanghai Academy (VSA)



Hong Kong Juvenile Care Centre (HKJCC)



Appendix C Noise Measurement Results

PA System / Loudspeaker

| Source ID | Measurement Distance (m) | Measured SPL, dB(A) | | | Max. Measured SPL, dB(A) |
|-----------|--------------------------|------------------------|------------------------|------------------------|--------------------------|
| | | L _{eq, 1 min} | L _{eq, 1 min} | L _{eq, 1 min} | |
| A1 | 2 | 70.5 | 70.2 | 68.6 | 70.5 |
| A2 | 2 | 70.5 | 70.2 | 68.6 | 70.5 |
| A3 | 2 | 70.5 | 70.2 | 68.6 | 70.5 |
| A4 | 2 | 70.5 | 70.2 | 68.6 | 70.5 |
| A5 | 2 | 70.5 | 70.2 | 68.6 | 70.5 |
| A6 | 2 | 70.5 | 70.2 | 68.6 | 70.5 |
| B1 | 2 | 71.8 | 72.4 | 71 | 72.4 |
| B2 | 2 | 71.8 | 72.4 | 71 | 72.4 |
| B3 | 2 | 71.8 | 72.4 | 71 | 72.4 |
| B4 | 2 | 71.8 | 72.4 | 71 | 72.4 |
| C1 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C2 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C3 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C4 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C5 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C6 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C7 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C8 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C9 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C10 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C11 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C12 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C13 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C14 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C15 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C16 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C17 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C18 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C19 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C20 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C21 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C22 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C23 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| C24 | 3 | 75 | 72.7 | 75.6 | 75.6 |
| D1 | 2 | 72.5 | 74.2 | 74.4 | 74.4 |
| D2 | 2 | 72.5 | 74.2 | 74.4 | 74.4 |
| D3 | 2 | 72.5 | 74.2 | 74.4 | 74.4 |
| D4 | 2 | 72.5 | 74.2 | 74.4 | 74.4 |
| E1 | 2 | 73.2 | 72.6 | 73.5 | 73.5 |
| E2 | 2 | 73.2 | 72.6 | 73.5 | 73.5 |
| E3 | 2 | 73.2 | 72.6 | 73.5 | 73.5 |
| E4 | 2 | 73.2 | 72.6 | 73.5 | 73.5 |
| E5 | 2 | 73.2 | 72.6 | 73.5 | 73.5 |
| E6 | 2 | 73.2 | 72.6 | 73.5 | 73.5 |
| E7 | 2 | 73.2 | 72.6 | 73.5 | 73.5 |
| E8 | 2 | 73.2 | 72.6 | 73.5 | 73.5 |
| F1 | 4 | 74.2 | 74.2 | 72.2 | 74.2 |
| F2 | 4 | 74.2 | 74.2 | 72.2 | 74.2 |
| F3 | 4 | 74.2 | 74.2 | 72.2 | 74.2 |
| G1 | 2 | 73 | 73.8 | 72.1 | 73.8 |
| G2 | 2 | 73 | 73.8 | 72.1 | 73.8 |
| H1 | 2 | 74.8 | 72.2 | 75 | 75 |
| H2 | 2 | 74.8 | 72.2 | 75 | 75 |
| H3 | 2 | 74.8 | 72.2 | 75 | 75 |
| H4 | 2 | 74.8 | 72.2 | 75 | 75 |
| H5 | 2 | 74.8 | 72.2 | 75 | 75 |
| H6 | 2 | 74.8 | 72.2 | 75 | 75 |
| H7 | 2 | 74.8 | 72.2 | 75 | 75 |
| H8 | 2 | 74.8 | 72.2 | 75 | 75 |
| H9 | 2 | 74.8 | 72.2 | 75 | 75 |
| H10 | 2 | 74.8 | 72.2 | 75 | 75 |
| I1 | 2 | 73.9 | 74.3 | 71.9 | 74.3 |
| I2 | 2 | 73.9 | 74.3 | 71.9 | 74.3 |
| I3 | 2 | 73.9 | 74.3 | 71.9 | 74.3 |
| I4 | 2 | 73.9 | 74.3 | 71.9 | 74.3 |
| I5 | 2 | 73.9 | 74.3 | 71.9 | 74.3 |
| I6 | 2 | 73.9 | 74.3 | 71.9 | 74.3 |
| I7 | 2 | 73.9 | 74.3 | 71.9 | 74.3 |
| J1 | 2 | 70.9 | 71.2 | 71.8 | 71.8 |
| J2 | 2 | 70.9 | 71.2 | 71.8 | 71.8 |
| J3 | 2 | 70.9 | 71.2 | 71.8 | 71.8 |
| J4 | 2 | 70.9 | 71.2 | 71.8 | 71.8 |
| J5 | 2 | 70.9 | 71.2 | 71.8 | 71.8 |
| J6 | 2 | 70.9 | 71.2 | 71.8 | 71.8 |
| J7 | 2 | 70.9 | 71.2 | 71.8 | 71.8 |
| K1 | 2 | 75.2 | 75.5 | 74.1 | 75.5 |
| K2 | 2 | 75.2 | 75.5 | 74.1 | 75.5 |
| K3 | 2 | 75.2 | 75.5 | 74.1 | 75.5 |
| K4 | 2 | 75.2 | 75.5 | 74.1 | 75.5 |
| L1 | 2 | 75.9 | 76.8 | 77.4 | 77.4 |
| L2 | 2 | 75.9 | 76.8 | 77.4 | 77.4 |
| L3 | 2 | 75.9 | 76.8 | 77.4 | 77.4 |
| M1 | 2 | 68.5 | 67.5 | 68.5 | 68.5 |
| M2 | 2 | 68.5 | 67.5 | 68.5 | 68.5 |
| M3 | 2 | 68.5 | 67.5 | 68.5 | 68.5 |
| M4 | 2 | 68.5 | 67.5 | 68.5 | 68.5 |
| M5 | 2 | 68.5 | 67.5 | 68.5 | 68.5 |
| M6 | 2 | 68.5 | 67.5 | 68.5 | 68.5 |
| M7 | 2 | 68.5 | 67.5 | 68.5 | 68.5 |

Major Fixed Plants

| Noise Source Description | Source ID | Measurement Distance (m) | Measured SPL, dB(A) | | | Max. Measured SPL, dB(A) |
|---------------------------------------|-----------|--------------------------|------------------------|------------------------|------------------------|--------------------------|
| | | | L _{eq, 1 min} | L _{eq, 1 min} | L _{eq, 1 min} | |
| Emergency Generator Set (Intake) | N1-1* | 6 | 76.2 | 75.7 | 75.8 | 76.2 |
| Emergency Generator Set (Discharge) | N1-2* | 12 | 58.9 | 58 | 58.6 | 58.9 |
| Emergency Generator Set (Intake) | N2-1 | 6 | 76.2 | 75.7 | 75.8 | 76.2 |
| Emergency Generator Set (Discharge) | N2-2 | 12 | 58.9 | 58 | 58.6 | 58.9 |
| Electricity Substation (High Voltage) | N3^ | 6 | 62.5 | 62.3 | 61.8 | 62.5 |
| Electricity Substation (High Voltage) | N4 | 6 | 62.5 | 62.3 | 61.8 | 62.5 |
| Cooling Tower (Discharge) | N5-1-1 | 5 | 82.3 | 82.4 | 82.6 | 82.6 |
| Cooling Tower (Discharge) | N5-2-1 | 5 | 84.6 | 84.6 | 84.6 | 84.6 |
| Cooling Tower (Discharge) | N5-3-1 | 5 | 84 | 84.2 | 84.2 | 84.2 |
| Cooling Tower (Discharge) | N5-4-1 | 5 | 84.8 | 84.9 | 85.1 | 85.1 |
| Cooling Tower (Discharge) | N5-5-1 | 5 | 86.4 | 86.4 | 86.9 | 86.9 |
| Cooling Tower (Discharge) | N5-6-1 | 5 | 86.9 | 87 | 87 | 87 |
| Cooling Tower (Intake) | N5-1-2 | 6 | 77.2 | 77.1 | 77.1 | 77.2 |
| Cooling Tower (Intake) | N5-2-2 | 6 | 78.7 | 78.6 | 78.5 | 78.7 |
| Cooling Tower (Intake) | N5-3-2 | 6 | 77.8 | 77.8 | 77.6 | 77.8 |
| Cooling Tower (Intake) | N5-4-2 | 6 | 77.2 | 77.1 | 77.1 | 77.2 |
| Cooling Tower (Intake) | N5-5-2 | 6 | 76.4 | 76.1 | 76 | 76.4 |
| Cooling Tower (Intake) | N5-6-2 | 6 | 76.1 | 76.1 | 76.2 | 76.2 |
| Chiller Room | N6 | 6 | 71.4 | 70.7 | 70.9 | 71.4 |
| Low Voltage Substation | N7 | 5 | 69.1 | 68.4 | 68 | 69.1 |
| Pump Room and Wave Generator | N8 | 6 | 67.9 | 69.7 | 67.3 | 69.7 |

Remarks:


(*) Since the emergency generator set N1 cannot be operated during the noise measurement, the measured noise levels at a similar emergency generator set N2 were adopted in the fixed noise impact assessment.

(^) Since the electricity substation N3 cannot be operated during the noise measurement, the measured noise levels at a similar electricity substation N4 were adopted in the fixed noise impact assessment.

PA System / Loudspeaker



| Source ID | Measurement Distance (m) | Measured SPL, dB(A) | | | Max. Measured SPL, dB(A) |
|-----------|--------------------------|------------------------|------------------------|------------------------|--------------------------|
| | | L _{eq, 1 min} | L _{eq, 1 min} | L _{eq, 1 min} | |
| N1-3 | 2 | 66.8 | 69 | 69 | 69 |
| O1-3 | 2 | 69.6 | 67.8 | 69.6 | 69.6 |
| P1 | 2 | 77.6 | 73.3 | 70.9 | 77.6 |
| P2 | 2 | 77.6 | 73.3 | 70.9 | 77.6 |
| P3 | 2 | 77.6 | 73.3 | 70.9 | 77.6 |
| P4 | 2 | 77.6 | 73.3 | 70.9 | 77.6 |
| P5 | 2 | 77.6 | 73.3 | 70.9 | 77.6 |
| Q1 | 3 | 75 | 75.8 | 73.4 | 75.8 |
| Q2 | 3 | 75 | 75.8 | 73.4 | 75.8 |
| R1 | 2 | 77.6 | 74.2 | 75.2 | 77.6 |
| R2 | 2 | 77.6 | 74.2 | 75.2 | 77.6 |
| S1 | 2 | 79.2 | 78.9 | 78.7 | 79.2 |
| S2 | 2 | 79.2 | 78.9 | 78.7 | 79.2 |
| S3 | 2 | 79.2 | 78.9 | 78.7 | 79.2 |
| T1 | 2 | 75.5 | 73.6 | 74.7 | 75.5 |
| T2 | 2 | 75.5 | 73.6 | 74.7 | 75.5 |
| T3 | 2 | 75.5 | 73.6 | 74.7 | 75.5 |
| T4 | 2 | 75.5 | 73.6 | 74.7 | 75.5 |
| U1 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U2 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U3 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U4 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U5 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U6 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U7 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U8 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U9 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U10 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U11 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U12 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U13 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U14 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U15 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| U16 | 3 | 79.6 | 78.3 | 79.7 | 79.7 |
| V1 | 2 | 74.6 | 74.9 | 74.8 | 74.9 |
| V2 | 2 | 74.6 | 74.9 | 74.8 | 74.9 |
| V3 | 2 | 74.6 | 74.9 | 74.8 | 74.9 |
| V4 | 2 | 74.6 | 74.9 | 74.8 | 74.9 |
| V5 | 2 | 74.6 | 74.9 | 74.8 | 74.9 |
| V6 | 2 | 74.6 | 74.9 | 74.8 | 74.9 |
| V7 | 2 | 74.6 | 74.9 | 74.8 | 74.9 |
| V8 | 2 | 74.6 | 74.9 | 74.8 | 74.9 |
| W1-3 | 2 | 66.7 | 67.8 | 67.7 | 67.8 |
| X1-3 | 2 | 76.4 | 76.7 | 75.8 | 76.7 |
| Y1 | 2 | 72 | 72.4 | 72.2 | 72.4 |
| Y2 | 2 | 72 | 72.4 | 72.2 | 72.4 |
| Y3 | 2 | 72 | 72.4 | 72.2 | 72.4 |
| Y4 | 2 | 72 | 72.4 | 72.2 | 72.4 |
| Z1 | 2 | 75.7 | 76.4 | 76.4 | 76.4 |
| Z2 | 2 | 75.7 | 76.4 | 76.4 | 76.4 |
| Z3 | 2 | 75.7 | 76.4 | 76.4 | 76.4 |
| Z4 | 2 | 75.7 | 76.4 | 76.4 | 76.4 |

Appendix D Information from Ocean Park Corporation




GENERAL NOTES:


- NOTE :
- 7.5m CLEARANCE TO COOLING TOWER EXHAUST
 - 5m CLEARANCE TO COOLING TOWER INTAKE



EAST TOWER ELEVATION A (SCALE 1:100)



EAST TOWER ELEVATION B (SCALE 1:100)



EAST TOWER ELEVATION C (SCALE 1:100)

| | | |
|---|------------|------------------------|
| 1 | 01-08-2019 | AS PER EMSD COMMENT |
| 0 | 26-06-2019 | 1ST EMSD-CT SUBMISSION |

Quantity Surveyors
AECOM Cost Consulting (Hong Kong) Limited

Structural & Geotechnical Consultant
SIU YIN WAI & ASSOCIATES LIMITED
8/F, LIPPO LEIGHTON TOWER,
103-109 LEIGHTON ROAD,
CAUSEWAY BAY, HONG KONG

E & M Consultant
ARUP Ove Arup & Partners
Hong Kong Ltd.
LEVEL 17 TOWER 1 GRAND CENTURY
PLACE 193 PRINCE EDWARD ROAD,
WEST MONG KOK
KOWLOON, HONGKONG

Traffic Consultant
MVA Hong Kong Limited

Utility Diversion Consultant
LAND MARKER (1980) HK CO LTD

Architect
+ + 31/F One Island East
18 Wheelands Road
Quarry Bay
Hong Kong
Aedas
+ + T +852 2861 1728
F +852 2529 6419
hongkong@aedas.com
aedas.com

Owner
Ocean Park Ocean Park Corporation

Client
Parkland (Hong Kong) Limited

MAIN CONTRACTOR
Gammon

MVAC CONTRACTOR:
KRUEGER ENGINEERING(ASIA) LIMITED
Suite 2003, 20/F., 148 Electric Road,
North Point, Hong Kong
Tel: 28607333 Fax: 28667132

PROJECT
Proposed Hotel Development at Ocean Park
Tai Shue Wan, HONG KONG R.B.L. 1020 & Ext.

DRAWING TITLE
ROOF LAYOUT, ELEVATION FOR CRITICAL
OPENINGS

CHECKED BY
KEL-18-038-
AC-CT-S-101

DRAWN BY
CMC

SCALE
1:100

REV.
0

Cooling Tower Technical Data Sheet



Registration No.:
PS - 2018-000-017-No.1 to No.4
Cooling Tower Ref. :
CT-01 to 03

Suzie Xi
1159, Luoning Rd, Baoshan district, Shanghai
Shanghai, 200237
CN
☎ 15221305620
✉ sxi@evapcochina.com

(1) UT 114-4024


Project Details

Project Name : ATAL - OPPO
Location: TBD

Date: 2018/11/20
Customer:
Contact:
Contact Email:

Product Description

The original Advanced Technology cooling tower provides an induced-draft, axial fan solution for a wide array of outdoor cooling capacities.



Selection Criteria

| Selection Criteria | Total | Each Unit | Required Capacity |
|----------------------|-----------|-----------|-------------------|
| Flow: | 186.6 LPS | 186.6 LPS | 3,900.00 kW |
| Fluid: | Water | Water | 887.31 Tons |
| Entering Fluid Temp: | 37.0°C | 37.0°C | 3,354,037 kcal/hr |
| Leaving Fluid Temp: | 32.0°C | 32.0°C | |
| Entering Wet Bulb: | 29.0°C | 29.0°C | |

Unit Selected

One(1) EVAPCO UT 114-4024 at 102.4% capacity (3,993.52 kW)

Product Line is CTI/ECC Certified. Design conditions are outside the scope of CTI Standard 201 RS.



Physical Data Per Unit

| | |
|-----------------------------|-----------------------------|
| Overall Dimensions (WxLxH): | 4,248mm x 7,239mm x 6,277mm |
| Operating Weight: | 17,099 kg |
| Shipping Weight: | 9,226 kg |
| Heaviest Section: | 6,577 kg |

*weights and dimensions could vary depending on options selected

IBC Design Capability

| | |
|---------------------------------|-----------------------|
| IBC Standard Structural Design | |
| 1.0 Importance Factor Specified | |
| Seismic(SDs): | up to 1.34 g, z/h = 0 |
| Wind Load(P): | up to 5.7 kPa |

Fan Motor Data per Unit

| | |
|-----------------------------|--------------------|
| Number of Fans: | 1 |
| # of Fan Motors: | 1 |
| Nameplate Power (380/3/50): | 37.00 kW Per Motor |

Additional Details

| | |
|-----------|----------------------|
| Air Flow: | 97 m ³ /s |
|-----------|----------------------|

Hydraulic Data

| | |
|------------------------|----------|
| Inlet Pressure Drop: | 20.6 kPa |
| Evaporated Water Rate: | 1.34 LPS |

Layout Criteria

| | |
|-------------------------|-------|
| From FACE B/D to wall: | 0.91m |
| From FACE A/C to wall: | 0.91m |
| Between FACE B/D ends: | 0.91m |
| Between FACE A/C sides: | 1.52m |

Sound Data(dB(A) @ 1.5m/15m)

| | | | |
|-------------------------|-------|----------------------|-------|
| Face A (Opp Mtr. Side): | 70/56 | Face C (Motor Side): | 70/56 |
| Face B (End): | 71/55 | Face D (Opp End): | 71/55 |
| Top: | 71/59 | | |

Notes: Sound Pressure Levels are according to CTI Standard ATC-128. Sound data is shown for 1 cell operating at full speed. The use of frequency inverters (Variable Frequency Drives) can increase sound levels. Sound Options: Super Low Sound Fan, Water Silencers

Shipping Data

1 Basin Sections: (WxLxH): 4241mm x 7467mm x 2667mm ; 2648kg each* | 1 Casing Sections: (WxLxH): 4241mm x 7696mm x 3505mm ; 6577kg each*
*dimensions and weights above include shipping skids

Accessories

| | | |
|---|--|-------------------------------------|
| (1) Equalizer Connection; TBD; 100 mm; BFW/GRVD; TBD | (1) Super Low Sound Fan | (1) EVAPAK Fill |
| (1) Louver Access Door | (1) Aluminum Ladder | (1) Water Silencers |
| (1) IBC Standard Structural Design | (1) Fan Motor: Inverter Capable (5~50 Hz, 6~60 Hz) | (1) 1.0 Importance Factor Specified |
| (1) Bottom inlet, including all internal piping | | |

Cooling Tower Technical Data Sheet



Registration No.:
PS - 2018-000-017-No.1 to No.4
Cooling Tower Ref. :
CT-04

Suzie Xi
1159, Luoning Rd, Baoshan district, Shanghai,
Shanghai, 200237
CN
☎ 15221305620
✉ sxi@evapcochina.com

(1) UT 112-3018


Project Details

Project Name : ATAL - OPPO
Location: TBD

Date: 2018/11/20
Customer:
Contact:
Contact Email:

Product Description

The original Advanced Technology cooling tower provides an induced-draft, axial fan solution for a wide array of outdoor cooling capacities.



Selection Criteria

| Selection Criteria | Total | Each Unit | Required Capacity |
|----------------------|-----------|-----------|-------------------|
| Flow: | 138.8 LPS | 138.8 LPS | 2,900.00 kW |
| Fluid: | Water | Water | 659.8 Tons |
| Entering Fluid Temp: | 37.0°C | 37.0°C | 2,494,028 kcal/hr |
| Leaving Fluid Temp: | 32.0°C | 32.0°C | |
| Entering Wet Bulb: | 29.0°C | 29.0°C | |

Unit Selected

One(1) EVAPCO UT 112-3018 at 100% capacity (2,899.94 kW)

Product Line is CTI/ECC Certified. Design conditions are outside the scope of CTI Standard 201 RS.



Physical Data Per Unit

| | |
|--|-----------------------------|
| Overall Dimensions (WxLxH): | 3,607mm x 5,486mm x 5,124mm |
| Operating Weight: | 10,812 kg |
| Shipping Weight: | 5,951 kg |
| Heaviest Section: | 4,182 kg |
| *weights and dimensions could vary depending on options selected | |

IBC Design Capability

| | |
|---------------------------------|-----------------------|
| IBC Standard Structural Design | |
| 1.0 Importance Factor Specified | |
| Seismic(SDs): | up to 1.34 g, z/h = 0 |
| Wind Load(P): | up to 5.7 kPa |

Fan Motor Data per Unit

| | |
|-----------------------------|--------------------|
| Number of Fans: | 1 |
| # of Fan Motors: | 1 |
| Nameplate Power (380/3/50): | 37.00 kW Per Motor |

Additional Details

| | |
|-----------|---------|
| Air Flow: | 75 m³/s |
|-----------|---------|

Hydraulic Data

| | |
|------------------------|----------|
| Inlet Pressure Drop: | 22.8 kPa |
| Evaporated Water Rate: | 1.00 LPS |

Layout Criteria

| | |
|-------------------------|-------|
| From FACE B/D to wall: | 0.91m |
| From FACE A/C to wall: | 0.91m |
| Between FACE B/D ends: | 0.91m |
| Between FACE A/C sides: | 1.83m |

Sound Data(dB(A) @ 1.5m/15m)

| | | | |
|-------------------------|-------|----------------------|-------|
| Face A (Opp Mtr. Side): | 70/56 | Face C (Motor Side): | 70/56 |
| Face B (End): | 70/55 | Face D (Opp End): | 70/55 |
| Top: | 71/59 | | |

Notes: Sound Pressure Levels are according to CTI Standard ATC-128. Sound data is shown for 1 cell operating at full speed. The use of frequency inverters (Variable Frequency Drives) can increase sound levels. Sound Options: Super Low Sound Fan, Water Silencers

Shipping Data

1 Basin Sections: (WxLxH): 3606mm x 5638mm x 2006mm ; 1769kg each* | 1 Casing Sections: (WxLxH): 3606mm x 6045mm x 2971mm ; 4182kg each*
*dimensions and weights above include shipping skids

Accessories

| | | |
|---|-------------------------------------|---|
| (1) Equalizer Connection; TBD; 100 mm; BFW/GRVD; TBD | (1) Super Low Sound Fan | (1) EVAPAK Fill |
| (1) Fan Motor: Inverter Capable (5~50 Hz, 6~60 Hz) | (1) Aluminum Ladder | (1) Water Silencers |
| (1) IBC Standard Structural Design | (1) 1.0 Importance Factor Specified | (1) Bottom inlet, including all internal piping |

Appendix E Fixed Noise Impact Assessment


Predicted Fixed Noise Impact from Fixed Noise Sources - Day-time Period (7am - 7pm)

| NSR ID | NSR Description | Fixed Noise Source | Source ID | Measured SPL, dB(A) | No. of Equipment | Total SPL, dB(A) | Measurement Distance (m) | Horizontal Distance (m) | Distance Attenuation dB(A) | Tonality Correction dB(A) | Screening Correction dB(A) | Facade Correction dB(A) | SPL, L _{eq(30min)} , dB(A) | Total SPL, L _{eq(30min)} , dB(A) | Assessment Period | Noise Criteria, dB(A) | | | | | | |
|--------|---------------------------|--|-----------|---------------------------|---|------------------|--------------------------|-------------------------|----------------------------|---------------------------|----------------------------|-------------------------|-------------------------------------|---|-------------------|-----------------------|-----|------|------|------|----------|----|
| VSA | Victoria Shanghai Academy | Major Fixed Plants within Tai Shue Wan Development | N1-1 | 76 | 1 | 76 | 6.0 | 519 | -39 | 0 | -10 | 3 | 30.3 | 44.5 | Day-time | 55 | | | | | | |
| | | | N1-2 | 59 | 1 | 59 | 12.0 | 515 | -33 | 0 | -10 | 3 | 19.3 | | | | | | | | | |
| | | | N2-1 | 76 | 1 | 76 | 6.0 | 643 | -41 | 0 | -10 | 3 | 28.4 | | | | | | | | | |
| | | | N2-2 | 59 | 1 | 59 | 12.0 | 641 | -35 | 0 | -10 | 3 | 17.4 | | | | | | | | | |
| | | | N3 | 63 | 1 | 63 | 6.0 | 522 | -39 | 0 | -10 | 3 | 17.2 | | | | | | | | | |
| | | | N4 | 63 | 1 | 63 | 6.0 | 524 | -39 | 0 | -10 | 3 | 17.2 | | | | | | | | | |
| | | | N5-1-1 | 83 | 1 | 83 | 5.0 | 699 | -43 | 0 | -10 | 3 | 33.1 | | | | | | | | | |
| | | | N5-2-1 | 85 | 1 | 85 | 5.0 | 700 | -43 | 0 | -10 | 3 | 35.1 | | | | | | | | | |
| | | | N5-3-1 | 84 | 1 | 84 | 5.0 | 701 | -43 | 0 | -10 | 3 | 34.1 | | | | | | | | | |
| | | | N5-4-1 | 85 | 1 | 85 | 5.0 | 710 | -43 | 0 | -10 | 3 | 35.0 | | | | | | | | | |
| | | | N5-5-1 | 87 | 1 | 87 | 5.0 | 711 | -43 | 0 | -10 | 3 | 36.9 | | | | | | | | | |
| | | | N5-6-1 | 87 | 1 | 87 | 5.0 | 712 | -43 | 0 | -10 | 3 | 36.9 | | | | | | | | | |
| | | | N5-1-2 | 77 | 1 | 77 | 6.0 | 696 | -41 | 0 | -10 | 3 | 28.7 | | | | | | | | | |
| | | | N5-2-2 | 79 | 1 | 79 | 6.0 | 696 | -41 | 0 | -10 | 3 | 30.7 | | | | | | | | | |
| | | | N5-3-2 | 78 | 1 | 78 | 6.0 | 697 | -41 | 0 | -10 | 3 | 29.7 | | | | | | | | | |
| | | | N5-4-2 | 77 | 1 | 77 | 6.0 | 713 | -42 | 0 | -10 | 3 | 28.5 | | | | | | | | | |
| | | | N5-5-2 | 76 | 1 | 76 | 6.0 | 714 | -42 | 0 | -10 | 3 | 27.5 | | | | | | | | | |
| | | | N5-6-2 | 76 | 1 | 76 | 6.0 | 715 | -42 | 0 | -10 | 3 | 27.5 | | | | | | | | | |
| | | | N6 | 71 | 1 | 71 | 6.0 | 677 | -41 | 0 | -10 | 3 | 22.9 | | | | | | | | | |
| | | | N7 | 69 | 1 | 69 | 5.0 | 660 | -42 | 0 | -10 | 3 | 19.6 | | | | | | | | | |
| | | | N8 | 70 | 1 | 70 | 6.0 | 642 | -41 | 0 | -10 | 3 | 22.4 | | | | | | | | | |
| | | | VSA | Victoria Shanghai Academy | PA System / Loudspeaker within Tai Shue Wan Development | A1 | 71 | 1 | 71 | 2.0 | 531 | -48 | 0 | | | | -10 | 3 | 15.5 | 43.8 | Day-time | 55 |
| | | | | | | A2 | 71 | 1 | 71 | 2.0 | 531 | -48 | 0 | | | | -10 | 3 | 15.5 | | | |
| | | | | | | A3 | 71 | 1 | 71 | 2.0 | 542 | -49 | 0 | | | | -10 | 3 | 15.3 | | | |
| | | | | | | A4 | 71 | 1 | 71 | 2.0 | 543 | -49 | 0 | | | | -10 | 3 | 15.3 | | | |
| | | | | | | A5 | 71 | 1 | 71 | 2.0 | 562 | -49 | 0 | | | | -10 | 3 | 15.0 | | | |
| | | | | | | A6 | 71 | 1 | 71 | 2.0 | 562 | -49 | 0 | | | | -10 | 3 | 15.0 | | | |
| | | B1 | | | | 72 | 1 | 72 | 2.0 | 534 | -49 | 0 | -10 | | | | 3 | 16.5 | | | | |
| | | B2 | | | | 72 | 1 | 72 | 2.0 | 537 | -49 | 0 | -10 | | | | 3 | 16.4 | | | | |
| | | B3 | | | | 72 | 1 | 72 | 2.0 | 548 | -49 | 0 | -10 | | | | 3 | 16.2 | | | | |
| | | B4 | | | | 72 | 1 | 72 | 2.0 | 558 | -49 | 0 | -10 | | | | 3 | 16.1 | | | | |
| | | C1 | | | | 76 | 1 | 76 | 3.0 | 549 | -45 | 0 | -10 | | | | 3 | 23.8 | | | | |
| | | C2 | | | | 76 | 1 | 76 | 3.0 | 559 | -45 | 0 | -10 | | | | 3 | 23.6 | | | | |
| | | C3 | | | | 76 | 1 | 76 | 3.0 | 562 | -45 | 0 | -10 | | | | 3 | 23.6 | | | | |
| | | C4 | | | | 76 | 1 | 76 | 3.0 | 556 | -45 | 0 | -10 | | | | 3 | 23.6 | | | | |
| | | C5 | | | | 76 | 1 | 76 | 3.0 | 546 | -45 | 0 | -10 | | | | 3 | 23.8 | | | | |
| | | C6 | | | | 76 | 1 | 76 | 3.0 | 543 | -45 | 0 | -10 | | | | 3 | 23.8 | | | | |
| | | C7 | | | | 76 | 1 | 76 | 3.0 | 531 | -45 | 0 | -10 | | | | 3 | 24.0 | | | | |
| | | C8 | | | | 76 | 1 | 76 | 3.0 | 528 | -45 | 0 | -10 | | | | 3 | 24.1 | | | | |
| | | C9 | | | | 76 | 1 | 76 | 3.0 | 527 | -45 | 0 | -10 | | | | 3 | 24.1 | | | | |
| | | C10 | | | | 76 | 1 | 76 | 3.0 | 531 | -45 | 0 | -10 | | | | 3 | 24.0 | | | | |
| | | C11 | | | | 76 | 1 | 76 | 3.0 | 534 | -45 | 0 | -10 | | | | 3 | 24.0 | | | | |
| | | C12 | | | | 76 | 1 | 76 | 3.0 | 535 | -45 | 0 | -10 | | | | 3 | 24.0 | | | | |
| | | C13 | | | | 76 | 1 | 76 | 3.0 | 544 | -45 | 0 | -10 | | | | 3 | 23.8 | | | | |
| | | C14 | | | | 76 | 1 | 76 | 3.0 | 546 | -45 | 0 | -10 | | | | 3 | 23.8 | | | | |
| | | C15 | | | | 76 | 1 | 76 | 3.0 | 553 | -45 | 0 | -10 | | | | 3 | 23.7 | | | | |
| | | C16 | | | | 76 | 1 | 76 | 3.0 | 563 | -45 | 0 | -10 | | | | 3 | 23.5 | | | | |
| | | C17 | | | | 76 | 1 | 76 | 3.0 | 573 | -46 | 0 | -10 | | | | 3 | 23.4 | | | | |
| C18 | 76 | 1 | | | | 76 | 3.0 | 580 | -46 | 0 | -10 | 3 | 23.3 | | | | | | | | | |
| C19 | 76 | 1 | | | | 76 | 3.0 | 581 | -46 | 0 | -10 | 3 | 23.3 | | | | | | | | | |
| C20 | 76 | 1 | | | | 76 | 3.0 | 581 | -46 | 0 | -10 | 3 | 23.3 | | | | | | | | | |
| C21 | 76 | 1 | | | | 76 | 3.0 | 581 | -46 | 0 | -10 | 3 | 23.3 | | | | | | | | | |
| C22 | 76 | 1 | | | | 76 | 3.0 | 579 | -46 | 0 | -10 | 3 | 23.3 | | | | | | | | | |
| C23 | 76 | 1 | | | | 76 | 3.0 | 575 | -46 | 0 | -10 | 3 | 23.4 | | | | | | | | | |
| C24 | 76 | 1 | | | | 76 | 3.0 | 570 | -46 | 0 | -10 | 3 | 23.4 | | | | | | | | | |
| D1 | 74 | 1 | | | | 74 | 2.0 | 651 | -50 | 0 | -10 | 3 | 16.7 | | | | | | | | | |
| D2 | 74 | 1 | | | | 74 | 2.0 | 655 | -50 | 0 | -10 | 3 | 16.7 | | | | | | | | | |
| D3 | 74 | 1 | | | | 74 | 2.0 | 661 | -50 | 0 | -10 | 3 | 16.6 | | | | | | | | | |
| D4 | 74 | 1 | | | | 74 | 2.0 | 665 | -50 | 0 | -10 | 3 | 16.6 | | | | | | | | | |
| E1 | 74 | 1 | | | | 74 | 2.0 | 626 | -50 | 0 | -10 | 3 | 17.1 | | | | | | | | | |
| E2 | 74 | 1 | | | | 74 | 2.0 | 628 | -50 | 0 | -10 | 3 | 17.1 | | | | | | | | | |
| E3 | 74 | 1 | | | | 74 | 2.0 | 631 | -50 | 0 | -10 | 3 | 17.0 | | | | | | | | | |
| E4 | 74 | 1 | | | | 74 | 2.0 | 634 | -50 | 0 | -10 | 3 | 17.0 | | | | | | | | | |
| E5 | 74 | 1 | | | | 74 | 2.0 | 636 | -50 | 0 | -10 | 3 | 17.0 | | | | | | | | | |
| E6 | 74 | 1 | | | | 74 | 2.0 | 639 | -50 | 0 | -10 | 3 | 16.9 | | | | | | | | | |
| E7 | 74 | 1 | | | | 74 | 2.0 | 644 | -50 | 0 | -10 | 3 | 16.8 | | | | | | | | | |
| E8 | 74 | 1 | | | | 74 | 2.0 | 667 | -50 | 0 | -10 | 3 | 16.5 | | | | | | | | | |
| F1 | 74 | 1 | | | | 74 | 4.0 | 560 | -43 | 0 | -10 | 3 | 24.1 | | | | | | | | | |
| F2 | 74 | 1 | | | | 74 | 4.0 | 560 | -43 | 0 | -10 | 3 | 24.1 | | | | | | | | | |
| F3 | 74 | 1 | 74 | 4.0 | 560 | -43 | 0 | -10 | 3 | 24.1 | | | | | | | | | | | | |
| G1 | 74 | 1 | 74 | 2.0 | 564 | -49 | 0 | -10 | 3 | 18.0 | | | | | | | | | | | | |
| G2 | 74 | 1 | 74 | 2.0 | 563 | -49 | 0 | -10 | 3 | 18.0 | | | | | | | | | | | | |
| H1 | 75 | 1 | 75 | 2.0 | 593 | -49 | 0 | -10 | 3 | 18.6 | | | | | | | | | | | | |
| H2 | 75 | 1 | 75 | 2.0 | 588 | -49 | 0 | -10 | 3 | 18.6 | | | | | | | | | | | | |
| H3 | 75 | 1 | 75 | 2.0 | 584 | -49 | 0 | -10 | 3 | 18.7 | | | | | | | | | | | | |
| H4 | 75 | 1 | 75 | 2.0 | 582 | -49 | 0 | -10 | 3 | 18.7 | | | | | | | | | | | | |
| H5 | 75 | 1 | 75 | 2.0 | 583 | -49 | 0 | -10 | 3 | 18.7 | | | | | | | | | | | | |
| H6 | 75 | 1 | 75 | 2.0 | 585 | -49 | 0 | -10 | 3 | 18.7 | | | | | | | | | | | | |
| H7 | 75 | 1 | 75 | 2.0 | 587 | -49 | 0 | -10 | 3 | 18.6 | | | | | | | | | | | | |
| H8 | 75 | 1 | 75 | 2.0 | 593 | -49 | 0 | -10 | 3 | 18.6 | | | | | | | | | | | | |
| H9 | 75 | 1 | 75 | 2.0 | 593 | -49 | 0 | -10 | 3 | 18.6 | | | | | | | | | | | | |
| H10 | 75 | 1 | 75 | 2.0 | 591 | -49 | 0 | -10 | 3 | 18.6 | | | | | | | | | | | | |
| I1 | 74 | 1 | 74 | 2.0 | 593 | -49 | 0 | -10 | 3 | 17.6 | | | | | | | | | | | | |
| I2 | 74 | 1 | 74 | 2.0 | 595 | -49 | 0 | -10 | 3 | 17.5 | | | | | | | | | | | | |
| I3 | 74 | 1 | 74 | 2.0 | 597 | -50 | 0 | -10 | 3 | 17.5 | | | | | | | | | | | | |
| I4 | 74 | 1 | 74 | 2.0 | 601 | -50 | 0 | -10 | 3 | 17.4 | | | | | | | | | | | | |
| I5 | 74 | 1 | 74 | 2.0 | 605 | -50 | 0 | -10 | 3 | 17.4 | | | | | | | | | | | | |
| I6 | 74 | 1 | 74 | 2.0 | 609 | -50 | 0 | -10 | 3 | 17.3 | | | | | | | | | | | | |
| I7 | 74 | 1 | 74 | 2.0 | 615 | -50 | 0 | -10 | 3 | 17.2 | | | | | | | | | | | | |
| J1 | 72 | 1 | 72 | 2.0 | 593 | -49 | 0 | -10 | 3 | 15.6 | | | | | | | | | | | | |
| J2 | 72 | 1 | 72 | 2.0 | 593 | -49 | 0 | -10 | 3 | 15.6 | | | | | | | | | | | | |
| J3 | 72 | 1 | 72 | 2.0 | 599 | -50 | 0 | -10 | 3 | 15.5 | | | | | | | | | | | | |
| J4 | 72 | 1 | 72 | 2.0 | 598 | -50 | 0 | -10 | 3 | 15.5 | | | | | | | | | | | | |
| J5 | 72 | 1 | 72 | 2.0 | 603 | -50 | 0 | -10 | 3 | 15.4 | | | | | | | | | | | | |
| J6 | 72 | 1 | 72 | 2.0 | 608 | -50 | 0 | -10 | 3 | 15.3 | | | | | | | | | | | | |
| J7 | 72 | 1 | 72 | 2.0 | 612 | -50 | 0 | -10 | 3 | 15.3 | | | | | | | | | | | | |
| K1 | 76 | 1 | 76 | 2.0 | 550 | -49 | 0 | -10 | 3 | 20.2 | | | | | | | | | | | | |
| K2 | 76 | 1 | 76 | 2.0 | 550 | -49 | 0 | -10 | 3 | 20.2 | | | | | | | | | | | | |
| K3 | 76 | 1 | 76 | 2.0 | 548 | -49 | 0 | -10 | 3 | 20.2 | | | | | | | | | | | | |
| K4 | 76 | 1 | 76 | 2.0 | 548 | -49 | 0 | -10 | 3 | 20.2 | | | | | | | | | | | | |
| L1 | 77 | 1 | 77 | 2.0 | 563 | -49 | 0 | -10 | 3 | 21.0 | | | | | | | | | | | | |
| L2 | 77 | 1 | 77 | 2.0 | 564 | -49 | 0 | -10 | 3 | 21.0 | | | | | | | | | | | | |
| L3 | 77 | 1 | 77 | 2.0 | 572 | -49 | 0 | -10 | 3 | 20.9 | | | | | | | | | | | | |
| M1 | 69 | 1 | 69 | 2.0 | 563 | -49 | 0 | -10 | 3 | 13.0 | | | | | | | | | | | | |
| M2 | 69 | 1 | 69 | 2.0 | 566 | -49 | 0 | -10 | 3 | 13.0 | | | | | | | | | | | | |
| M3 | 69 | 1 | 69 | 2.0 | 569 | -49 | 0 | -10 | 3 | 12.9 | | | | | | | | | | | | |
| M4 | 69 | 1 | 69 | 2.0 | 572 | -49 | 0 | -10 | 3 | 12.9 | | | | | | | | | | | | |
| M5 | 69 | 1 | 69 | 2.0 | 575 | -49 | 0 | -10 | 3 | 12.8 | | | | | | | | | | | | |
| M6 | 69 | 1 | 69 | 2.0 | 580 | -49 | 0 | -10 | 3 | 12.8 | | | | | | | | | | | | |
| M7 | 69 | 1 | 69 | 2.0 | 583 | -49 | 0 | -10 | 3 | 12.7 | | | | | | | | | | | | |
| N1-3 | 69 | 3 | 74 | 2.0 | 590 | -49 | 0 | -10 | 3 | 17.6 | | | | | | | | | | | | |
| O1-3 | 70 | 3 | 74 | 2.0 | 597 | -50 | 0 | -10 | 3 | 17.5 | | | | | | | | | | | | |
| P1 | 78 | 1 | 78 | 2.0 | 598 | -50 | 0 | -10 | 3 | 21.5 | | | | | | | | | | | | |
| P2 | 78 | 1 | 78 | 2.0 | 604 | -50 | 0 | -10 | 3 | 21.4 | | | | | | | | | | | | |
| P3 | 78 | 1 | 78 | 2.0 | 607 | -50 | 0 | -10 | 3 | 21.4 | | | | | | | | | | | | |
| P4 | 78 | 1 | 78 | 2.0 | 612 | -50 | 0 | -10 | 3 | 21.3 | | | | | | | | | | | | |
| P5 | 78 | 1 | 78 | 2.0 | 616 | -50 | 0 | -10 | 3 | 21.2 | | | | | | | | | | | | |
| Q1 | 76 | 1 | 76 | 3.0 | 606 | -46 | 0 | -10 | 3 | 22.9 | | | | | | | | | | | | |
| Q2 | 76 | 1 | 76 | 3.0 | 607 | -46 | 0 | -10 | 3 | 22.9 | | | | | | | | | | | | |
| R1 | 78 | 1 | 78 | 2.0 | 623 | -50 | 0 | -10 | 3 | 21.1 | | | | | | | | | | | | |
| R2 | 78 | 1 | 78 | 2.0 | 624 | -50 | 0 | -10 | 3 | 21.1 | | | | | | | | | | | | |
| S1 | 79 | 1 | 79 | 2.0 | 626 | -50 | 0 | -10 | 3 | 22.1 | | | | | | | | | | | | |
| S2 | 79 | 1 | 79 | 2.0 | 633 | -50 | 0 | -10 | 3 | 22.0 | | | | | | | | | | | | |
| S3 | 79 | 1 | 79 | 2.0 | 641 | -50 | 0 | -10 | 3 | 21.9 | | | | | | | | | | | | |
| T1 | 76 | 1 | 76 | 2.0 | 564 | -49 | 0 | -10 | 3 | 20.0 | | | | | | | | | | | | |
| T2 | 76 | 1 | 76 | 2.0 | 565 | -49 | 0 | -10 | 3 | 20.0 | | | | | | | | | | | | |
| T3 | 76 | 1 | 76 | 2.0 | 565 | -49 | 0 | -10 | 3 | 20.0 | | | | | | | | | | | | |
| T4 | 76 | 1 | 76 | 2.0 | 565 | -49 | 0 | -10 | 3 | 20.0 | | | | | | | | | | | | |
| U1 | 80 | 1 | 80 | 3.0 | 557 | -45 | 0 | -10 | 3 | 27.6 | | | | | | | | | | | | |
| U2 | 80 | 1 | 80 | 3.0 | 555 | -45 | 0 | -10 | 3 | 27.7 | | | | | | | | | | | | |
| U3 | 80 | 1 | 80 | 3.0 | 553 | -45 | 0 | -10 | 3 | 27.7 | | | | | | | | | | | | |
| U4 | 80 | 1 | 80 | 3.0 | 549 | -45 | 0 | -10 | 3 | 27.8 | | | | | | | | | | | | |
| U5 | 80 | 1 | 80 | 3.0 | 547 | -45 | 0 | -10 | 3 | 27.8 | | | | | | | | | | | | |
| U6 | 80 | 1 | 80 | 3.0 | 546 | -45 | 0 | -10 | 3 | 27.8 | | | | | | | | | | | | |
| U7 | 80 | 1 | 80 | 3.0 | 539 | -45 | 0 | -10 | 3 | 27.9 | | | | | | | | | | | | |
| U8 | 80 | 1 | 80 | 3.0 | 533 | -45 | 0 | -10 | 3 | 28.0 | | | | | | | | | | | | |
| U9 | 80 | 1 | 80 | 3.0 | 523 | -45 | 0 | -10 | 3 | 28.2 | | | | | | | | | | | | |
| U10 | 80 | 1 | 80 | 3.0 | 526 | -45 | | | | | | | | | | | | | | | | |

Predicted Fixed Noise Impact from Fixed Noise Sources - Day-time & Evening Periods (7am - 11pm)

| NSR ID | NSR Description | Fixed Noise Source | Source ID | Measured SPL, dB(A) | No. of Equipment | Total SPL, dB(A) | Measurement Distance (m) | Horizontal Distance (m) | Distance Attenuation dB(A) | Tonality Correction dB(A) | Screening Correction dB(A) | Facade Correction dB(A) | SPL, L _{eq(30min)} , dB(A) | Total SPL, L _{eq(30min)} , dB(A) | Assessment Period | Noise Criteria, dB(A) |
|--------|--------------------------------|--|-----------|---------------------|------------------|------------------|--------------------------|-------------------------|----------------------------|---------------------------|----------------------------|-------------------------|-------------------------------------|---|--------------------|-----------------------|
| HKJCC | Hong Kong Juvenile Care Centre | Major Fixed Plants within Tai Shue Wan Development | N1-1 | 76 | 1 | 76 | 6.0 | 515 | -39 | 0 | -10 | 3 | 30.3 | 44.5 | Day-time & Evening | 50 |
| | | | N1-2 | 59 | 1 | 59 | 12.0 | 514 | -33 | 0 | -10 | 3 | 19.4 | | | |
| | | | N2-1 | 76 | 1 | 76 | 6.0 | 621 | -40 | 0 | -10 | 3 | 28.7 | | | |
| | | | N2-2 | 59 | 1 | 59 | 12.0 | 610 | -34 | 0 | -10 | 3 | 17.9 | | | |
| | | | N3 | 63 | 1 | 63 | 6.0 | 527 | -39 | 0 | -10 | 3 | 17.1 | | | |
| | | | N4 | 63 | 1 | 63 | 6.0 | 525 | -39 | 0 | -10 | 3 | 17.2 | | | |
| | | | N5-1-1 | 83 | 1 | 83 | 5.0 | 701 | -43 | 0 | -10 | 3 | 33.1 | | | |
| | | | N5-2-1 | 85 | 1 | 85 | 5.0 | 701 | -43 | 0 | -10 | 3 | 35.1 | | | |
| | | | N5-3-1 | 84 | 1 | 84 | 5.0 | 701 | -43 | 0 | -10 | 3 | 34.1 | | | |
| | | | N5-4-1 | 85 | 1 | 85 | 5.0 | 712 | -43 | 0 | -10 | 3 | 34.9 | | | |
| | | | N5-5-1 | 87 | 1 | 87 | 5.0 | 712 | -43 | 0 | -10 | 3 | 36.9 | | | |
| | | | N5-6-1 | 87 | 1 | 87 | 5.0 | 712 | -43 | 0 | -10 | 3 | 36.9 | | | |
| | | | N5-1-2 | 77 | 1 | 77 | 6.0 | 698 | -41 | 0 | -10 | 3 | 28.7 | | | |
| | | | N5-2-2 | 79 | 1 | 79 | 6.0 | 698 | -41 | 0 | -10 | 3 | 30.7 | | | |
| | | | N5-3-2 | 78 | 1 | 78 | 6.0 | 698 | -41 | 0 | -10 | 3 | 29.7 | | | |
| | | | N5-4-2 | 77 | 1 | 77 | 6.0 | 715 | -42 | 0 | -10 | 3 | 28.5 | | | |
| | | | N5-5-2 | 76 | 1 | 76 | 6.0 | 715 | -42 | 0 | -10 | 3 | 27.5 | | | |
| | | | N5-6-2 | 76 | 1 | 76 | 6.0 | 715 | -42 | 0 | -10 | 3 | 27.5 | | | |
| | | N6 | 71 | 1 | 71 | 6.0 | 672 | -41 | 0 | -10 | 3 | 23.0 | | | | |
| | | N7 | 69 | 1 | 69 | 5.0 | 644 | -42 | 0 | -10 | 3 | 19.8 | | | | |
| | | N8 | 70 | 1 | 70 | 6.0 | 611 | -40 | 0 | -10 | 3 | 22.8 | | | | |
| | | A1 | 71 | 1 | 71 | 2.0 | 553 | -49 | 0 | -10 | 3 | 15.2 | | | | |
| | | A2 | 71 | 1 | 71 | 2.0 | 553 | -49 | 0 | -10 | 3 | 15.2 | | | | |
| | | A3 | 71 | 1 | 71 | 2.0 | 555 | -49 | 0 | -10 | 3 | 15.1 | | | | |
| | | A4 | 71 | 1 | 71 | 2.0 | 555 | -49 | 0 | -10 | 3 | 15.1 | | | | |
| | | A5 | 71 | 1 | 71 | 2.0 | 565 | -49 | 0 | -10 | 3 | 15.0 | | | | |
| | | A6 | 71 | 1 | 71 | 2.0 | 565 | -49 | 0 | -10 | 3 | 15.0 | | | | |
| | | B1 | 72 | 1 | 72 | 2.0 | 553 | -49 | 0 | -10 | 3 | 16.2 | | | | |
| | | B2 | 72 | 1 | 72 | 2.0 | 553 | -49 | 0 | -10 | 3 | 16.2 | | | | |
| | | B3 | 72 | 1 | 72 | 2.0 | 557 | -49 | 0 | -10 | 3 | 16.1 | | | | |
| | | B4 | 72 | 1 | 72 | 2.0 | 563 | -49 | 0 | -10 | 3 | 16.0 | | | | |
| | | C1 | 76 | 1 | 76 | 3.0 | 545 | -45 | 0 | -10 | 3 | 23.8 | | | | |
| | | C2 | 76 | 1 | 76 | 3.0 | 555 | -45 | 0 | -10 | 3 | 23.7 | | | | |
| | | C3 | 76 | 1 | 76 | 3.0 | 555 | -45 | 0 | -10 | 3 | 23.7 | | | | |
| | | C4 | 76 | 1 | 76 | 3.0 | 548 | -45 | 0 | -10 | 3 | 23.8 | | | | |
| | | C5 | 76 | 1 | 76 | 3.0 | 539 | -45 | 0 | -10 | 3 | 23.9 | | | | |
| | | C6 | 76 | 1 | 76 | 3.0 | 537 | -45 | 0 | -10 | 3 | 23.9 | | | | |
| | | C7 | 76 | 1 | 76 | 3.0 | 528 | -45 | 0 | -10 | 3 | 24.1 | | | | |
| | | C8 | 76 | 1 | 76 | 3.0 | 523 | -45 | 0 | -10 | 3 | 24.2 | | | | |
| | | C9 | 76 | 1 | 76 | 3.0 | 520 | -45 | 0 | -10 | 3 | 24.2 | | | | |
| | | C10 | 76 | 1 | 76 | 3.0 | 522 | -45 | 0 | -10 | 3 | 24.2 | | | | |
| | | C11 | 76 | 1 | 76 | 3.0 | 524 | -45 | 0 | -10 | 3 | 24.2 | | | | |
| | | C12 | 76 | 1 | 76 | 3.0 | 521 | -45 | 0 | -10 | 3 | 24.2 | | | | |
| | | C13 | 76 | 1 | 76 | 3.0 | 532 | -45 | 0 | -10 | 3 | 24.0 | | | | |
| | | C14 | 76 | 1 | 76 | 3.0 | 536 | -45 | 0 | -10 | 3 | 24.0 | | | | |
| | | C15 | 76 | 1 | 76 | 3.0 | 540 | -45 | 0 | -10 | 3 | 23.9 | | | | |
| | | C16 | 76 | 1 | 76 | 3.0 | 550 | -45 | 0 | -10 | 3 | 23.7 | | | | |
| | | C17 | 76 | 1 | 76 | 3.0 | 560 | -45 | 0 | -10 | 3 | 23.6 | | | | |
| C18 | 76 | 1 | 76 | 3.0 | 569 | -46 | 0 | -10 | 3 | 23.4 | | | | | | |
| C19 | 76 | 1 | 76 | 3.0 | 571 | -46 | 0 | -10 | 3 | 23.4 | | | | | | |
| C20 | 76 | 1 | 76 | 3.0 | 574 | -46 | 0 | -10 | 3 | 23.4 | | | | | | |
| C21 | 76 | 1 | 76 | 3.0 | 575 | -46 | 0 | -10 | 3 | 23.3 | | | | | | |
| C22 | 76 | 1 | 76 | 3.0 | 575 | -46 | 0 | -10 | 3 | 23.3 | | | | | | |
| C23 | 76 | 1 | 76 | 3.0 | 573 | -46 | 0 | -10 | 3 | 23.4 | | | | | | |
| C24 | 76 | 1 | 76 | 3.0 | 569 | -46 | 0 | -10 | 3 | 23.4 | | | | | | |
| D1 | 74 | 1 | 74 | 2.0 | 647 | -50 | 0 | -10 | 3 | 16.8 | | | | | | |
| D2 | 74 | 1 | 74 | 2.0 | 651 | -50 | 0 | -10 | 3 | 16.8 | | | | | | |
| D3 | 74 | 1 | 74 | 2.0 | 656 | -50 | 0 | -10 | 3 | 16.7 | | | | | | |
| D4 | 74 | 1 | 74 | 2.0 | 660 | -50 | 0 | -10 | 3 | 16.6 | | | | | | |
| E1 | 74 | 1 | 74 | 2.0 | 618 | -50 | 0 | -10 | 3 | 17.2 | | | | | | |
| E2 | 74 | 1 | 74 | 2.0 | 620 | -50 | 0 | -10 | 3 | 17.2 | | | | | | |
| E3 | 74 | 1 | 74 | 2.0 | 623 | -50 | 0 | -10 | 3 | 17.1 | | | | | | |
| E4 | 74 | 1 | 74 | 2.0 | 627 | -50 | 0 | -10 | 3 | 17.1 | | | | | | |
| E5 | 74 | 1 | 74 | 2.0 | 629 | -50 | 0 | -10 | 3 | 17.0 | | | | | | |
| E6 | 74 | 1 | 74 | 2.0 | 633 | -50 | 0 | -10 | 3 | 17.0 | | | | | | |
| E7 | 74 | 1 | 74 | 2.0 | 639 | -50 | 0 | -10 | 3 | 16.9 | | | | | | |
| E8 | 74 | 1 | 74 | 2.0 | 661 | -50 | 0 | -10 | 3 | 16.6 | | | | | | |
| F1 | 74 | 1 | 74 | 4.0 | 542 | -43 | 0 | -10 | 3 | 24.4 | | | | | | |
| F2 | 74 | 1 | 74 | 4.0 | 541 | -43 | 0 | -10 | 3 | 24.4 | | | | | | |
| F3 | 74 | 1 | 74 | 4.0 | 539 | -43 | 0 | -10 | 3 | 24.4 | | | | | | |
| G1 | 74 | 1 | 74 | 2.0 | 546 | -49 | 0 | -10 | 3 | 18.3 | | | | | | |
| G2 | 74 | 1 | 74 | 2.0 | 543 | -49 | 0 | -10 | 3 | 18.3 | | | | | | |
| H1 | 75 | 1 | 75 | 2.0 | 565 | -49 | 0 | -10 | 3 | 19.0 | | | | | | |
| H2 | 75 | 1 | 75 | 2.0 | 561 | -49 | 0 | -10 | 3 | 19.0 | | | | | | |
| H3 | 75 | 1 | 75 | 2.0 | 558 | -49 | 0 | -10 | 3 | 19.1 | | | | | | |
| H4 | 75 | 1 | 75 | 2.0 | 559 | -49 | 0 | -10 | 3 | 19.1 | | | | | | |
| H5 | 75 | 1 | 75 | 2.0 | 561 | -49 | 0 | -10 | 3 | 19.0 | | | | | | |
| H6 | 75 | 1 | 75 | 2.0 | 565 | -49 | 0 | -10 | 3 | 19.0 | | | | | | |
| H7 | 75 | 1 | 75 | 2.0 | 570 | -49 | 0 | -10 | 3 | 18.9 | | | | | | |
| H8 | 75 | 1 | 75 | 2.0 | 573 | -49 | 0 | -10 | 3 | 18.9 | | | | | | |
| H9 | 75 | 1 | 75 | 2.0 | 572 | -49 | 0 | -10 | 3 | 18.9 | | | | | | |
| H10 | 75 | 1 | 75 | 2.0 | 568 | -49 | 0 | -10 | 3 | 18.9 | | | | | | |
| I1 | 74 | 1 | 74 | 2.0 | 577 | -49 | 0 | -10 | 3 | 17.8 | | | | | | |
| I2 | 74 | 1 | 74 | 2.0 | 581 | -49 | 0 | -10 | 3 | 17.7 | | | | | | |
| I3 | 74 | 1 | 74 | 2.0 | 584 | -49 | 0 | -10 | 3 | 17.7 | | | | | | |
| I4 | 74 | 1 | 74 | 2.0 | 588 | -49 | 0 | -10 | 3 | 17.6 | | | | | | |
| I5 | 74 | 1 | 74 | 2.0 | 592 | -49 | 0 | -10 | 3 | 17.6 | | | | | | |
| I6 | 74 | 1 | 74 | 2.0 | 598 | -50 | 0 | -10 | 3 | 17.5 | | | | | | |
| I7 | 74 | 1 | 74 | 2.0 | 603 | -50 | 0 | -10 | 3 | 17.4 | | | | | | |
| J1 | 72 | 1 | 72 | 2.0 | 580 | -49 | 0 | -10 | 3 | 15.8 | | | | | | |
| J2 | 72 | 1 | 72 | 2.0 | 580 | -49 | 0 | -10 | 3 | 15.7 | | | | | | |
| J3 | 72 | 1 | 72 | 2.0 | 586 | -49 | 0 | -10 | 3 | 15.7 | | | | | | |
| J4 | 72 | 1 | 72 | 2.0 | 587 | -49 | 0 | -10 | 3 | 15.7 | | | | | | |
| J5 | 72 | 1 | 72 | 2.0 | 592 | -49 | 0 | -10 | 3 | 15.6 | | | | | | |
| J6 | 72 | 1 | 72 | 2.0 | 596 | -49 | 0 | -10 | 3 | 15.5 | | | | | | |
| J7 | 72 | 1 | 72 | 2.0 | 601 | -49 | 0 | -10 | 3 | 15.4 | | | | | | |
| K1 | 76 | 1 | 76 | 2.0 | 535 | -49 | 0 | -10 | 3 | 20.4 | | | | | | |
| K2 | 76 | 1 | 76 | 2.0 | 535 | -49 | 0 | -10 | 3 | 20.4 | | | | | | |
| K3 | 76 | 1 | 76 | 2.0 | 537 | -49 | 0 | -10 | 3 | 20.4 | | | | | | |
| K4 | 76 | 1 | 76 | 2.0 | 537 | -49 | 0 | -10 | 3 | 20.4 | | | | | | |
| L1 | 77 | 1 | 77 | 2.0 | 535 | -49 | 0 | -10 | 3 | 21.5 | | | | | | |
| L2 | 77 | 1 | 77 | 2.0 | 535 | -49 | 0 | -10 | 3 | 21.5 | | | | | | |
| L3 | 77 | 1 | 77 | 2.0 | 538 | -49 | 0 | -10 | 3 | 21.4 | | | | | | |
| M1 | 69 | 1 | 69 | 2.0 | 541 | -49 | 0 | -10 | 3 | 13.4 | | | | | | |
| M2 | 69 | 1 | 69 | 2.0 | 542 | -49 | 0 | -10 | 3 | 13.3 | | | | | | |
| M3 | 69 | 1 | 69 | 2.0 | 544 | -49 | 0 | -10 | 3 | 13.3 | | | | | | |
| M4 | 69 | 1 | 69 | 2.0 | 547 | -49 | 0 | -10 | 3 | 13.3 | | | | | | |
| M5 | 69 | 1 | 69 | 2.0 | 549 | -49 | 0 | -10 | 3 | 13.2 | | | | | | |
| M6 | 69 | 1 | 69 | 2.0 | 552 | -49 | 0 | -10 | 3 | 13.2 | | | | | | |
| M7 | 69 | 1 | 69 | 2.0 | 555 | -49 | 0 | -10 | 3 | 13.1 | | | | | | |
| N1-3 | 69 | 3 | 74 | 2.0 | 545 | -49 | 0 | -10 | 3 | 18.3 | | | | | | |
| O1-3 | 70 | 3 | 74 | 2.0 | 544 | -49 | 0 | -10 | 3 | 18.3 | | | | | | |
| P1 | 78 | 1 | 78 | 2.0 | 569 | -49 | 0 | -10 | 3 | 21.9 | | | | | | |
| P2 | 78 | 1 | 78 | 2.0 | 575 | -49 | 0 | -10 | 3 | 21.8 | | | | | | |
| P3 | 78 | 1 | 78 | 2.0 | 578 | -49 | 0 | -10 | 3 | 21.8 | | | | | | |
| P4 | 78 | 1 | 78 | 2.0 | 582 | -49 | 0 | -10 | 3 | 21.7 | | | | | | |
| P5 | 78 | 1 | 78 | 2.0 | 585 | -49 | 0 | -10 | 3 | 21.7 | | | | | | |
| Q1 | 76 | 1 | 76 | 3.0 | 593 | -46 | 0 | -10 | 3 | 23.1 | | | | | | |
| Q2 | 76 | 1 | 76 | 3.0 | 594 | -46 | 0 | -10 | 3 | 23.1 | | | | | | |
| R1 | 78 | 1 | 78 | 2.0 | 609 | -50 | 0 | -10 | 3 | 21.3 | | | | | | |
| R2 | 78 | 1 | 78 | 2.0 | 609 | -50 | 0 | -10 | 3 | 21.3 | | | | | | |
| S1 | 79 | 1 | 79 | 2.0 | 595 | -49 | 0 | -10 | 3 | 22.5 | | | | | | |
| S2 | 79 | 1 | 79 | 2.0 | 603 | -50 | 0 | -10 | 3 | 22.4 | | | | | | |
| S3 | 79 | 1 | 79 | 2.0 | 612 | -50 | 0 | -10 | 3 | 22.3 | | | | | | |
| T1 | 76 | 1 | 76 | 2.0 | 544 | -49 | 0 | -10 | 3 | 20.3 | | | | | | |
| T2 | 76 | 1 | 76 | 2.0 | 546 | -49 | 0 | -10 | 3 | 20.3 | | | | | | |
| T3 | 76 | 1 | 76 | 2.0 | 546 | -49 | 0 | -10 | 3 | 20.3 | | | | | | |
| T4 | 76 | 1 | 76 | 2.0 | 548 | -49 | 0 | -10 | 3 | 20.2 | | | | | | |
| U1 | 80 | 1 | 80 | 3.0 | 547 | -45 | 0 | -10 | 3 | 27.8 | | | | | | |
| U2 | 80 | 1 | 80 | 3.0 | 547 | -45 | 0 | -10 | 3 | 27.8 | | | | | | |
| U3 | 80 | 1 | 80 | 3.0 | 546 | -45 | 0 | -10 | 3 | 27.8 | | | | | | |
| U4 | 80 | 1 | 80 | 3.0 | 543 | -45 | 0 | -10 | 3 | 27.8 | | | | | | |
| U5 | 80 | 1 | 80 | 3.0 | 543 | -45 | 0 | -10 | 3 | 27.9 | | | | | | |
| U6 | 80 | 1 | 80 | 3.0 | 540 | -45 | 0 | -10 | 3 | 27.9 | | | | | | |
| U7 | 80 | 1 | 80 | 3.0 | 534 | -45 | 0 | -10 | 3 | 28.0 | | | | | | |
| U8 | 80 | 1 | 80 | 3.0 | 529 | -45 | 0 | -10 | 3 | 28.1 | | | | | | |
| U9 | 80 | 1 | 80 | 3.0 | 519 | -45 | 0 | -10 | 3 | 28.2 | | | | | | |
| U10 | 80 | 1 | 80 | 3.0 | 523 | -45 | 0 | -10 | 3 | 28.2 | | | | | | |
| U11 | 80 | 1 | 80 | 3.0 | 525 | -45 | 0 | -10 | 3 | 28.1 | | | | | | |
| U12 | 80 | 1 | 80 | 3.0 | 530 | -45 | 0 | -10 | 3 | 28.1 | | | | | | |
| U13 | 80 | 1 | 80 | 3.0 | 525 | -45 | 0 | -10 | 3 | 28.1 | | | | | | |
| U14 | 80 | 1 | 80 | 3.0 | 520 | -45 | 0 | -10 | 3 | 28.2 | | | | | | |
| U15 | 80 | 1 | 80 | 3.0 | 514 | -45 | 0 | -10 | 3 | 28.3 | | | | | | |
| U16 | 80 | 1 | 80</ | | | | | | | | | | | | | |

Figures



Notes:

Key to symbols:

LEGEND

- PROJECT BOUNDARY
- 300m ASSESSMENT AREA

| Rev | Date | Drawn | Description | Ch'k'd | App'd |
|-----|----------|-------|-------------|--------|-------|
| P1 | JUL 2021 | KN | | HL | GC |

M M
MOTT MACDONALD
 3/F International Trade Tower
 348 Kwun Tung Road
 Kwun Tung, Kowloon
 Hong Kong
 T +852 2828 5757
 F +852 2827 1823
 W mottmac.com



Client
 土木工程拓展署
 Civil Engineering and
 Development Department


Project
**TAI SHUE WAN DEVELOPMENT
 AT OCEAN PARK**

Title
LOCATION OF THE PROJECT

| | | | |
|-------------|--------|--------------|--|
| Designed | | Eng check | |
| Drawn | | Coordination | |
| Dwg check | | Approved | |
| Scale at A3 | Status | Rev | |

Drawing Number **FIGURE 1.1**





Notes:

Key to symbols:

LEGEND

- PROJECT BOUNDARY
- ▲ PA SYSTEMS / LOUDSPEAKERS
- MAJOR FIXED PLANTS



| Rev | Date | Drawn | Description | Ch'k'd | App'd |
|-----|----------|-------|-------------|--------|-------|
| P1 | JUL 2021 | KN | | HL | GC |


M M
MOTT MACDONALD
 3/F International Trade Tower
 348 Kwun Tung Road
 Kwun Tung, Kowloon
 Hong Kong
 T +852 2828 5757
 F +852 2827 1823
 W mottmac.com

Client
土木工程拓展署
Civil Engineering and Development Department


Project
TAI SHUE WAN DEVELOPMENT AT OCEAN PARK

Title
LOCATIONS OF FIXED NOISE SOURCES

| | | | |
|-------------|--------|--------------|--|
| Designed | | Eng check | |
| Drawn | | Coordination | |
| Dwg check | | Approved | |
| Scale at A3 | Status | Rev | |






Drawing Number **FIGURE 2.1**



Notes:

Key to symbols:

LEGEND

-  PROJECT BOUNDARY
-  300m ASSESSMENT AREA
-  NOISE SENSITIVE RECEIVER

| Rev | Date | Drawn | Description | Ch'k'd | App'd |
|-----|----------|-------|-------------|--------|-------|
| P1 | JUL 2021 | KN | | HL | GC |

M **M**
MOTT **MACDONALD**
 3/F International Trade Tower
 348 Kwun Tung Road
 Kwun Tung, Kowloon
 Hong Kong
 T +852 2828 5757
 F +852 2827 1823
 W mottmac.com


Client
 土木工程拓展署
 Civil Engineering and
 Development Department


Project
**TAI SHUE WAN DEVELOPMENT
 AT OCEAN PARK**

Title
**LOCATIONS OF REPRESENTATIVE
 NOISE SENSITIVE RECEIVERS**

| | | | |
|-------------|--------|--------------|--|
| Designed | | Eng check | |
| Drawn | | Coordination | |
| Dwg check | | Approved | |
| Scale at A3 | Status | Rev | |

Drawing Number **FIGURE 3.1**





Notes:

Key to symbols:

LEGEND

- PROJECT BOUNDARY
- 300m ASSESSMENT AREA
- FIXED NOISE SOURCES FROM CONCURRENT PROJECTS

| Rev | Date | Drawn | Description | Ch'k'd | App'd |
|-----|----------|-------|-------------|--------|-------|
| P1 | JUL 2021 | KN | | HL | GC |

M M
MOTT MACDONALD
 3/F International Trade Tower
 348 Kwun Tung Road
 Kwun Tung, Kowloon
 Hong Kong
 T +852 2828 5757
 F +852 2827 1823
 W mottmac.com

Client
土木工程拓展署
Civil Engineering and Development Department

Project
TAI SHUE WAN DEVELOPMENT AT OCEAN PARK

Title
LOCATIONS OF FIXED NOISE SOURCES FROM CONCURRENT PROJECTS

| | | | |
|-------------|--------|--------------|--|
| Designed | | Eng check | |
| Drawn | | Coordination | |
| Dwg check | | Approved | |
| Scale at A3 | Status | Rev | |

Drawing Number **FIGURE 3.2**

