



Stanger Asia

ENVIRONMENTAL MONITORING AND AUDIT REPORT

FOR

CONTRACT No. CV/2002/13

FILL BANK AT TUEN MUN AREA 38

NOVEMBER 2004

(Revision No. 0)

Report No.: ET12367

Certified by: Mr. Jeff Tsang Date: 17/12/2004  
Mr. Jeff Tsang  
Environmental Team Leader  
for Stanger Asia Limited

Verified by: Mr. Joseph T. L. Poon Date: 17/12/2004  
Mr. Joseph T. L. Poon  
Independent Environmental Checker  
for Materis Lab Consultants Ltd.

## **CONTENTS**

	<u>Page</u>
<b>EXECUTIVE SUMMARY</b>	1
<b>1. INTRODUCTION</b>	
1.1 Background	4
1.2 Report Structure	4
<b>2. PROJECT INFORMATION</b>	
2.1 Site Description	5
2.2 Project Organization	5
2.3 Construction Programme	5
<b>3. ENVIRONMENTAL PERMITS AND LICENSES</b>	6
<b>4. SUMMARY OF EM&amp;A REQUIREMENTS</b>	
4.1 Air Quality	6
4.2 Water Quality	8
4.3 Event and Action Plan	10
<b>5. IMPLEMENTATION STATUS OF ENVIRONMENTAL MITIGATION MEASURES</b>	10
<b>6. MONITORING RESULTS</b>	
6.1 Completed Monitoring Works	11
6.2 Air Quality Monitoring	12
6.3 Water Quality Monitoring	13
<b>7. AUDIT REPORT</b>	
7.1 Air Quality Monitoring	13
7.2 Water Quality Monitoring	13
7.3 Site Inspections	14
7.4 Landscape and Visual	15
<b>8. WASTE MANAGEMENT</b>	15
<b>9. COMPLAINTS, NOTIFICATIONS OF SUMMONS AND SUCCESSFUL PROSECUTIONS</b>	15
<b>10. FUTURE KEY ISSUES</b>	15
<b>11. CONCLUSION</b>	16
<b>LIST OF FIGURES</b>	
2.1 The Site Layout Plan	
4.1 Air Quality Monitoring Stations	
4.2 Water Quality Monitoring Stations	

## **LIST OF FIGURES (Continued)**

- 6.1 Graphical Plot for 24-hour TSP Levels
- 6.2 Graphical Plot for 1-hour TSP Levels
- 6.3 Graphical Plot for Surface and Middle Averaged Dissolved Oxygen – Mid Flood Tide
- 6.4 Graphical Plot for Surface and Middle Averaged Dissolved Oxygen – Mid Ebb Tide
- 6.5 Graphical Plot for Bottom Dissolved Oxygen – Mid Flood Tide
- 6.6 Graphical Plot for Bottom Dissolved Oxygen – Mid Ebb Tide
- 6.7 Graphical Plot for Turbidity – Mid Flood Tide
- 6.8 Graphical Plot for Turbidity – Mid Ebb Tide
- 6.9 Graphical Plot for Suspended Solids – Mid Flood Tide
- 6.10 Graphical Plot for Suspended Solids – Mid Ebb Tide

## **TABLES**

- Table 3.1 Summary of the Environmental Permits and Licenses
- Table 4.1 Co-ordinates of Air Quality Monitoring Stations
- Table 4.2 Air Quality Monitoring Frequency
- Table 4.3 Action and Limit Levels for the project
- Table 4.4 Water Quality Monitoring Frequency
- Table 4.5 Action and Limit Level for Water Quality
- Table 6.1 Completed Monitoring Works for November 2004
- Table 6.2 Results of 24-hour TSP Monitoring
- Table 6.3 Results of 1-hour TSP Monitoring
- Table 6.4 Summary of Water Quality Monitoring Data
- Table 7.1 Summary of Findings, Actions and Outcomes of Site Inspection by ET
- Table 7.2 Summary of Findings, Actions and Outcomes of Site Inspection by IEC
- Table 10.1 Works Programme for December 2004

## **APPENDICES**

- I Organization Chart
- II Calibration Certificates of the Monitoring Equipment
- III Event and Action Plans
- IV Implementation Status of Mitigation Measures
- V Air Quality Monitoring Results
- VI Water Quality Monitoring Results
- VII Complaint Log
- VIII Cumulative Statistics on Complaints, Notifications of Summons and Successful Prosecutions
- IX Master Construction Programme
- X Monitoring Schedule for the following month
- XI Wind Speed and Direction Data

## **EXECUTIVE SUMMARY.**

This is the 17<sup>th</sup> monthly Environmental Monitoring and Audit (EM&A) report for Contract No. CV/2002/13 – Fill Bank at Tuen Mun Area 38. The site has been in operation as a public filling area as part of the reclamation. The site is 24 hours operated except during the Chinese New Year holidays to provide a stable outlet for public fill to serve the construction industry. This report covers the monitoring works conducted during the month of November 2004.

### **Construction Activities for the Reported Period.**

- Public fill operation.
- Operation of tipping hall.
- Installation of CCTV system.
- Construction of drainage system.

### **Air Quality Monitoring.**

Two stations (A1 and A2) have been identified as the locations for the monitoring of 24-hour and 1-hour Total Suspended Particulates (TSP). In this reporting period, the monitoring of 24-hour TSP was carried out on five occasions at A1 and A2. Monitoring of 1-hour TSP was carried out on fifteen occasions at A1 and A2. There was no exceedance to the set action or limit levels for both parameters at both stations.

### **Water Quality Monitoring.**

Water quality in terms of turbidity, dissolved oxygen, suspended solids, temperature, and salinity, was carried out on thirteen occasions during flood tide and ebb tide at FM1, FM2, FC1 and FC2 in this reporting period. There was no exceedance to the set action or limit level for all parameters at all stations.

### **Landscape Audit.**

The slopes on the north-western side of the fill bank were not hydroseeded. The Contractor was recommended to complete the slope works and carry out hydroseeding as soon as possible.

### **Waste Management.**

132,460m<sup>3</sup> public fill was collected to the Fill Bank. 19.05t C&D waste and general refuse were disposed of at WENT Landfill. Chemical waste generated was stored in temporary chemical waste storage area. No chemical waste was disposed of in this reporting period.

### **Complaints and Notifications of Summons and Successful Prosecutions.**

No complaints or notification of summonses was received in this reporting period.

## Site Inspections.

Four weekly site inspections were conducted on 6<sup>th</sup>, 13<sup>th</sup>, 18<sup>th</sup> and 25<sup>th</sup> November 2004. Major observations are summarised in the following table.

Observations	Actions by Contractor	Outcome
Dust emission at the tipping hall when materials were being unloaded. (18.11.2004)	Wet the materials at the reception office prior to unloading.	Dust emission at the tipping hall was minimised. (25.11.2004)
Drainage channels were filled with deposit. (18.11.2004)	Cleaned up the deposit.	Drainage channels were cleaned up on regular basis.
Dust generation from site traffic on dry haul roads at the seafront. (18.11.2004)	Increased the frequency of water spraying and delineated haul roads.	Situation improved. (25.11.2004)
Waste chemical drums were found on bare ground. (18.11.2004)	Collected and stored the waste drums in chemical waste storage area.	The waste chemical drums were collected and stored in the chemical waste storage area. (25.11.2004)

An Independent Environmental Checker (IEC) audit was conducted on 18<sup>th</sup> November 2004 with the Environmental Team. Major observations are summarized in the following table.

Observations	Actions by Contractor	Outcome
Heavy dust emission on haul roads along the seafront.	Increased the frequency of water spraying and delineated haul roads..	Situation improved. (25.11.2004)
Dust generation during transfer of dry soil to the barge at the tipping hall.	Wet the materials at the reception office prior to unloading.	Dust emission at the tipping hall was minimised. (25.11.2004)
Oil containers were scattered around the drip tray next to the site office.	Collected and stored the containers in chemical waste storage area.	The containers were collected and stored in the chemical waste storage area. (25.11.2004)
Splashing generated during the transfer of wet soil to the barge at the tipping hall caused splashing into the sea.	To ensure the barge is fitted with nets / tarpaulin sheeting and the tarpaulin sheets at the tipping hall are always dropped down closer to the barge during the transfer.	To be observed in the next reporting period.
The automatic high-pressure water jet at the site exit was not functioning during the time of inspection. No staff was no stand-by to provide washing service.	Deploy stand-by staff to provide manual wheel washing when the automatic machine is not functioning.	The automatic wheel washing facility was operating. (25.11.2004)

### **Future Key Issues.**

The tentative works activities, predicted impacts and areas of environmental concern for the following month are summarised in the following table.

Works Activities	Predicted Impacts	Proposed Mitigation Measures
Public filling operation.	- Dust - Water	- Dampening of fill materials and exposed area. - Avoid stockpiling fill materials near seafront. - Avoid spillage of fill materials into the marine water.
Operation of tipping hall for unloading public fill into barges.	- Dust - Water	- The tipping halls shall be top and 3-sides enclosed. - Avoid spillage of fill materials into the marine water.
Construction of drainage system.	- Dust - Noise - Water	- Apply water spray during excavation and earth moving. - Comply with the conditions of construction noise permit. - Treat all wastewater to acceptable prior to discharge.

## **1. INTRODUCTION.**

### **1.1 Background.**

Stanger Asia Ltd. has been commissioned by the Penta-Ocean Construction Co. Ltd. to provide an Environmental Team (ET) to monitor air and water quality and audit landscape works for Contract No.CV/2002/13. The team is to take a pro-active role in all issues, which may be of environmental concern during the establishment, operation and decommissioning phases of the Fill Bank at Tuen Mun Area 38.

The Independent Environmental Checker (IEC) appointed for this project is Materialab Consultants Ltd.

In this report, the air and water quality monitoring works and landscape audit conducted for the November 2004 will be detailed and reviewed. All monitoring works were carried out in accordance to "*Agreement No, PW 01/2002 Project Profile for Fill Bank at Tuen Mun Area 38, Environmental Monitoring and Audit Manual*".

### **1.2 Report Structure.**

The purpose of this report is to detail and review the air and water quality monitoring works and landscape audit undertaken during November 2004. The impact forecast for the next reporting month and the schedules of monitoring works for the following month is also given.

The report follows the format given below:

- Section 1      Introduction and background information to the content of this report.
- Section 2      This section gives the information of the project.
- Section 3      This section summarises all the environmental permits and licenses.
- Section 4      Summary of the EM&A requirements is presented.
- Section 5      This section details the implemented mitigation measures.
- Section 6      Details monitoring results.
- Section 7      Audit the monitoring results.
- Section 8      The status for solid and liquid waste management for the site is overviewed.
- Section 9      Complaints, notifications of summons and successful prosecutions are summarized.
- Section 10     This section gives the predicted impacts of the construction activities.
- Section 11     This section gives a conclusion in relation to all monitoring activities.

## **2. PROJECT INFORMATION.**

### **2.1 Site Description.**

The works mainly comprise the construction of temporary storm water system, setting up of C&D material loading/unloading facilities, setting up/ refurbishing site facilities, stockpiling of 4.9 million m<sup>3</sup> of public fill, and decommissioning of the temporary fill bank.

The site layout plan is shown in Figure 2.1.

### **2.2 Project Organization.**

Mr. L.M. Chan is the Engineer's Representative for the Civil Engineering and Development Department, Government of the HKSAR. (Tel: 2762 5602, Fax: 2714 0113).

The Independent Environmental Checker (IEC) for this project is headed by Mr. Joseph Poon - Manager of Materialab Consultants Ltd. (Tel: 2450 8238, Fax: 2450 6138).

Mr. Lok Wah Fung is the Site Agent for Penta-Ocean Construction Co., Ltd. (Tel: 2491 1584, Fax: 2496 0433).

The Environmental Team (ET) for the project is Stanger Asia Ltd. The team is headed by Mr Jeff Tsang – Environmental Scientist. (Tel: 2682 1203, Fax: 2682 0046).

The Organization Chart with the key personnel contacts names and telephone numbers is given in Appendix I.

### **2.3 Construction Programme.**

The overall construction programme is given in Appendix IX. Details of the construction activities are listed below.

- Site clearance;
- Construction of storm water drainage system;
- Stockpiling of 4.9 million m<sup>3</sup> of public fill;
- Construction of landscape works; and
- Removal of stockpiled public fill.

### **3. ENVIRONMENTAL PERMITS AND LICENSES.**

The summary of the status of all environmental permits, licenses and notification for this project as at November 2004 is summarized in the following table.

**Table 3.1 Summary of the Environmental Permits and Licenses**

Description	Licence/Permit No.	Date of Issue	Date of Expiry	Status
Environmental Permit	EP-153/2003	13-Feb-03	--	Superseded
Registration of Chemical Waste Producer	WPN5296-421-P2800-03	05-Aug-03	--	Issued
Amended Environmental Permit	EP-153/2003/A	30-Oct-03	--	Issued
Construction Noise Permit	GW-RW0628-04	15-Nov-04	14-May-05	Issued

### **4. SUMMARY OF EM&A REQUIREMENTS.**

#### **4.1 Air Quality.**

##### *Monitoring Location.*

The project has two designated locations (A1 & A2) for the monitoring of air quality. A1 is a fixed location in the vicinity of the site office to monitor the TSP levels at River Trade Terminal and A2 is a movable location to the western boundary of the site that is designed to move as works progress. The air monitoring locations are shown in Figure 4.1.

**Table 4.1 Coordinates of Air Quality Monitoring Stations**

Station	HK Metric Grid – Easting	HK Metric Grid - Northing
A1	811368	825593
A2	810812*	825096*

\* - Coordinates of present location.

##### *Methodology*

Measurement of 24-hour and 1-hour TSP levels were carried out in accordance to the high volume sampling method as set out in the Title 40 of the Code of Federal Regulations, Chapter 1 (Part 50). When positioning the high volume samplers, the following requirements have been observed:

- a horizontal platform with appropriate support to secure the high volume sampler against gusty wind, should be provided;
- horizontal distance between the high volume samplers and an obstacle, such as buildings, must be at least twice the height of the obstacle protruding above the high volume samplers;
- a minimum separation of 2 m should be provided from walls, parapets, and penthouses for rooftop high volume samplers;

- a minimum separation of 2 m should be provided from any supporting structure measured horizontally;
- there should not be any furnace or incinerator flues nearby;
- there should be unrestricted airflow around the high volume samplers;
- a minimum separation of 20 m should be provided from the dripline;
- any wire fence and gate employed to protect the high volume samplers should not cause any obstruction during monitoring.

All relevant data including temperature, pressure, weather conditions, elapsed-timer meter reading for the start and finish of the sampling period, identification and weight of the filter paper, and other special phenomena were recorded.

#### *Monitoring Equipment and Calibration Details.*

Andersen GMW Model GS2310 high volume samplers were used to carry out the monitoring of 24-hour and 1-hour TSP. The high volume sampler is in compliance with the specifications as listed in the Environmental Schedule, given below:

- 0.6 – 1.7 m<sup>3</sup>/min (20-60 SCFM) adjustable flow range;
- equipped with a timing / control device with 5 minutes accuracy over 24 hours operations;
- installed with elapsed-time meter with 2 minutes accuracy over 24 hours operations;
- capable of providing a minimum exposed area of 406 cm<sup>2</sup> (63 in<sup>2</sup>);
- flow control accuracy: 2.5% deviation over 24-hr sampling period;
- equipped with shelter to protect the filter and sampler;
- incorporated with an electronic mass flow rate controller or other equivalent devices;
- equipped with a flow recorder for continuous monitoring;
- provided with peaked roof inlet, incorporated with manometer;
- able to hold and seal the filter paper to the sampler housing at horizontal position;
- easy to change filter; and
- capable of operating continuously for 24-hr period.

The high volume sampler is calibrated at bi-monthly intervals. The calibration kit (Andersen Model G2535) comprising pressure plates and a transfer standard is traceable to the internationally recognized standard. Calibration records for the high volume sampler is given in Appendix II of this report.

#### *Laboratory Measurement.*

Laboratory measurements were carried out in Stanger Asia Ltd. own HOKLAS accredited laboratory with constant temperature and humidity control, and equipped with necessary measuring and conditioning instruments.

Clean filter papers of size 8"x10" with no pinholes were labelled before sampling. They were conditioned in a dessicator with less than 50% relative humidity for over 24 hours and pre-weighed before use for sampling.

After sampling, the filter papers loaded with dust were kept in a clean and tightly sealed plastic bag. The filter papers were then returned to the laboratory for reconditioning in the dessicator with less than 50% relative humidity followed by accurate weighing on an electronic balance regularly calibrated against a traceable standard and readable to 0.1 mg.

Stanger Asia Ltd. operates comprehensive quality assurance and quality control programmes. For QA/AC procedures, all filters were equilibrated and weighed repeatedly until the difference of two consecutive results was less than 0.5 mg.

#### *Monitoring Parameters Frequency.*

**Table 4.2 Air Quality Monitoring Frequency**

Monitoring Locations	Parameter	Frequency
A1 & A2	24-hr TSP	Once in every six days
	1-hr TSP	Three times in every six days

#### *Action and Limit Levels.*

The Action levels for air quality monitoring were established from the impact monitoring data of Contract No. CV/2000/01 prior to the commencement of the fill bank utilising the criteria laid out in *section 4.7* of the EM&A Manual for the project. The Limit levels for air quality monitoring has been set in line with statutory guidelines for air quality in Hong Kong. Action and Limit levels for both 24-hour and 1-hour TSP are given in the following table.

**Table 4.3 Action and Limit Levels for the Project**

Parameter Monitored	Action Level, $\mu\text{g}/\text{m}^3$	Limit Level, $\mu\text{g}/\text{m}^3$
1-hour TSP	344	500
24-hour TSP	192	260

## **4.2 Water Quality.**

#### *Monitoring Locations.*

The EM&A Manual produced for this project has proposed two monitoring stations (FM1 & FM2) and two control stations (FC1 & FC2) for the carrying out of water quality monitoring. Control Station FC1 will act as upstream control station for the mid-ebb tide with control station FC2 acting as upstream control stations for the mid-flood tide.

The designated monitoring stations are shown in Figure 4.2.

#### *Methodology.*

Measurements are taken at three water depths, namely 1m below water surface, mid-water and 1m above seabed at both mid-flood and mid-ebb tides, except where the water depth less than 6m, when the mid-depth station may be omitted. Should the water depth have been less than 3m, only the mid-depth was monitored.

Two measurements of turbidity, dissolved oxygen (mg/L), dissolved oxygen (% saturation) and temperature at each depth of each station is taken. The probes are removed from the water after the first measurement and then redeployed for the second measurement. If the difference in value between the first and second reading of each set is more than 25% of the value of the first reading, the readings are discarded and further readings taken. Replicate samples of suspended solids measurements are taken at each depth and at each water quality monitoring and control station. The samples are kept in a chilled condition during delivery to the laboratory ad before commencement of analysis. For the purpose of evaluating the water quality, all values for suspended solids and turbidity shall be depth-averaged.

During monitoring works the following shall also be recorded:

- monitoring location;
- depth of water;
- time;
- weather conditions including ambient temperature;
- water temperature;

#### *Monitoring Equipment.*

The following equipment was employed for routine water quality monitoring.

- Dissolved Oxygen meter: YSI model 58 with stirrer
- Turbidity meter: Hach 2100P
- Echo sounder: Hummingbird 100SX
- Water sampler: Kahlisco 135WB203
- GPS receiver: Trimble NT2002D
- Thermometer: YSI model 58

#### *Monitoring Equipment Calibration Details.*

All on-site monitoring equipment was calibrated three-monthly at Stanger Asia's HOKLAS accredited laboratory. An on-site calibration check was carried out prior to the taking of measurements in accordance with standard water quality monitoring procedures.

Equipment calibration details were given in Appendix II.

#### *Laboratory Analysis.*

The laboratory measurements of suspended solids were carried out at Stanger Asia Limited, a HOKLAS accredited laboratory in accordance with Method No. 2540D 17<sup>th</sup> Edition of APHA.

Stanger Asia operates a comprehensive quality assurance and quality control programmes for QA/AC procedures in accordance with the requirements of HOKLAS accreditation, all filters were equilibrated and weighted repeatedly until the difference of two consecutive results is less than 0.5 mg.

*Monitoring Parameters and Frequency.*

**Table 4.4 Water Quality Monitoring Frequency**

Monitoring Locations	Monitoring Parameters	Frequency	Requirements
Designated Control Stations: FC1 & FC2. Designated Monitoring Stations: FM1 & FM2.	Temperature, Salinity, Dissolved Oxygen, Turbidity, Suspended Solids.	Three days per week.	At three depths during mid-ebb and mid-flood tides.

*Action and Limit Levels.*

The Action and Limit levels for water quality monitoring were established from the impact monitoring data of Contract No. CV/2000/01 prior to the commencement of the fill bank utilising the criteria laid out in *section 6.8* of the EM&A Manual for the project.

**Table 4.5 Action and Limit Level for Water Quality**

Parameter	Action level	Limit level
Dissolved Oxygen in mg/L.		
Surface & Middle Bottom.	<4.78mg/L <4.16mg/L	<4mg/L <2mg/L
Suspended Solids (SS) in mg/L (depth-averaged)	>120% of upstream control station's SS at the same time of the same day.	>130% of upstream control station's SS at the same tide of the same day .
Turbidity (Tby) in NTU	>120% of upstream control station's Tby at the same tide of the same day.	>130% of upstream control station's Tby at the same tide of the same day.

All the figures given in the table are used for reference only and the EPD may amend the figures whenever necessary.

#### **4.3 Event and Action Plans.**

The Event and Action Plans for air and water are attached in Appendix III of this report.

#### **5. IMPLEMENTATION STATUS OF ENVIRONMENTAL MITIGATION MEASURES.**

The contractor implemented various environmental mitigation measures as recommended in the Project Profile and Environmental Permit. The implementation status is attached in Appendix IV and summarised as follows:

- Wheel washing facilities were provided at the exit point of the site and the wheel washing bay was cleared regularly.
- Slopes were compacted as far as practicable.

- Site accesses were covered with concrete.
- Waste collection points were maintained and cleaned on a regular basis.
- Hoarding was erected along Lung Mun Road and near River Trade Terminal.
- Oil drums were placed in drip trays.
- Water bowsers and road sweepers were in operation.
- Buffer trees were planted.
- Speed limit warning signs were posted.
- Sea blocks were placed along the seawall.
- Completed slopes were hydroseeded.

## 6. MONITORING RESULTS.

### 6.1 Completed Monitoring Works.

Table 6.1 gives the completed monitoring works for the reported period.

**Table 6.1 Completed Monitoring Works for November 2004**

Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday
	<u>November 1</u>		2	3	4	5
	WQM (Ebb: 15:03) (Flood: 10:04)	1 – hr TSP 24 – hr TSP		WQM (Ebb: 07:30) (Flood: 17:12)		WQM (Ebb: 07:35) (Flood: 17:00) Site Inspection
7	WQM (Ebb: 09:28) (Flood: 16:35) 1 – hr TSP 24 – hr TSP	8	9	10	11	12
14	WQM (Ebb: 14:51) (Flood: 09:35)	15	16	17	18	19
21	WQM (Ebb: 09:33) (Flood: 16:23)	22	23	24	25	26
28	WQM (Ebb: 14:08) (Flood: 09:19)	29	30			27

- Notes:
1. 24 –hr TSP (monitored once every 6 days) at monitoring locations A1 and A2.
  2. 1 hour TSP (monitored three times every six days when highest level of dust generation expected) at monitoring locations A1 and A2.
  3. WQM - water quality monitoring three times per week, on mid-flood and mid-ebb tides. Days of monitoring to be separated by at least 36 hours. Monitoring locations FC1, FM1, FM2 & FC2.
  4. Site inspections to be carried out once per week.
  5. Auditing of landscape works to be carried out once per month.

## 6.2 Air Quality Monitoring.

Impact monitoring of 24-Hour TSP was conducted on five occasions at A1 and A2, with the monitoring of 1-Hour TSP being conducted on fifteen occasions at A1 and A2 in this reported period.

The monitoring records for 24-hour and 1-hour TSP are given in the following table. Details of monitoring results are given in Appendix V. The results are presented graphically in Figures 6.1 and 6.2.

**Table 6.2 Results of 24-hour TSP Monitoring**

Date	A1, $\mu\text{g}/\text{m}^3$	Exceedance (Y/N)	A2, $\mu\text{g}/\text{m}^3$	Exceedance (Y/N)
02/11/2004	108	N	125	N
08/11/2004	108	N	121	N
13/11/2004	110	N	128	N
19/11/2004	177	N	124	N
25/11/2004	123	N	144	N
Action Level			192 $\mu\text{g}/\text{m}^3$	
Limit Level			260 $\mu\text{g}/\text{m}^3$	

**Table 6.3 Results of 1-hour TSP Monitoring**

Date	A1, $\mu\text{g}/\text{m}^3$	Exceedance (Y/N)	A2, $\mu\text{g}/\text{m}^3$	Exceedance (Y/N)
02/11/2004	235	N	283	N
02/11/2004	226	N	256	N
02/11/2004	223	N	248	N
08/11/2004	319	N	317	N
08/11/2004	203	N	285	N
08/11/2004	221	N	335	N
13/11/2004	264	N	264	N
13/11/2004	293	N	240	N
13/11/2004	188	N	257	N
19/11/2004	158	N	209	N
19/11/2004	208	N	284	N
19/11/2004	311	N	288	N
25/11/2004	329	N	273	N
25/11/2004	223	N	315	N
25/11/2004	192	N	282	N
Action Level			344 $\mu\text{g}/\text{m}^3$	
Limit Level			500 $\mu\text{g}/\text{m}^3$	

Wind speed and direction data from the wind station is given in Appendix XI.

### **6.3 Water Quality Monitoring.**

Water quality monitoring was carried out on thirteen occasions during flood tide and ebb tide at FM1, FM2, FC1 and FC2.

Results for water quality monitoring are summarised in the following tables. Details of monitoring results are presented in Appendix VI. Graphical presentations of the results are shown in Figure 6.3 – Figure 6.10.

**Table 6.4 Summary of Water Quality Monitoring Data**

Sample Location	Surface & Middle Averaged Dissolved Oxygen (Range), mg/L	Bottom Averaged Dissolved Oxygen (Range), mg/L	Depth Averaged Turbidity (Range), NTU	Depth Averaged Suspended Solids (Range), mg/L
FM1	7.02 (6.00-8.30)	6.65 (5.21-7.65)	8.09 (4.63-19.17)	18.1 (13.7-28.2)
FM2	6.85 (6.27-7.75)	6.55 (5.07-7.65)	7.98 (4.51-13.27)	18.2 (12.8-25.3)
FC1	6.78 (6.13-8.00)	6.58 (5.01-7.81)	8.28 (5.36-19.73)	18.3 (13.2-26.5)
FC2	6.90 (6.25-7.93)	6.60 (5.06-7.61)	8.74 (4.49-16.78)	18.3 (12.0-27.0)

## **7. AUDIT REPORT.**

### **7.1 Air Quality Monitoring.**

No exceedance to set action or limit levels for either 24 or 1-Hour TSP monitoring was recorded at air monitoring station A1 and A2 in this reported period.

### **7.2 Water Quality Monitoring.**

There was no exceedance to the Action and Limit Level for water quality parameters in this reported period.

### 7.3 Site Inspections.

Four weekly site inspections were conducted on 6<sup>h</sup>, 13<sup>h</sup>, 18<sup>th</sup> and 25<sup>th</sup> November 2004. Observations by ET, action by the Contractor and outcome are summarised in the following table.

**Table 7.1 Summary of Findings, Actions and Outcomes of Site Inspection by ET**

Observations	Actions by Contractor	Outcome
Dust emission at the tipping hall when materials were being unloaded. (18.11.2004)	Wet the materials at the reception office prior to unloading.	Dust emission at the tipping hall was minimised. (25.11.2004)
Drainage channels were filled with deposit. (18.11.2004)	Cleaned up the deposit.	Drainage channels were cleaned up on regular basis.
Dust generation from site traffic on dry haul roads at the seafront. (18.11.2004)	Increased the frequency of water spraying and delineated haul roads.	Situation improved. (25.11.2004)
Waste chemical drums were found on bare ground. (18.11.2004)	Collected and stored the waste drums in chemical waste storage area.	The waste chemical drums were collected and stored in the chemical waste storage area. (25.11.2004)

The Independent Environmental Checker (IEC) conducted an audit on 18<sup>th</sup> November 2004. The major observations were summarized in the following table.

**Table 7.2 Summary of Findings, Actions and Outcomes of Site Inspection by IEC**

Observations	Actions by Contractor	Outcome
Heavy dust emission on haul roads along the seafront.	Increased the frequency of water spraying and delineated haul roads..	Situation improved. (25.11.2004)
Dust generation during transfer of dry soil to the barge at the tipping hall.	Wet the materials at the reception office prior to unloading.	Dust emission at the tipping hall was minimised. (25.11.2004)
Oil containers were scattered around the drip tray next to the site office.	Collected and stored the containers in chemical waste storage area.	The containers were collected and stored in the chemical waste storage area. (25.11.2004)
Splashing generated during the transfer of wet soil to the barge at the tipping hall caused splashing into the sea.	To ensure the barge is fitted with nets / tarpaulin sheeting and the tarpaulin sheets at the tipping hall are always dropped down closer to the barge during the transfer.	To be observed in the next reporting period.
The automatic high-pressure water jet at the site exit was not functioning during the time of inspection. No staff was on stand-by to provide washing service.	Deploy stand-by staff to provide manual wheel washing when the automatic machine is not functioning.	The automatic wheel washing facility was operating. (25.11.2004)

#### **7.4 Landscape and Visual.**

A landscape audit was conducted on 25<sup>th</sup> November 2004. The slopes on the north-western side of the fill bank were not hydroseeded. The Contractor was recommended to complete the slope works and carry out hydroseeding as soon as possible.

#### **8. WASTE MANAGEMENT.**

132,460m<sup>3</sup> public fill was collected to the Fill Bank. 19.05t C&D waste and general refuse were disposed of at WENT Landfill. Chemical waste generated was stored in temporary chemical waste storage area. No disposal of chemical waste was carried out in this reporting period.

#### **9. COMPLAINTS, NOTIFICATIONS OF SUMMONSES AND SUCCESSFUL PROSECUTIONS.**

No complaint was received this month. Complaint Log is attached in Appendix VII. Cumulative statistics on complaints, notifications of summonses and successful prosecutions are attached in Appendix VIII.

#### **10. FUTURE KEY ISSUES.**

The following are the scheduled construction activities for the next reported period. Scheduled monitoring activities for the following month are given in Appendix IX.

**Table 10.1 Works Programme for December 2004**

Works Activities	Predicted Impacts	Proposed Mitigation Measures
Public filling operation.	- Dust - Water	- Dampening of fill materials and exposed area. - Avoid stockpiling fill materials near seafront. - Avoid spillage of fill materials into the marine water.
Operation of tipping hall for unloading public fill into barges.	- Dust - Water	- The tipping halls shall be top and 3-sides enclosed. - Avoid spillage of fill materials into the marine water.
Construction of drainage system.	- Dust - Noise - Water	- Apply water spray during excavation and earth moving. - Comply with the conditions of construction noise permit. - Treat all wastewater to acceptable prior to discharge.

## **11. CONCLUSION.**

All results for the air quality monitoring conducted this month were acceptable with no exceedance to set action or limit levels for either 24 or 1-hour TSP.

In relation to the monitoring of water quality, there was no record of exceedance to the set Action and Limit Level during this reporting period.

The slopes on the north-western side of the fill bank were recommended to be hydroseeded.

## **Figures**





Figure 1 - The System

The copyright of this document is owned by Major Alia Lloreda. It may not be reproduced without the prior written approval of the author.



**Figure 4.1 – Air Quality Monitoring Stations**





Figure 4-2 – Water Quality Monitoring Stations

45. The recipient of your report is named by Plaintiff as Plaintiff's attorney. Plaintiff's attorney is also reported as having been retained by Plaintiff's attorney in the instant case.

**Figure 6.1 - Graphical Plot for 24-hr TSP**



**Figure 6.2 - Graphical Plot for 1-hr TSP**




Fig 6.3

Figure 6.3 - Surface and Middle Averaged Dissolved Oxygen - Mid-Flood






Fig 6.4


Figure 6.4 - Surface and Middle Averaged Dissolved Oxygen - Mid-Ebb



**Figure 6.5 - Bottom Averaged Dissolved Oxygen - Mid-Flood**



**Figure 6.6 - Bottom Averaged Dissolved Oxygen - Mid-Ebb**



**Figure 6.7 - Depth Averaged Turbidity - Mid-Flood**




Figure 6.8 - Depth Averaged Turbidity - Mid-Ebb




Figure 6.9 - Depth Averaged Suspended Solids - Mid-Flood






Figure 6.10 - Depth Averaged Suspended Solids - Mid-Ebb



**Appendix I**  
**Organization Chart**

**Project Organization (Environmental)**  
**Fill Bank at Tuen Mun Area 38**  
**Contract No. CV/2002/13**



**Appendix II**  
**Calibration Certificates of the Monitoring Equipment**



Stranger Asia


SIMP ENV032 - CALIBRATION RECORD OF HIGH VOLUME AIR SAMPLER (TSI)

Date: 18/11/2014  
Temp: 20.1°C  
Alt. Press: 762 mm Hg  
Calibrated by: Dennis Tisch  
Next Calibration Due Date: 18/11/2014

Equipment No.	EM-5552
Serial No.	
Calibration No.:	

**Rambeck:** The correlation coefficient is larger than 0.50 indicates the correlation is linear.

Tran's Library Home 206 - A1



Testimony \_\_\_\_\_

#### • **Glaucoma**

*Dolf R*



Stanger Asia

## SOMP ENV052 : CALIBRATION RECORD OF HIGH VOLUME AIR SAMPLER (HS2)


Date: 16/12/2004  
 Temp.: 25 °C  
 Alt. Press.: 1021 milli bar  
 Calibrated by: Dennis Tse  
 Next Calibration Due Date: 16/12/2004

Equipment No.: EM5303  
 Serial No.: 1133000309  
 Calibration No.:

Flow	Flow Rate ml/min	Time in HOD	Corrected Flow (GPM)
18	1.982	10.0	51.55
15	1.677	8.0	48.35
10	1.255	6.2	41.65
7	0.985	4.3	31.85
5	0.753	3.3	24.35

Remarks: The nonlinearity coefficient is larger than 2.00 indicates the calibration is linear.  
 Slope= 0.072677  
 Intercept = -0.305422

Location: Train Metre Area 3B-A2



Tested:

Dennis Tse  
 Dennis Tse

Checked By:

DP/R  
 Arthur Liang



Stanger Asia

SOMP ENV062: CALIBRATION RECORD OF TURBIDIMETERDate of Calibration: 24/09/2004Due Date of Next Calibration: 24/12/2004Equipment No.: EM 2365Manufacturer: HACHModel: 2100PSerial No.: 970500014289Turbidimeter Calibration standard (HACH): No.1: 20 NTUNo.2: 100 NTUNo.3: 800 NTUStock Calibration standard No.: 803Three-point calibration accepted: Y / NStock Calibration checking standards No.: QCS 935

Turbidity value - Checking standards (NTU)		
Actual value	Measured value	Accepted* Y/N
0	0	Y
5	5.2	Y
10	11.0	Y
50	53.2	Y
100	102	Y
400	396	Y

\*Allowing Deviation: +/- 10%

Tested by: Dennis Tsui  
Dennis TsuiChecked by: Jeff Tsang  
Jeff Tsang



Stanger Asia

**SOMP ENV066 : CALIBRATION RECORD OF YSI MODEL 30  
HANDHELD SALINITY, CONDUCTIVITY &  
TEMPERATURE SYSTEM**

Equipment No. FM 3694

Serial No. 00F0285AA

Date of Calibration: 17/09/2004

Due Date of Next Calibration: 17/12/2004

Stock Calibration Standard Potassium Chloride No. 625

Stock Calibration Check Potassium Chloride No. 648

Volumetric glassware employed: V16, V17, V104, V111, V110, V117

Calibration Check of the Salinity, Conductivity and Temperature System	
Calibration Check Solutions, ppt	Meter reading, ppt
0.0	0.0
10.0	10.1
20.0	20.2
30.0	32.0
40.0	42.9

Allowing deviation :  $\pm 10\%$

Tested by: Arthur Cheng

Checked By: Jeff Tsang



Stanger Asia

**SOMP ENV064 : CALIBRATION RECORD OF DISSOLVED OXYGEN METER**

Dissolved Oxygen Meter Equipment No.: EM 961Dissolved Oxygen Serial No.: 93M12874Dissolved Oxygen Probe Serial No.: 96K0145Date of Calibration: 24-09-2004Due Date of Next Calibration: 24-12-2004Molarity of sodium thiosulphate solution: 0.0253MPotassium Bi-iodate No.: 480

Standardisation of Sodium Thiosulphate Solution				
Standard Solution	Initial burette reading B, mL	Final burette reading C, mL	Vol. of Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> used A, mL = (C - B)	
Standard 1	0.00	20.20	20.20	
Standard 2	0.00	20.20	20.20	
Standard 3	0.00	20.20	20.20	
Average Value				20.20

Calibration of the Dissolved Oxygen Meter					
Standard Solutions	Initial burette reading B, mL	Final burette reading C, mL	Vol. of Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> used A, mL = (C - B)	D.O. by estimate, mg/l	Meter reading, mg/l
A	0.00	2.05	2.05	2.07	2.04
B	0.00	5.45	5.45	5.50	5.40
C	0.00	6.80	6.80	6.87	6.75
D	0.00	7.95	7.95	8.03	7.95

Allowing deviation:  $\pm 10\%$ Tested by: Dennis TsuiChecked By: Jeff Tsang

**Appendix III**  
**Event and Actions Plans**

## Event and Action Plan for Air Quality

<b>ACTION</b>					
<b>EVENT</b>	<b>ET Leader</b>	<b>IC (E)</b>	<b>ER</b>	<b>CONTRACTOR</b>	
Action Level Exceedance for one sample	<ol style="list-style-type: none"> <li>1. Identify source, investigate the causes of exceedance and propose remedial measures.</li> <li>2. Inform ER, IEC and Contractor.</li> <li>3. Repeat measurement to confirm findings.</li> <li>4. Increase monitoring frequency to daily.</li> </ol>	<ol style="list-style-type: none"> <li>1. Check monitoring data submitted by ET.</li> <li>2. Check Contractor's working methods.</li> </ol>	<ol style="list-style-type: none"> <li>1. Notify Contractor.</li> </ol>	<ol style="list-style-type: none"> <li>1. Rectify unacceptable practice.</li> <li>2. Amend working methods if appropriate.</li> </ol>	
Exceedance for two or more consecutive samples	<ol style="list-style-type: none"> <li>1. Identify source, investigate the causes of exceedance and propose remedial measures.</li> <li>2. Inform IEC and Contractor.</li> <li>3. Repeat measurement to confirm findings.</li> <li>4. Increase monitoring frequency to daily.</li> <li>5. Discuss with IEC and Contractor on remedial actions.</li> <li>6. If exceedance continues, arrange meeting with IEC and ER.</li> <li>7. If exceedance stops, cease additional monitoring.</li> </ol>	<ol style="list-style-type: none"> <li>1. Check monitoring data submitted by ET.</li> <li>2. Check Contractor's working method.</li> <li>3. Discuss with ET and Contractor on possible remedial measures.</li> <li>4. Advise the ER on the effectiveness of the proposed remedial measures.</li> <li>5. Supervise implementation of remedial measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Confirm receipt of notification of failure in writing.</li> <li>2. Notify Contractor.</li> <li>3. Ensure remedial actions are properly implemented.</li> </ol>	<ol style="list-style-type: none"> <li>1. Submit proposals for remedial actions to ER within 3 working days of notification.</li> <li>2. Implement the agreed proposals.</li> <li>3. Amend proposals if appropriate.</li> </ol>	

**Event and Action Plan for Air Quality (cont'd)**

EVENT	ET Leader	ACTION			CONTRACTOR
		IC (E)	ER		
Limit Level					
Exceedance for one sample	<ol style="list-style-type: none"> <li>1. Identify source, investigate the causes of exceedance and propose remedial measures.</li> <li>2. Inform ER, Contractor and EPD.</li> <li>3. Repeat measurement to confirm findings.</li> <li>4. Increase monitoring frequency to daily.</li> <li>5. Assess effectiveness of Contractor's remedial actions and keep IEC, EPD and ER informed of the results.</li> <li>6. Supervisor implementation of remedial measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Check monitoring data submitted by ET.</li> <li>2. Check Contractor's working method.</li> <li>4. Discuss with ET and Contractor on possible remedial measures.</li> <li>5. Advise the ER on the effectiveness of the proposed remedial measures.</li> <li>6. Supervisor implementation of remedial measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Confirm receipt of notification of failure in writing.</li> <li>2. Notify Contractor.</li> <li>3. Ensure remedial actions properly implemented.</li> </ol>	<ol style="list-style-type: none"> <li>1. Take immediate action to avoid further exceedances.</li> <li>2. Submit proposals for remedial actions to IEC within 3 working days of notification.</li> <li>3. Implement the agreed proposals.</li> <li>4. Amend proposal if appropriate.</li> </ol>	
Exceedance for two or more consecutive samples	<ol style="list-style-type: none"> <li>1. Identify source, investigate the causes of exceedance and propose remedial measures.</li> <li>2. Inform IEC, ER and Contractor and EPD.</li> <li>3. Repeat measurements to confirm findings.</li> <li>4. Increase monitoring frequency to daily.</li> <li>5. Carry out analysis of Contractor's working procedures to determine possible mitigation measure(s) to be implemented.</li> <li>6. Arrange meeting with IEC and ER to discuss the remedial actions to be taken.</li> <li>7. Assess effectiveness of Contractor's remedial actions and keep IEC, EPD and ER informed of the results.</li> <li>8. If exceedance stops, cease additional monitoring.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss amongst ER, ET and Contractor on the potential remedial actions.</li> <li>2. Review Contractor's remedial actions whenever necessary to assure their effectiveness and advise the ER accordingly.</li> <li>3. Supervise the implementation of remedial measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Confirm receipt of notification of failure in writing.</li> <li>2. Notify Contractor.</li> <li>3. In consultation with the IEC, agree with the Contractor on the remedial measures to be implemented.</li> <li>4. Ensure remedial measures properly implemented.</li> <li>5. If exceedance continues, consider what portion of the work is responsible and instruct the Contractor to stop that portion of work until the exceedance is abated.</li> </ol>	<ol style="list-style-type: none"> <li>1. Take immediate action to avoid further exceedance.</li> <li>2. Submit proposals for remedial actions to IEC within 3 working days of notification.</li> <li>3. Implement the agreed proposals.</li> <li>4. Resubmit proposals if problem still not under control.</li> <li>5. Stop the relevant portion of works as determined by the ER until the exceedance is abated.</li> </ol>	

**Event and Action Plan for Water Quality**

EVENT	ACTION			
	ET	IEC	ER	CONTRACTOR
Action level				
Action level being exceeded by one sampling day.	<ol style="list-style-type: none"> <li>1. Repeat in-situ measurements to confirm findings;</li> <li>2. Identify source(s) of impacts;</li> <li>3. Inform IEC and Contractor;</li> <li>4. Check monitoring data, all plant, equipment and Contractor's working methods;</li> <li>5. Discuss mitigation measures with IEC and Contractor;</li> <li>6. Repeat measurements on next day of exceedance.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss with ET and Contractor on the mitigation measures;</li> <li>2. Review proposals on mitigation measures submitted by Contractor and advise ER accordingly;</li> <li>3. Assess the effectiveness of implemented mitigation measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss with IEC on the proposed mitigation measures;</li> <li>2. Make agreement on the mitigation measures to be implemented.</li> </ol>	<ol style="list-style-type: none"> <li>1. Inform the ER and confirm notification of the non-compliance in writing;</li> <li>2. Rectify unacceptable practice;</li> <li>3. Check all plant and equipment;</li> <li>4. Consider changes of working methods;</li> <li>5. Discuss with ET and IEC and propose mitigation measures to IEC and ER;</li> <li>6. Implement the agreed mitigation measures.</li> </ol>
Action level being exceeded by more than one consecutive sampling day.	<ol style="list-style-type: none"> <li>1. Repeat in-situ measurements to confirm findings;</li> <li>2. Identify source(s) of impact;</li> <li>3. Inform contractor and IEC;</li> <li>4. Check monitoring data, all plant, equipment and Contractor's working methods;</li> <li>5. Discuss mitigation measures with ER and Contractor;</li> <li>6. Ensure mitigation measures are implemented;</li> <li>7. Prepare to increase the monitoring frequency to daily;</li> <li>8. Repeat measurements on next day of exceedance.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss with ET and Contractor on the proposed mitigation measures;</li> <li>2. Review proposals on mitigation measures submitted by Contractor and advise ER accordingly;</li> <li>3. Assess the effectiveness of the implemented mitigation measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss with IEC on the proposed mitigation measures;</li> <li>2. Make agreement on the mitigation measures to be implemented;</li> <li>3. Assess the effectiveness of the implemented mitigation measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Inform the Engineer and confirm notification of the non-compliance in writing;</li> <li>2. Rectify unacceptable practice;</li> <li>3. Check all plant and equipment;</li> <li>4. Consider changes of working methods;</li> <li>5. Discuss with the ET and IEC and propose mitigation measures to IEC and ER within 3 working days;</li> <li>6. Implement the agreed mitigation measures.</li> </ol>

**Event and Action Plan for Water Quality (Cont'd)**

EVENT	ACTION			
	ET	IEC	ER	CONTRACTOR
<b>Limit level</b>				
Limit level being exceeded by one sampling day.	<ol style="list-style-type: none"> <li>1. Repeat in-situ measurements to confirm findings;</li> <li>2. Identify source(s) of impact;</li> <li>3. Inform contractor and IEC;</li> <li>4. Check monitoring data, all plant, equipment and Contractor's working methods;</li> <li>5. Discuss mitigation measures with ER and Contractor;</li> <li>6. Ensure mitigation measures are implemented;</li> <li>7. Prepare to increase the monitoring frequency to daily until no exceedance of Limit level.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss with ET and Contractor on the mitigation measures;</li> <li>2. Review proposals on mitigation measures submitted by the Contractor and advise the ER accordingly;</li> <li>3. Assess the effectiveness of implemented mitigation measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss with IEC, ET and Contractor on the proposed mitigation measures;</li> <li>2. Request Contractor to critically review the working methods;</li> <li>3. Make agreement on the mitigation measures to be implemented;</li> <li>3. Assess the effectiveness of the implemented mitigation measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Inform the Engineer and confirm notification of the non-compliance in writing;</li> <li>2. Rectify unacceptable practice;</li> <li>3. Check all plant and equipment;</li> <li>4. Consider changes of working methods;</li> <li>5. Discuss with the ET and IEC and propose mitigation measures to IEC and ER within 3 working days;</li> <li>6. Implement the agreed mitigation measures.</li> </ol>
Limit level being exceeded by more than one sampling day.	<ol style="list-style-type: none"> <li>1. Repeat in-situ measurements to confirm findings;</li> <li>2. Identify source(s) of impact;</li> <li>3. Inform contractor and IEC;</li> <li>4. Check monitoring data, all plant, equipment and Contractor's working methods;</li> <li>5. Discuss mitigation measures with ER and Contractor;</li> <li>6. Ensure mitigation measures are implemented;</li> <li>7. Increase the monitoring frequency to daily until no exceedance of Limit level for two consecutive days.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss with ET and Contractor on the mitigation measures;</li> <li>2. Review proposals on mitigation measures submitted by the Contractor and advise ER accordingly;</li> <li>3. Assess the effectiveness of implemented mitigation measures.</li> </ol>	<ol style="list-style-type: none"> <li>1. Discuss with IEC on the proposed mitigation measures;</li> <li>2. Request Contractor to critically review the working methods;</li> <li>3. Make agreement on the mitigation measures to be implemented;</li> <li>4. Assess the effectiveness of the implemented mitigation measures.</li> <li>5. Consider and instruct, if necessary, the Contractor to slow down or to stop all or part of works identified as the cause of exceedance until no exceedance of Limit level.</li> </ol>	<ol style="list-style-type: none"> <li>1. Inform the Engineer and confirm notification of the non-compliance in writing;</li> <li>2. Rectify unacceptable practice;</li> <li>3. Check all plant and equipment;</li> <li>4. Consider changes of working methods;</li> <li>5. Discuss with the ET and IEC and propose mitigation measures to IEC and ER within 3 working days;</li> <li>6. Implement the agreed mitigation measures;</li> <li>7. As directed by the Engineer, slow down or stop all or part of the works identified as the cause of exceedance or construction activities.</li> </ol>

**Appendix IV**  
**Implementation Status of Mitigation Measures**

## IMPLEMENTATION STATUS OF MITIGATION MEASURES

<b>Area</b>	<b>Mitigation Measures</b>	<b>Implementation Period</b>	<b>Implementation Status</b>
1. General	Maximum stockpiling height to be limited to a maximum of +35mPD.	Throughout the operation period	Implemented
2. Air Quality	Working areas where excavation or earthmoving operations are taking place shall be sprayed with water or a dusty suppression chemical.  Any stockpiling of excavated material shall be covered by impervious sheeting or sprayed with water or a dust suppression chemical.	Throughout the operation period	Occasionally implemented
	All roads within the site to be covered with concrete, bituminous materials, hardcore or metal plates.  Erect a hoarding of at least 2.4m high along the northern and eastern boundaries of the site except at the site entrance/exit.  Before occupation of the Recovery Park Phase I and II, site hoarding of at least 2.4m high should also be erected along the western boundary of the fill bank.	Throughout the operation period	Implemented
	Install/refurbish vehicle wheel washing facilities including high pressure water jets provided at designated vehicle exit points.  At the barging point, the drop height between the barge and dump trucks shall be minimized.	Throughout the operation period	Implemented
	Tipping halls provided for transfer of public fill from trucks to barges shall be top and 3-sides enclosed.  Water lorries and/or road sweepers shall be provided and used in dust suppression.	Throughout the operation period	Implemented
	The designated main haul roads shall be watered at approximately every 2 hours to ensure that the roads are kept sufficiently dampened.	Throughout the operation period	Implemented

Area	Mitigation Measures	Implementation Period	Implementation Status
2. Air Quality	Truck speed to be controlled to within 10 km/hr.	Throughout the operation period	Implemented
	All dusty fill material shall be sprayed with water or a dust suppression chemical prior to loading, unloading or transfer.	Throughout the operation period	Occasionally Implemented
	Frequent watering (at least three times per day) of the worksites with active dusty operations is recommended. The frequency shall be increased when the weather is dry.	Throughout the operation period	Implemented
	Loading of public fill delivered to the site shall be sprayed with water at the material landing point to minimize dust emission except when the materials are sufficiently dampened when landing.	Throughout the operation period	Occasionally Implemented
	Vehicle washing facilities including high pressure water jet at the existing exits shall be maintained and operated by designated staff to ensure that these dust control measures are being used.	Throughout the operation period	Implemented
	Before leaving the fill bank site, every vehicle shall be washed to remove any dusty materials from its body and wheels.	Throughout the operation period	Implemented
	Trucks carrying dusty loads entered to the site shall be sprayed with water once the impervious sheeting covering the load is removed.	Throughout the operation period	Implemented
	A minimum buffer distance of 20m shall always be maintained between the edge of public fill stockpiling area and the nearest air sensitive receivers at the River Trade Terminal.	Throughout the operation period	Implemented
	An area of 100m x 100m in the north-eastern corner of the stockpiling area shall be managed by the Contractor as a “truckload control zone”. Number of trucks traveling to the control zone shall be limited to a maximum of 64 vehicles per hour, and a daily maximum of 633 vehicles per day.	Throughout the operation period	Implemented

Area	Mitigation Measures	Implementation Period	Implementation Status
2. Air Quality	A minimum buffer zone of 20m shall be maintained between the edge of the public fill stockpiling area and the nearest air sensitive land use at Recovery Park Phase I and Phase II along the western boundary of the site.	Throughout the operation period	Implemented
	Temporary slope surfaces shall be covered with tarpaulin sheets or other impermeable sheets, or sprayed with water or a dust suppression chemical, or protected by other methods approved by CED.	Throughout the operation period	Partially implemented
	Final slope surfaces shall be treated by compaction, followed by hydroseeding, vegetation planting or other suitable surface stabiliser approved by CED to prevent the washing away of stockpiled material.	Throughout the operation period	Implemented
	Any belt conveyor systems used for transfer of dusty materials shall be enclosed on top and 2 sides.	Throughout the operation period	N/A
	Every transfer point between two conveyors shall be totally enclosed.	Throughout the operation period	N/A
	An effective belt scraper or equivalent device shall be installed at the head pulley of every belt conveyor to dislodge fine particles that may adhere to the belt surface.	Throughout the operation period	N/A
	The belt conveyor shall be equipped with bottom plates or other similar means to prevent falling of material from the return belt.	Throughout the operation period	N/A
	Every stockpiling belt conveyor shall be provided with a mechanism to adjust its level such that the vertical distance between the belt conveyor and the material landing point is maintained at no more than 1m.	Throughout the operation period	N/A
	Dusty materials loaded from a belt conveyor outlet to stockpiles, storage bins, trucks, barges and other open areas shall be sprayed with water or a dust suppression chemical.	Throughout the operation period	N/A

<b>Area</b>	<b>Mitigation Measures</b>	<b>Implementation Period</b>	<b>Implementation Status</b>
2. Air Quality	Frequent mist spraying should be applied on dusty areas. The frequency of spraying required will depend upon local meteorological conditions such as rainfall, temperature, wind speed and humidity. The amount of mist spraying should be just enough to dampen the material without over-watering.	Throughout the operation period	Implemented
3. Noise	No project activities associated with land-based intake of public fill shall be carried out between 20:00 and 08:00 hrs daily.  All construction works should be carried out during the non-restricted hours (i.e. 7.00 a.m. to 7.00 p.m. on weekdays other than General Holidays).  Before the commencement of any works that may generate a significant noise impact, the Contractor should submit to the Engineer for approval the method of working, equipment and sound-reducing measures (e.g. use of silenced type equipment).  The fill bank should not be in operation from 8:00 p.m. to 8:00 a.m. the next day.	Throughout the operation period  Throughout the operation period  Throughout the operation period	Implemented  N/A  N/A
4. Water Quality	Trapezoidal surface channels should be constructed to intercept polluted surface runoff. These channels shall be equipped with sand/de-silting traps such that the effluent discharged from site during the establishment, operation and decommissioning phases will meet the required discharge limits.  Tipping halls at the waterfront provided for transfer of public fill from trucks to barges shall be enclosed design with the top 3-sides enclosed to prevent spillage of material into the marine water.  Before the completion of the surface drainage channels at the commencement of the project, earth bunds and sand bag barriers shall be use at required locations to effectively divert storm water to available drainage channels constructed under the reclamation works.	Throughout the operation period  Throughout the operation period	Implemented  Implemented

Area	Mitigation Measures	Implementation Period	Implementation Status
4. Water Quality	Temporary drainage facilities provided shall allow polluted stormwater to be diverted to existing intercepting channels before stockpiling of public fill should begin.	Throughout the operation period	Implemented
	Intercepting channels shall be equipped with sand/silt removal facilities to allow the stormwater to be treated before discharge at the designated outfalls.	Throughout the operation period	Implemented
	Effluent discharged shall meet the relevant discharge limits.	Throughout the operation period	N/A
	A minimum buffer distance of 50m will be provided between the edge of the stockpiling area of the fill bank and seafront.	Throughout the operation period	Implemented
	Open channels and/or other effective drainage system shall be constructed at the perimeter of the site for intercepting and directing runoff to sand/silt removal facilities prior to discharge.	Throughout the operation period	Implemented
	The unpaved area on the seaward side of the channels shall be covered with gravel and formed with slope so that polluted stormwater will be intercepted by the channels.	Throughout the operation period	Implemented
	Any excavated material generated near the seafront (e.g. from the construction of the barging point) not required to be backfilled immediately should be transported away from the seafront to avoid potential water quality impact especially during the rainy season.	Throughout the operation period	Implemented
	Public fill transported to the stockpiling area for storage should not contain unsuitable material such as peat, vegetation, timber, organic, soluble or perishable material, dangerous or toxic material, floatable materials (such as bottle, plastic bags, foam box), and materials susceptible to combustion.	Throughout the operation period	Implemented

Area	Mitigation Measures	Implementation Period	Implementation Status
4. Water Quality	Temporary slope surfaces shall be covered as far as practicable and as soon as possible with tarpaulin or other impermeable sheets, or protected by other methods approved by CED when rainstorms are likely, especially when a rainstorm is imminent or forecast.	Throughout the operation period	Implemented
	Final slope surfaces shall be treated by compaction, followed by hydroseeding, vegetation planting or other suitable stabilizer approved by CED to prevent the washing away of stockpiled material.	Throughout the operation period	Partially Implemented
	Adequately designed and constructed catchpits, sand and silt removal facilities and intercepting channels should be maintained, and the deposited silt and grit should be removed weekly and on a as need basis especially during the onset of and after each rainstorm to ensure that these facilities are functioning properly at all times.	Throughout the operation period	Implemented
	A wheel washing bay should be provided at the site exit and washwater should have sand and silt settled out or removed before the water is being reused or discharged into storm drains.	Throughout the operation period	Implemented
	All vehicles and plant bodies should be cleaned before they leave the fill bank site to ensure that no earth, mud or debris is deposited by them on roads.	Throughout the operation period	Implemented
	The section of construction road between the wheel washing bay and the public road should be paved with concrete, bituminous materials or hardcores to reduce vehicle tracking of soil and to prevent site run-off from entering public roads drains.	Throughout the operation period	Implemented

Area	Mitigation Measures	Implementation Period	Implementation Status
4. Water Quality	<p>Sewage from toilets and similar facilities should be discharged into a foul sewer, or chemical toilets should be provided. Should chemical toilets be employed these must be provided by a licensed contractor, who will be responsible for appropriate disposal and maintenance of these facilities.</p> <p>Wastewater collected from canteen kitchens, including that from basins, sinks and floor drains, should be discharged into foul sewers via grease traps.</p>	Throughout the operation period	Implemented
	<p>Drainage systems provided at car parking areas shall be provided with oil interceptors in addition to sand/silt removal facilities.</p>	Throughout the operation period	N/A
	<p>All barges used in the transportation of fill material during the operation/decommissioning stages should be properly licensed under the Shipping and Port Control Ordinance, and of appropriate size such that adequate clearance is maintained between the vessels and the sea bed at all states of the tide.</p>	Throughout the operation period	Implemented
	<p>All vessels used for transportation of fill material should have tight fitting seals to their bottom openings.</p>	Throughout the operation period	Implemented
	<p>When backhoe fixed on an appropriately designed flat-top pontoon is in use, the reach of the backhoe shall be controlled to within the flat-top pontoon of sufficient length to avoid accidental dropping of public fill into the sea.</p>	Throughout the operation period	N/A
	<p>When hopper barges with mobile crane is in use, guardrails or equivalent shall be fixed alongside the berthing faces to guide the movement of the crane to avoid accidental dropping of fill material.</p>	Throughout the operation period	N/A
	<p>When derrick barges with built-in crane are in use, the reach of the jib shall be controlled to within the length of the barge to avoid accidental dropping of public fill into the sea.</p>	Throughout the operation period	Implemented

Area	Mitigation Measures	Implementation Period	Implementation Status
4. Water Quality	<p>The design of the specific transfer methods shall be as such that the pathway of material delivery from barge to the waterfront will not be directly on top of the marine water.</p> <p>Barges should not be filled to a level which may cause overflow of material during loading or transportation.</p> <p>Barge effluents (e.g. muddy water) should be properly collected and treated prior to disposal.</p>	Throughout the operation period	Implemented
5. Landfill Gas	<p>Work activities should not cause any visible foam, oil, grease, scum, litter or other objectionable matters to be present on the water in the vicinity of the barging point.</p> <p>A waste collection vessel shall be deployed to remove floating refuse on the sea near the fill bank for proper disposal.</p>	Throughout the operation period	Implemented
	<p>Main site offices of the fill bank shall be constructed within the site area lying outside the 250m consultation zone of the restored Siu Lang Shui Landfill.</p>	Throughout the operation period	Occasionally Implemented
	<p>The container office(s) to be set up at the site entrance/exit which is situated within the construction zone of the landfill shall be constructed on a raised hollow platform, or equivalent.</p>	Throughout the operation period	Implemented
	<p>No underground structures such as drainage and sewage systems, underground pipelines and chambers shall be constructed at the site area lying within the consultation zone.</p>	Throughout the operation period	Implemented
	<p>In the unlikely event that any sign of leachate-contaminated groundwater be encountered during the establishment, operation or decommissioning phases of the fill bank, the landfill operator should be informed so that this can be collected for proper treatment and disposal.</p>	Throughout the operation period	Implemented

Area	Mitigation Measures	Implementation Period	Implementation Status
6. Landscape and Visual	<p>Hydroscreeding or coloured geo-textile matting (dark green/brown) shall be provided on the slopes of the fill bank along the eastern, northern and western sides of the fill bank as the slopes of each layer of platform are formed.</p> <p>A buffer tree planting strip should be provided along the northern perimeter of the site where space permits. A row of approximately 3m high native evergreen tree species with a tall habit when fully grown (e.g. Casuarina equisetifolia) shall be planted at the early establishment/ operational phase of the project.</p>	<p>Throughout the operation period</p>	Implemented
	<p>The design, colour and finish of structures at the fill bank should be such that they are visually recessive. Reflectivity should be reduced through selection of material or surface treatment.</p>	<p>Throughout the operation period</p>	Implemented
	<p>The surface colour selected should be of an earthy tone with strong natural qualities (e.g. green/grey/brown). The use of bold colour schemes should be avoided.</p> <p>The existing 2.4m high site hoarding located along Lung Mun Road should be maintained to help screening of the fill bank.</p>	<p>Throughout the operation period</p>	Implemented

**Appendix V**  
**Air Quality Monitoring Results**

### Report on 24-hour Total Suspended Particulate Monitoring - A1

Sample Number	Location Code	Date and Time of Sampling	Start Counter Reading	Stop Counter Reading	Temperature, °C	Pressure, mmHg	Weather Conditions	Wind Direction	Weight of Filter, g Initial/Final	Flow rate Q <sub>a</sub> , std m <sup>3</sup> /min	Total air volume of sample, std m <sup>3</sup>	Mass Concentration of TSP, µg/std m <sup>3</sup>
13221	A1	02/11/2004 14:40	2269.03	2314.19	24	763	Sunny	N	2.8499	1.32	1993	108
13233	A1	08/11/2004 15:50	2317.19	2341.67	24	763	Sunny	E	2.8448	1.32	1999	108
13266	A1	13/11/2004 14:55	2344.67	2369.69	24	764	Sunny	E	2.8312	1.32	1982	110
13274	A1	19/11/2004 15:20	2372.69	2396.69	20	765	Sunny	E	3.0499	1.32	1901	177
13292	A1	25/11/2004 15:25	2399.67	2423.97	24	766	Sunny	NE	2.8370	1.32	1925	123
					22	765			3.0745			

### Report on 24-hour Total Suspended Particulate Monitoring - A2

Sample Number	Location Code	Date and Time of Sampling	Start Counter Reading	Stop Counter Reading	Temperature, °C	Pressure, mmHg	Weather Conditions	Wind Direction	Weight of Filter, g Initial/Final	Flow rate Q <sub>a</sub> , std m <sup>3</sup> /min	Total air volume of sample, std m <sup>3</sup>	Mass Concentration of TSP, µg/std m <sup>3</sup>
13119	A2	02/11/2004 14:55	10471.35	10495.36	24	764	Sunny	N	2.8431	1.27	1829	125
13034	A2	08/11/2004 16:00	10499.35	10522.36	24	763	Sunny	E	2.8410	1.27	1829	121
13058	A2	13/11/2004 14:35	10525.35	10549.36	24	764	Sunny	E	2.8450	1.27	1829	128
13075	A2	19/11/2004 15:40	10552.35	10576.36	20	765	Sunny	E	2.8542	1.29	1858	124
13093	A2	25/11/2004 15:40	10579.35	10603.36	24	766	Sunny	NE	2.8547	1.29	1858	144
					22	765			3.1023			

## Report on 1-hour Total Suspended Particulate Monitoring - A1

Sample Number	Location Code	Date and Time	Start Counter Reading	Stop Counter Reading	Temperature, °C	Pressure, mmHg	Weather Conditions	Wind Direction	Weight of Filter, g	Flow rate Q <sub>gas</sub> , std. m <sup>3</sup> /min	Total air volume of sample, std. m <sup>3</sup>	Mass Concentration of TSP, µg/std. m <sup>-3</sup>
							Initial/Final					
13206	A1	02/11/2004 09:35	2286.03	2287.03	24	763	Sunny	N	2.8600	1.32	79	265
13210	A1	02/11/2004 10:35	2287.03	2288.03	24	763	Sunny	N	2.8686	1.32	79	265
12314	A1	02/11/2004 13:40	2288.03	2289.03	24	763	Sunny	N	2.8456	1.32	79	265
13224	A1	06/11/2004 10:40	2314.19	2315.19	24	763	Sunny	E	2.8440	1.32	79	319
13227	A1	06/11/2004 13:06	2315.19	2316.19	24	763	Sunny	E	2.8693	1.32	79	223
13230	A1	06/11/2004 14:45	2316.19	2317.19	24	763	Sunny	E	2.8360	1.32	79	203
13244	A1	13/11/2004 09:15	2341.67	2342.67	24	764	Sunny	E	2.8521	1.32	79	221
13248	A1	13/11/2004 10:15	2342.67	2343.67	24	764	Sunny	E	2.8606	1.32	79	264
13252	A1	13/11/2004 13:15	2343.67	2344.67	24	764	Sunny	E	2.8422	1.32	79	293
13265	A1	19/11/2004 09:15	2369.69	2370.69	20	765	Sunny	E	2.8654	1.32	79	188
13268	A1	19/11/2004 10:20	2370.69	2371.69	20	765	Sunny	E	2.8444	1.32	79	158
13271	A1	19/11/2004 14:15	2371.69	2372.69	20	765	Sunny	E	2.8223	1.32	79	311
13265	A1	25/11/2004 10:55	2396.60	2397.67	24	766	Sunny	NE	2.8370	1.32	85	399
13268	A1	25/11/2004 12:10	2397.67	2398.67	24	766	Sunny	NE	2.8649	1.32	79	223
13269	A1	25/11/2004 13:55	2398.67	2399.67	24	766	Sunny	NE	2.8461	1.32	79	192

## Report on 1-hour Total Suspended Particulate Monitoring - A2

Sample Number	Location Code	Date and Time of Sampling	Start Counter Reading	Stop Counter Reading	Temperature, °C	Pressure, mmHg	Weather Conditions	Wind Direction Initial/Final	Weight of Filter, g	Flow rate Q <sub>std</sub> , std. m <sup>3</sup> /min	Mass Concentration of TSP, µg/std. m <sup>3</sup>		
											Initial	Final	of sample, std. m <sup>3</sup>
13208	A2	02/11/2004 09:55	10469.35	10469.35	24	763	Sunny	N	2.8400	1.27	76	203	
13212	A2	02/11/2004 10:55	10469.35	10470.35	24	763	Sunny	N	2.8624				
13216	A2	02/11/2004 13:55	10470.35	10471.35	24	763	Sunny	N	2.8326	1.27	76	296	
13226	A2	02/11/2004 10:45	10496.35	10496.35	24	763	Sunny	E	2.8521				
13229	A2	08/11/2004 13:10	10496.35	10497.35	24	763	Sunny	E	2.8432	1.27	76	240	
13232	A2	08/11/2004 14:55	10497.35	10498.35	24	763	Sunny	E	2.8621				
13246	A2	13/11/2004 09:35	10522.35	10523.35	24	764	Sunny	E	2.8637	1.3	79	295	
13250	A2	13/11/2004 10:35	10523.35	10524.35	24	764	Sunny	E	2.8589				
13254	A2	13/11/2004 13:35	10524.35	10525.35	24	764	Sunny	E	2.8443	1.3	78	335	
13266	A2	19/11/2004 09:30	10549.35	10550.35	20	765	Sunny	E	2.8704				
13269	A2	19/11/2004 10:35	10550.35	10551.35	20	765	Sunny	E	2.8295	1.27	76	264	
13272	A2	19/11/2004 14:30	10551.35	10552.35	20	765	Sunny	E	2.8496				
13284	A2	25/11/2004 10:40	10576.35	10577.35	24	766	Sunny	NE	2.8343	1.27	76	240	
13287	A2	25/11/2004 11:55	10577.35	10578.35	24	766	Sunny	NE	2.8430	1.28	77	209	
13290	A2	25/11/2004 14:10	10578.35	10579.35	24	766	Sunny	NE	2.8500	1.28	77	282	

**Appendix VI**  
**Water Quality Monitoring Results**

Project Contract No. CIV/2002/13 Fil Bank At Tien Man Area 3B							Client: Gentle-Ocean Construction Co., Ltd. Job No.: 4654.1									
Date of Sampling:	01/11/2004	Weather Condition:			Cloudy			Ambient Temperature, °C.:			23			Tide State:	Mid-Flood	
Station	Time	Site Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/l	Dissolved Oxygen, mg/l Percentage	a	b	Average	a	b	NTU	Turbidity, NTU	Suspended Solids, mg/l	Remarks
FMI S			1.0	26.5	26.5	7.03	7.12	50.3	91.4	91.2	31.6	4.92	4.87	15	13	
FMI M	10:40	Small wave	17.0	8.5	26.4	26.5	7.11	7.09	91.5	91.4	31.7	31.7	4.86	6.00	5.30	14
FMI B			16.0	26.2	26.3	6.94	6.99	6.97	88.7	88.9	88.8	31.7	6.20	5.97	15	13
FBD M	10:15	Small wave	18.0	9.0	26.4	26.5	7.05	7.14	52.3	93.2	93.7	31.9	6.13	6.16	13	15
FBD B			17.0	26.4	26.4	6.93	6.90	6.92	89.4	89.0	89.2	31.8	4.48	4.46	12	13
FC1 M	10:26	Small wave	22.0	11.0	26.2	26.2	7.06	7.11	92.0	92.4	91.0	31.7	5.46	5.51	15	17
FC1 B			21.0	26.0	26.1	6.85	6.92	6.89	90.4	90.9	90.7	31.8	5.34	5.31	14	14
FC2 S			1.0	26.9	26.9	6.99	6.95	7.03	89.9	89.7	91.0	31.8	6.42	6.36	5.40	14
FC2 M	10:00	Small wave	17.0	8.5	25.9	25.8	7.00	7.06	91.7	92.5	91.3	31.8	4.96	5.01	4.69	13
FC2 B			13.0	26.0	26.0	6.87	6.87	6.87	87.8	87.6	87.7	31.8	4.00	4.00	12	11

Bold data with single underline indicates an exceedance to Action Level  
Bold data with double underline indicates an exceedance to Limit Level

Equipment used:	Dissolved Oxygen Meter:	EM	961	Calibration Check:	0mg/L ok	100% ok	Sampled By:
	Turbidity Meter:	EM	2365	Calibration Check:	4.68, 47.1,	465 NTU	Checked By:
	Salinity Meter:	EM	3694	Calibration Check:	50.7	mS	Date:
	Thermometer:	ET	961				

Project Contract No. CWY200213 Fall Bank At Tree Mtn Area 38

Date of Sampling : 06/11/2004

Client: Eesti-Ocean Construction Co., Ltd. Job No.: 44341

Station	Time	Sea Condition	Sampling Depth, m			Dissolved Oxygen, mg/L			Salinity, ppt			Turbidity, NTU			Tide Status	M-EBB		
			a	b	c	a	b	c	a	b	c	a	b	c				
Fm1 S			1.0	26.7	26.7	7.23	7.01		94.2	90.1		31.6	6.10	6.26	15	15		
Fm1 M	15:15	Small wave	17.0	8.5	25.9	6.99	6.98		89.4	88.6		31.6	6.23	6.23	6.10	14	14	
Fm1 B			16.0	25.5	25.4	6.72	6.68		67.0	66.3	66.0	68.2	31.7	5.92	5.86	13	12	
Fm2 S			1.0	26.2	26.1	6.90	6.96		89.4	89.2		31.6	6.05	6.71	16	17		
Fm2 M	15:25	Small wave	17.0	8.5	26.1	7.12	7.13		92.4	92.4		31.8	5.81	5.10	6.22	15	13	
Fm2 B			16.0	25.7	25.8	7.00	7.02		7.01	89.6	89.7	89.7	31.9	7.54	7.51	14	15	
Fc1 S			1.0	26.9	26.9	7.01	7.07		89.8	90.5		31.7	5.23	5.37	15	17		
Fc1 M	15:00	Small wave	22.0	11.0	25.1	25.2	7.00	6.99	89.7	89.6		31.9	5.86	5.87	5.53	12	10	
Fc1 B			21.0	25.8	25.7	6.98	6.85		6.87	88.5	88.3	88.4	92.0	5.47	5.36	12	13	
Fc2 S			1.0	26.1	26.0	6.90	6.94		90.1	89.9		31.6	6.73	5.74	13	16		
Fc2 M	15:40	Small wave	17.0	8.5	26.1	26.2	6.94		6.99	89.0	88.8		31.7	5.98	5.61	6.20	12	12
Fc2 B			16.0	25.7	25.9	6.97	6.90		6.94	89.9	89.4	89.7	32.1	7.25	7.26	13	14	

**Bold data with single underline indicates an exceedance to Action Level**  
**Basic data with double underline indicates no exceedance to Limit Level**

Equipment used:

Dissolved Oxygen Meter: EM 961

Calibration Check: 0mg/L ok 100% ok

Sampled By:

Turbidity Meter: EM 2366

Calibration Check: 4.63, 45.2, 452 NTU

Checked By:

Salinity Meter: EM 3884

Calibration Check: 58.7 mS

Date:

Thermometer: ET 961

Project: Contract No. CIV/2020/3 Fil Bank At Tuen Mun Area 32

Date of Sampling	04/11/2004	Weather Condition:			Cloudy			Ambient Temperature, °C:			26			Tide State:	Mid-Flood
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Salinity, ‰	pH	Turbidity, NTU	Suspended Solids, mg/L	Remarks				
FM1 S			1.0	26.1	6.36	6.38	a	b	a	b	16	18			
FM1 M	17:36	Small wave	18.0	9.0	26.4	6.11	6.20	80.4	81.0	82.7	32.7	4.40	4.58		
FM1 B			17.0	26.3	6.37	6.41	6.39	84.6	83.1	83.9	32.0	32.0	6.92		
FM2 S			1.0	26.2	6.62	6.61	6.55	86.0	85.6	84.9	32.9	32.9	4.50	4.71	
FM2 M	17:25	Small wave	18.0	9.0	26.3	6.47	6.51	83.1	84.0	83.1	33.1	33.1	5.54	5.62	
FM2 B			17.0	26.4	6.56	6.60	6.59	85.7	85.5	86.2	33.0	33.0	6.00	6.11	
FC1 S			1.0	26.4	6.72	6.73	6.68	87.1	85.1	86.8	33.0	33.0	5.16	5.12	
FC1 M	17:50	Small wave	23.0	11.5	26.5	6.68	6.59	86.9	87.0	82.9	32.9	32.9	5.76	5.81	
FC1 B			22.0	26.4	6.71	6.58	6.65	86.9	85.7	86.3	32.9	32.9	6.40	6.31	
FC2 S			1.0	26.1	6.30	6.28	6.25	83.0	83.7	82.6	32.8	32.8	5.75	5.81	
FC2 M	17:10	Small wave	18.0	9.0	26.3	6.21	6.20	82.6	81.1	82.7	32.7	32.7	3.95	4.14	
FC2 B			17.0	26.4	6.14	6.11	6.13	80.1	80.1	80.1	32.8	32.8	7.09	7.21	

**Bold data with single underline** indicates an exceedance to Action Level  
Basic data with double underline indicates an exceedance to Limit Level

Equipment used	Dissolved Oxygen Meter:	EM	961	Calibration Check: 0mg/L ok	100%: ok	Sampled By:	
	Turbidity Meter:	EM	2366	Calibration Check: 4.49	45.8,	455	NTU
	Salinity Meter:	EM	3684	Calibration Check: 59.9	mS	Checked By:	
	Thermometer:	ET	961	Data:			

Project: Contract No. CV/2000/3 Fill Bank At Tum Mun Area

Date of Sampling: 04/11/2004

Client: Ports-Ocean Construction Co., Ltd. Job No.: 449.1.1

Station	Time	Sea Condition	Weather Condition:			Sampling Temperature, °C			Dissolved Oxygen, mg/L			Salinity, ‰			Turbidity, NTU			Tide State:			
			a	b	Average	a	b	Average	a	b	Average	a	b	Average	a	b	Average	a	b	Average	Remarks
FMI S	07:45	Small wave	1.0	25.4	25.4	6.11	6.14	6.00	80.2	81.1	78.8	33.0	33.0	33.0	4.55	4.51	4.51	17	18		
FMI M	07:55	Small wave	17.0	8.5	26.6	5.05	5.07	78.9	77.1	78.8	33.1	33.1	33.1	4.59	4.62	4.62	18	21	20.2		
FMI B			16.0	26.5	26.5	6.61	6.69	6.65	74.3	76.9	76.1	33.1	33.1	33.1	4.71	4.80	4.80	22	26		
FHQ S			1.0	26.8	26.8	6.59	6.47	6.37	83.4	83.8	82.9	32.9	32.9	32.9	3.88	3.62	3.62	18	18		
FHQ M			17.0	8.5	26.6	6.21	6.19	6.26	81.9	82.6	82.9	33.1	33.1	33.1	4.61	4.45	4.45	25	24	23.0	
FHQ B			16.0	25.7	25.7	6.11	6.14	6.13	81.4	79.3	80.4	33.0	33.0	33.0	5.22	5.27	5.27	28	25		
FC1 S			1.0	26.1	26.1	6.24	6.36	6.24	82.6	82.7	82.3	32.7	32.7	32.7	6.56	6.80	6.80	26	24		
FC1 M	07:30	Small wave	22.0	11.0	26.2	6.20	6.17	6.19	82.0	82.0	82.0	32.8	32.8	32.8	4.69	4.73	4.73	5.36	27	26	26.5
FC1 B			21.0	26.0	26.0	6.01	6.08	6.05	77.6	78.2	77.9	32.9	32.9	32.9	4.71	4.84	4.84	28	23		
FC2 S			1.0	25.4	25.4	6.75	6.74	6.73	85.7	84.1	86.0	33.0	33.0	33.0	5.61	5.74	5.74	14	15		
FC2 M	08:10	Small wave	17.0	8.5	26.5	6.72	6.69	6.73	86.6	84.7	82.9	32.9	32.9	32.9	4.04	4.14	4.14	4.49	26	26	21.3
FC2 B			16.0	26.5	26.5	6.34	6.41	6.38	83.6	83.6	83.6	33.0	33.0	33.0	3.67	3.71	3.71	23	22		

**Field data with single underline indicates an exceedance to Action Level**  
Data with double underline indicates an exceedance to Limit Level

Equipment used:	Dissolved Oxygen Meter	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:
Turbidity Meter:		EM	2366	Calibration Check: 4.54	45.8	462 NTU Checked By:
Salinity Meter:		EM	3694	Calibration Check: 58.8	msS	Date:
Thermometer:		ET	961			

Project: Contract No. CIV/2020/3 Fil Bank At Tuen Mun Area 32

Date of Sampling: 06/11/2004 Weather Condition: Sunny Client: Petro-Ocean Construction Co., Ltd. Job No.: 4494.1

Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Dissolved Oxygen, %	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Remarks
				a	b	Average	a	b	a	b	Depth Average
FM1 S			1.0	26.2	26.2	7.11	7.04	81.7	82.1	31.7	31.8
FM1 M	17:15	Big wave	18.0	9.0	26.4	7.00	7.11	80.7	81.7	31.7	31.7
FM1 B			17.0	26.3	26.3	6.98	6.94	83.9	79.0	70.4	31.9
FM2 S			1.0	26.1	26.1	6.91	6.72	80.1	81.6	31.8	31.8
FM2 M	17:25	Big wave	18.0	9.0	26.2	5.72	5.71	76.4	76.5	31.9	31.9
FM2 B			17.0	26.4	26.4	5.06	5.11	5.09	70.1	70.4	31.8
FC1 S			1.0	26.4	26.4	7.26	7.27	82.7	83.4	31.7	31.7
FC1 M	17:50	Big wave	23.0	11.5	26.3	7.08	7.01	80.6	83.7	31.7	31.7
FC1 B			22.0	26.4	26.4	6.97	6.86	6.92	79.7	78.4	31.8
FC2 S			1.0	26.2	26.2	7.41	7.46	83.4	84.6	31.7	31.7
FC2 M	17:40	Big wave	18.0	9.0	26.4	7.21	7.26	7.34	82.6	81.4	31.8
FC2 B			17.0	26.5	26.5	7.00	7.01	7.01	80.6	79.5	32.0

**Bold data with single underline** indicates an exceedance to Action Level  
Data with double underline indicates an exceedance to Limit Level

Equipment used	Dissolved Oxygen Meter:	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:	
	Turbidity Meter:	EM	2366	Calibration Check: 4.45 - 45.7	452 NTU	Checked By:	
	Salinity Meter:	EM	3684	Calibration Check: 59.8	mS	Date:	
	Thermometer:	ET	961				

Project Contract No. CWY200213 Fill Bank At Tuan Mun Area 38

Date of Sampling : 06/11/2004

Station	Time	Sea Condition	Overall Sampling Depth, m	Temperature, °C			Dissolved Oxygen, mg/L			Salinity, ppt			Turbidity, NTU			Tide Status	Meteo	Remarks
				a	b	Average	a	b	Average	a	b	Average	a	b	Average			
Fm1 S			1.0	25.4	25.4	25.4	7.60	7.96	7.48	90.2	89.0	88.0	31.6	31.6	31.6	5.41	12	10
Fm1 M	07:55	Small wave	17.0	8.5	25.7	25.7	7.41	7.36	7.45	87.6	87.4	87.4	31.7	31.7	31.7	5.18	5.98	18
Fm1 B			16.0	25.6	25.6	25.6	7.26	7.31	7.29	86.1	85.4	85.8	31.7	31.7	31.7	6.30	17	17
Fm2 S			1.0	26.5	26.5	26.5	7.42	7.62	7.35	80.9	80.6	80.3	32.0	32.0	32.0	6.29	6.31	11
Fm2 M	07:45	Small wave	17.0	8.5	25.4	25.4	7.20	7.17	7.35	85.4	83.1	83.1	32.0	32.0	32.0	5.98	6.01	15
Fm2 B			16.0	25.4	25.4	25.4	7.18	7.07	7.13	82.4	83.1	82.8	32.0	32.0	32.0	7.24	7.36	17
Fc1 S			1.0	26.6	26.6	26.6	7.60	7.14	7.28	80.7	79.8	81.1	31.9	31.9	31.9	6.11	6.21	14
Fc1 M	08:10	Small wave	22.0	11.0	25.7	25.7	7.11	7.36	81.6	82.1	82.1	32.0	32.0	32.0	6.35	6.34	15	
Fc1 B			21.0	25.8	25.8	25.8	7.20	7.18	7.19	84.4	84.3	84.4	32.0	32.0	32.0	7.48	7.49	13
Fc2 S			1.0	26.6	26.6	26.6	6.95	6.91	6.91	80.1	80.4	80.0	31.8	31.8	31.8	6.97	6.96	15
Fc2 M	07:30	Small wave	17.0	8.5	25.7	25.7	6.92	6.86	6.91	79.8	79.8	79.8	31.9	31.9	31.9	5.86	5.87	12
Fc2 B			16.0	25.7	25.7	25.7	6.97	6.99	6.98	79.5	80.1	79.8	31.9	31.9	31.9	6.20	6.27	14

**Bold data with single underline indicates an exceedance in Action Level**  
**Italic data with double underline indicates no exceedance to Limit Level**

Equipment used:

Dissolved Oxygen Meter:	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:
Turbidity Meter:	EM	2306	Calibration Check: 4.00, 45.5,	45.1 NTU	Checked By:
Salinity Meter:	EM	3834	Calibration Check: 58.8 mS		Date:
Thermometer:	ET	961			

Project: Contract No. CW/2002/13 Fill Bank At Tuan Min Area 3B		Date of Sampling: 09/11/2004		Weather Condition: Sunny		Client: Besta Dolan Construction Co., Ltd.		Job No.: 4494.1	
						Ambient Temperature, °C: 26			
Station	Time	Sea Condition	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Dissolved Oxygen, %	Salinity, ‰	Turbidity, NTU	Suspended Solids, mg/L
			a b m	a b m	a b m	a b Average	a b m	a b m	Average
FH1 S			1.0	26.8	26.6	7.41	7.36	7.09	67.9 88.1
FH1 M	16:55	Big wave	18.0	9.0	26.7	26.8	6.88	6.72	77.5 76.1
FH1 B			17.0	26.8	26.9	6.26	6.34	6.30	76.4 75.6
FH2 S			1.0	26.0	26.0	7.17	7.20	6.93	82.1 83.4
FH2 M	16:50	Big wave	20.0	10.0	26.6	26.6	6.77	6.66	76.4 76.9
FH2 B			19.0	26.5	26.5	6.14	6.34	6.24	71.3 72.6
FC1 S			1.0	26.9	26.9	6.95	6.86	6.88	80.4 80.1
FC1 M	17:10	Big wave	17.0	8.5	26.5	6.91	6.81	78.6 79.4	79.6
FC1 B			16.0	26.4	26.4	6.76	6.77	6.77	77.6 77.5
FC2 S			1.0	26.8	26.7	7.21	7.19	7.11	83.4 83.1
FC2 M	16:35	Big wave	18.0	9.0	26.7	26.7	7.04	7.00	80.5 80.6
FC2 B			17.0	26.5	26.5	7.20	7.16	7.10	82.1 81.7

**Bold data with single underline indicates an exceedance in Action Level**  
Basic data with double underline indicates an exceedance to Limit Level

Equipment used:	Dissolved Oxygen Meter	EM	961	Calibration Check	0mg/L ok	100% ok	Sampled By:
							Checked By:
	Turbidity Meter	EM	2366	Calibration Check	4.51, 46.3	458 NTU	Date:
	Salinity Meter	EM	3004	Calibration Check	58.8 msS		
	Thermometer	ET	961				

Project Contract No. CV/2000/013 Fil Blank At Tien Mu Area 3B

Client: Port &amp; Ocean Construction Co., Ltd. Job No.: 4624.1

Date of Sampling	06/11/2004	Weather Condition:		Sunny		Ambient Temperature, °C.		25		Tide State:		Mid-Tide	
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Dissolved Oxygen, %	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Remarks	Depth Average	
FH1 S			1.0	26.1	7.10	7.16	6.95	81.4	82.6	79.3	32.1	32.1	
FH1 M	09:40	Small wave	17.0	8.5	26.4	26.4	5.96	5.97	77.6	75.4	32.0	32.0	
FH1 B			16.0	26.1	6.01	6.11	6.06	70.4	79.4	78.9	32.1	32.1	
FH2 S			1.0	26.2	26.2	7.08	7.11	80.7	80.6	81.3	32.1	32.1	
FH2 M	09:50	Small wave	17.0	8.5	26.3	26.3	7.14	7.15	81.6	82.1	32.1	32.1	
FH2 B			16.0	26.4	26.4	7.29	7.31	84.5	84.7	84.6	32.1	32.1	
FC1 S			1.0	26.4	26.4	7.00	7.01	81.6	80.4	79.5	32.1	32.1	
FC1 M	09:26	Small wave	23.0	11.5	26.3	26.3	5.97	5.96	78.4	77.4	32.0	32.0	
FC1 B			22.0	26.3	5.00	5.01	5.01	70.4	70.3	70.4	32.2	32.2	
FC2 S			1.0	26.4	26.4	7.11	7.30	80.4	81.4	80.4	32.1	32.1	
FC2 M	10:05	Small wave	17.0	8.5	26.4	26.4	7.04	7.00	80.0	79.8	32.2	32.2	
FC2 B			16.0	26.3	6.97	6.86	6.92	79.4	80.7	80.1	32.2	32.2	

**Bold data with single underline indicates an exceedance to Action Level**  
**Italic data with double underline indicates an exceedance to Limit Level**

Equipment used: Dissolved Oxygen Meter: EM 961 Calibration Check: Dmg/L ok 100% ok

Turbidity Meter: EM 2905 Calibration Check: 4.53, 45.4, 463 NTU

Salinity Meter: EM 3694 Calibration Check: 50.0 mS

Thermometer: ET 961

Sampled By:

Checked By:

Date:

Project Contract No. CV2002013 Fil Bank At Tien Man Area		Client Pent-Ocean Construction Co., Ltd.		Job No.	44241						
Date of Sampling :	10/11/2004	Weather Condition:	Cloudy	Ambient Temperature, °C:	29						
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/l	Dissolved Oxygen, mg/l Average	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/l	Remarks
FIM S			1.0	26.1	26.1	6.89	6.98	6.41	83.8	82.1	
FIM M	17:40	Small wave	16.0	9.0	26.4	6.21	6.14	7.76	78.1	80.4	31.0 8.10 8.14
FIM B			17.0	26.0	26.0	6.00	5.97	5.99	75.4	74.7	31.7 12.30 13.60
FM2 S			1.0	26.3	26.3	6.76	6.66	6.51	82.6	83.1	10.06 21 21 22.6
FM2 M	17:30	Small wave	19.0	9.5	26.1	6.34	6.35	79.4	79.5	81.2	31.8 9.01 9.21
FM2 B			18.0	26.4	26.4	6.16	6.21	6.19	76.4	76.9	32.0 8.40 8.51
FC1 S			1.0	26.4	26.4	6.51	6.47	6.39	80.2	81.4	31.7 9.41
FC1 M	17:55	Small wave	23.0	11.5	26.6	6.30	6.26	75.6	75.7	76.2	32.0 11.00 11.90
FC1 B			22.0	26.5	26.5	6.41	6.30	6.35	80.0	80.1	31.7 9.41
FC2 S			1.0	26.5	26.5	6.36	6.47	76.9	77.3	76.2	31.7 7.81 7.61
FC2 M	17:15	Small wave	18.0	9.0	26.6	6.31	6.30	75.7	75.6	76.4	31.0 12.60 14.20
FC2 B			17.0	26.1	26.1	6.10	6.11	6.11	76.0	75.7	31.9 11.70 12.80

Bold data with single underline indicates an exceedance to Action Level  
Data over with double underline indicates an exceedance to Limit Level

Equipment used:	Dissolved Oxygen Meter:	EM	961	Calibration Check:	0mg/L ok	100% ok	Sampled By:
	Turbidity Meter:	EM	2365	Calibration Check:	4.497	45.5	Checked By:
	Salinity Meter:	EM	3694	Calibration Check:	58.8	mS	Date:
	Thermometer:	ET	961				

Project Contract No. CV/2000/3 Fill Bank At Tum Mun Area

Date of Sampling : 10/11/2004

Client: Ports-Ocean Construction Co., Ltd. Job No : 449.1.1

Station	Time	Sea Condition	Weather Condition:			Sampling Temperature, °C			Dissolved Oxygen, mg/L			Salinity, ‰			Turbidity, NTU			Site State	Mn-Ebb	Remarks	
			a	b	Average	a	b	Average	a	b	Average	a	b	Average	a	b	Average				
FMI S			1.0	25.4	25.4	8.16	8.21	8.18	56.4	56.7	56.5	31.6	31.7	31.7	7.58	7.59	7.59	22	22		
FMI M	11:15	Small wave	17.0	8.5	25.2	6.51	6.65	6.58	80.2	81.6	80.9	32.0	32.0	32.0	9.64	9.66	9.66	9.21	25	24	24.5
FMI B			16.0	26.2	26.4	6.21	6.39	6.30	78.6	77.6	78.1	32.6	32.6	32.6	10.70	10.70	10.70	10.10	27	27	
FHQ S			1.0	26.4	26.4	7.96	7.75	7.80	90.4	91.5	91.6	31.7	31.6	31.6	5.53	5.56	5.56	17	17	15	
FHQ M	11:25	Small wave	17.0	8.5	25.4	5.21	5.46	5.30	71.9	72.5	72.1	32.1	32.1	32.1	8.00	7.94	7.94	9.79	22	25	21.8
FHQ B			16.0	25.4	25.4	5.11	5.03	5.07	71.0	70.6	70.8	32.7	32.7	32.7	15.30	15.30	15.30	16.70	25	27	
FC1 S			1.0	26.5	26.5	6.97	7.00	6.97	84.8	83.6	80.0	31.6	31.7	31.7	6.94	6.76	6.76	24	20		
FC1 M	11:00	Small wave	22.0	11.0	26.3	6.01	6.31	6.57	75.4	76.1	75.4	32.2	32.2	32.2	10.50	11.60	10.15	22	20	23.0	
FC1 B			21.0	26.2	26.2	5.71	5.76	5.74	74.9	73.1	74.0	32.4	32.4	32.4	12.40	12.70	12.70	27	25		
FC2 S			1.0	25.4	25.4	8.01	8.20	8.01	95.4	94.2	95.5	31.8	31.7	31.7	5.82	5.82	5.82	23	22		
FC2 M	11:40	Small wave	17.0	8.5	26.3	5.71	5.82	6.94	75.6	76.9	76.5	31.9	31.9	31.9	9.32	9.16	9.16	10.06	19	20	22.5
FC2 B			16.0	26.3	26.3	5.31	5.40	5.36	72.7	73.1	72.9	32.0	32.0	32.0	15.10	15.10	15.10	26	25		

Field data with single underline indicates an exceedance to Action Level  
Data with double underline indicates an exceedance to Limit Level

Equipment used:	Dissolved Oxygen Meter	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:
Turbidity Meter:		EM	2366	Calibration Check: 4.56, 45.6,	456 NTU	Checked By:
Salinity Meter:		EM	3694	Calibration Check: 58.7	58.7 mS	Date:
Thermometer:		ET	961			

Project Contract No: CW/2000/13 Fill Bank At Tuen Mun Area 38						Client: Penta-Ocean Construction Co., Ltd. Job No.: 4494.1					
Date of Sampling: 12/11/2004			Weather Condition: Sunny			Ambient Temperature, °C: 29			Tide State: Mid/Flood		
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Dissolved Oxygen, %	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Remarks
FMI S			1.0	25.7	25.7	8.41	8.45	8.30	98.7	98.4	
FMI M	19:00	Small wave	9.0	25.6	25.6	8.14	8.21	99.1	96.5	90.2	32.0 6.68 6.75 18 20
FMI B			17.0	25.9	25.9	7.56	7.57	7.62	88.8	88.1	31.9 5.50 6.66 6.82 11 12 15.3
FNQ S			1.0	25.5	25.5	7.81	7.76	7.62	91.7	92.6	91.0 31.9 4.91 4.82 14 15
FNQ M	18:50	Small wave	9.5	25.6	25.6	7.52	7.40	90.1	89.6	90.9	31.7 5.39 5.37 5.85 14 15 15.3
FNQ B			18.0	25.9	25.9	7.34	7.37	7.36	84.5	84.6	84.6 31.9 7.21 7.40 16 18
FC1 S			1.0	25.9	25.9	7.51	7.62	7.56	90.5	89.8	90.9 31.8 5.61 5.75 16 18
FC1 M	19:20	Small wave	11.5	25.5	25.5	7.61	7.47	91.7	91.7	91.7	31.9 5.97 6.86 6.50 15 15 15.3
FC1 B			22.0	25.4	25.4	6.31	6.48	6.40	75.6	74.7	75.2 31.9 6.78 6.99 17 17
FC2 S			1.0	25.7	25.7	7.47	7.36	7.38	88.6	88.6	88.6 31.8 5.54 5.61 13 13
FC2 M	18:35	Small wave	9.0	25.7	25.7	7.30	7.39	83.1	82.5	86.0	31.9 5.62 6.73 6.51 13 13 13.8
FC2 B			17.0	25.4	25.4	5.71	5.86	5.79	75.6	74.3	75.0 31.9 7.09 7.20 15 15

**Bold data with single underline indicates an exceedance to Action Level**  
**italic data with double underline indicates an exceedance to Limit Level**

Equipment used:	Dissolved Oxygen Meter:	EM 951	Calibration Check: 0mg/L ok	100% ok	Sampled By:
	Turbidity Meter:	EM 2355	Calibration Check: 4.52	45.9, 445 NTU	Checked By:
	Salinity Meter:	EM 3694	Calibration Check: 58.8 mS		Date:
	Thermometer:	ET 951			

Project: Contract No. C/2020/013 Fill Bank At Tain Man Area 3B		Client: Pent-Ocean Construction Co., Ltd.		Job No.: 44241	
Date of Sampling:	12/11/2004	Weather Condition:	Sunny	Ambient Temperature, °C:	32
Station	Time	Sea Condition	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L
FMC1S			1.0	27.5	6.81
FMC1M	12:40	Big wave	17.0	8.5	26.9 5.72 5.74
FMC1B			16.0	26.8	5.17 5.24
FMC2S			1.0	27.4	6.81 6.90
FMC2M	12:50	Big wave	17.0	8.5	27.0 5.92 5.86
FMC2B			16.0	27.0	5.67 5.72
FC1C1S			1.0	27.1	7.11 7.20
FC1C1M	12:55	Big wave	22.0	11.0	26.8 5.21 5.16
FC1C1B			21.0	26.7	6.20 6.34
FC2C2S			1.0	26.0	6.89 7.09
FC2C2M	13:05	Big wave	17.0	8.5	26.9 5.86 5.75
FC2C2B			16.0	26.9	5.70 5.64
<b>Bold data with single underline indicates an exceedance to Action Level</b>					
<b>italic data with double underline indicates an exceedance to Limit Level</b>					
Dissolved Oxygen Meter:	EM	901	Calibration Check: 0mg/L ok		
Turbidity Meter:	EM	2365	Calibration Check: 450, 453, 447 NTU		
Salinity Meter:	EM	3894	Calibration Check: 50.7 mS		
Thermometer:	ET	961			
Sampled By:			Checked By:		
Date:					

**Solid data with single underline** indicates an exceedance in Action Level.

Project Contract No. CIV20020213 Fill Bank At Tuen Mun Area 38

Date of Sampling : 15/11/2004 Weather Condition: Cloudy Client: Benle-Ocean Construction Co.,Ltd. Job No.: 4434 1

Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Dissolved Oxygen, %	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Remarks
			a	b	a	Average	a	b	a	Average	Depth Average
FH1 S			1.0	26.2	26.2	7.01	7.11	90.4	99.0	11.50	20 30
FH1 M	09:55	Small wave	8.5	25.9	25.8	6.74	6.78	92.4	92.1	30.2	10.10 24
FH1 B			16.0	25.7	25.7	6.58	6.60	6.58	89.7	90.0	11.65 26.3
FH2 S			1.0	26.0	26.1	6.94	6.90	96.2	94.9	30.4	12.60 23
FH2 M	09:40	Small wave	8.5	25.9	25.0	6.75	6.77	92.1	92.2	30.3	13.80 22
FH2 B			16.0	25.6	25.7	6.80	6.82	6.84	90.9	90.0	14.90 23
FC1 S			1.0	26.0	26.0	6.78	6.74	92.3	92.6	30.3	11.30 24
FC1 M	10:05	Small wave	10.5	26.0	26.0	7.01	7.09	98.5	98.1	30.3	8.92 21
FC1 B			20.0	25.9	26.0	7.11	7.13	7.12	99.7	99.6	10.50 23.8
FC2 S			1.0	26.1	26.1	6.94	6.86	92.9	93.3	30.1	12.50 20
FC2 M	09:30	Small wave	8.5	25.7	25.8	6.72	6.76	6.79	90.6	90.7	12.62 26
FC2 B			16.0	25.6	25.6	6.63	6.60	6.62	88.8	88.5	12.30 30

**Bold data with single underline indicates an exceedance to Action Level**  
**Data with double underline indicates an exceedance to Limit Level**

Equipment used:

Dissolved Oxygen Meter:	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:
Turbidity Meter:	EM	2366	Calibration Check: 4.62	45.0	462 NTU Checked By:
Salinity Meter:	EM	3634	Calibration Check: 59.8	mS	Date:
Thermometer:	ET	961			

Project Contract No. Cxv/2002/H3 Fil Bank At Tien Mun Area 38

Date of Sampling : 15/11/2004

Client: Pante-Ocean Construction Co., Ltd. Job No: 4424.1

Weather Condition: Cloudy

Ambient Temperature, °C: 26

Sampling Temperature, °C: 27.1

Dissolved Oxygen, mg/l: 99.2

Salinity, ppt: 30.1

Turbidity, NTU: 10.40

Suspended Solids, mg/L: 33

Depth, m: 0.99

Average: 30.1

b: 10.40

Remarks: 33

Overall Depth, m: 1.0

a: 27.2

b: 0.99

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Sampling Depth, m: 16.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Overall Depth, m: 17.0

a: 9.0

b: 26.6

Average: 27.1

3: 99.2

b: 0.99

Remarks: 33

Project Contract No: CW/2000/13 Fill Bank At Tuen Mun Area 38						Client: Penta-Ocean Construction Co., Ltd. Job No.: 4494.1						
Date of Sampling:			Weather Condition:			Sampling Details:			Ambient Temperature, °C:			
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Average	Dissolved Oxygen, %	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Remarks
FNI S			1.0	24.9	24.9	6.02	6.04	6.56	75.4	76.9	61.2	31.4
FNI M	12:05	Small wave	9.0	25.0	25.0	7.05	7.09	85.7	86.7	31.6	5.43	5.42
FNI B			17.0	24.7	24.7	6.76	6.95	6.81	82.7	81.1	81.9	32.6
FNQ S			1.0	24.7	24.7	6.14	6.25	6.31	75.7	76.4	78.0	31.5
FNQ M	11:55	Small wave	9.0	24.8	24.8	6.36	6.47	79.7	80.1	31.6	8.85	9.93
FNQ B			17.0	24.6	24.6	6.10	6.07	6.09	75.9	73.1	74.5	31.6
FC1 S			1.0	25.1	25.1	7.21	7.17	6.99	87.6	88.9	86.2	31.7
FC1 M	12:15	Small wave	11.5	24.6	24.6	6.86	6.71	83.6	84.7	31.5	5.99	5.97
FC1 B			22.0	24.6	24.6	6.17	6.20	6.19	76.9	77.1	77.0	31.8
FC2 S			1.0	25.0	25.0	6.97	6.76	6.33	84.7	85.6	80.9	31.7
FC2 M	11:35	Small wave	9.0	24.5	24.5	5.71	5.87	75.6	77.8	31.8	11.00	11.50
FC2 B			17.0	24.2	24.2	5.01	5.10	5.06	70.2	71.5	70.9	31.8

**Bold data with single underline indicates an exceedance to Action Level**  
**italic data with double underline indicates an exceedance to Limit Level**

Equipment used: Dissolved Oxygen Meter: EM 951 Calibration Check: 0mg/L ok 100% ok Sampled By:

Turbidity Meter: EM 2365 Calibration Check: 4.52 45.4, 456 NTU Checked By:

Salinity Meter: EM 3694 Calibration Check: 58.7 mS Date:

Thermometer: ET 951

Project: Contract No. CIV/2002/013 Fill Bank At Tuen Mun Area 3B										Client: Faro-Ocean Construction Co., Ltd. Job No.: 4494.1			
Date of Sampling	17/11/2004	Weather Condition			Ambient Temperature, °C			Tide State			Mid-Ebb		
Station	Time	Sea Condition	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Average	Dissolved Oxygen, %	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Depth	Remarks	
FMI S			1.0	26.0	7.69	7.76	90.7	90.2	88.7	31.4	5.30	5.21	
FMI M	16.55	Small wave	17.0	8.5	24.5	7.21	7.30	87.5	86.4	32.7	5.53	5.60	
FMI B			16.0	24.6	24.6	6.85	6.76	82.6	81.7	32.7	5.34	5.53	
FM2 S			1.0	24.7	6.95	6.86	83.5	84.7	85.5	31.5	5.21	4.42	
FM2 M	16.45	Small wave	17.0	8.5	24.8	7.05	7.11	86.6	87.1	32.6	4.96	5.02	
FM2 B			16.0	24.6	24.6	6.86	6.97	5.92	7.7	77.2	77.5	32.8	
FC1 S			1.0	24.7	24.7	6.11	6.21	6.13	76.4	75.0	75.7	32.1	
FC1 M	16.30	Small wave	22.0	11.0	24.6	6.09	6.10	75.4	75.9	76.7	33.0	5.38	
FC1 B			21.0	24.6	24.6	6.20	6.20	76.6	77.9	77.3	30.1	5.76	
FC2 S			1.0	24.7	24.7	7.11	7.10	7.07	88.6	89.4	86.0	31.7	
FC2 M	17.05	Small wave	17.0	8.5	24.5	7.05	7.01	85.0	84.2	31.7	5.10	5.33	
FC2 B			16.0	24.7	24.7	7.00	6.91	6.96	84.3	85.1	84.7	32.0	

*Excluded data with single underscores are excluded to prevent loss of all*

Project Contract No. C012002013 Fill Bank At Tuen Mun Area 38						Client: Benle-Ocean Construction Co., Ltd. Job No.: 4434 1							
Date of Sampling:	19/11/2004	Weather Condition:			Sunny	Ambient Temperature, °C:			28	Tide State:			Mid-Flood
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Average	Dissolved Oxygen, %	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Depth Average	Remarks
FH1 S			1.0	26.7	26.7	7.00	7.01	100.1	100.1	5.23	15	13	
FH1 M	15:00	Small wave	8.5	26.4	26.5	6.84	6.89	94.2	95.0	30.3	30.2	6.18	6.56
FH1 B			16.0	26.0	26.2	6.65	6.60	6.63	65.4	65.0	6.60	13	12
FH2 S			1.0	27.0	27.0	6.72	6.62	6.78	96.5	94.1	30.2	30.3	9.49
FH2 M	14:50	Small wave	8.5	26.4	25.4	6.95	6.94	90.1	89.4	67.5	30.2	30.1	7.74
FH2 B			16.0	26.6	26.7	6.41	6.52	6.47	83.2	84.5	83.9	30.1	21
FC1 S			1.0	26.8	26.8	6.62	6.72	95.3	96.7	30.4	30.3	6.65	8.54
FC1 M	15:15	Small wave	10.5	26.7	26.8	6.94	7.00	98.2	100.0	30.2	30.1	8.07	6.92
FC1 B			20.0	26.4	26.5	6.78	6.84	6.81	90.0	92.3	91.2	30.3	27.79
FC2 S			1.0	26.5	26.5	6.99	6.97	99.7	99.4	30.2	30.3	7.04	6.90
FC2 M	14:35	Small wave	8.5	26.8	26.8	7.01	6.99	6.98	100.0	99.9	99.0	30.4	7.22
FC2 B			16.0	26.4	26.3	6.83	6.83	6.83	92.4	92.5	92.5	30.3	7.48
												17	17.2
												19	19
												21	21

**Bold data with single underline indicates an exceedance to Action Level**  
**Data with double underline indicates an exceedance to Limit Level**

Equipment used:	Dissolved Oxygen Meter:	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:	
	Turbidity Meter:	EM	2366	Calibration Check: 4.63	45.6	Checked By:	
	Salinity Meter:	EM	3634	Calibration Check: 59.8	mS	Date:	
	Thermometer:	ET	961				



Project Contract No: CW/2000/13 Fill Bank At Tuen Mun Area 38						Client: Penta-Ocean Construction Co., Ltd. Job No.: 4494.1					
Date of Sampling: 22/11/2004			Weather Condition: Sunny			Ambient Temperature, °C: 27			Tide State: Mid/Flood		
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Dissolved Oxygen, %	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Remarks
FNI S			1.0	25.4	25.4	6.84	6.95	6.76	97.3	5.41	
FNI M	16:45	Small wave	8.5	26.1	26.1	6.65	6.57	89.9	90.1	30.2	
FNI B			16.0	25.8	25.8	6.60	6.52	6.51	88.3	88.4	
FNQ S			1.0	25.3	25.4	6.74	6.95	6.74	93.2	95.6	
FNQ M	16:30	Small wave	9.0	26.0	26.1	6.65	6.72	90.0	91.3	30.2	
FNQ B			17.0	25.7	25.9	6.60	6.70	6.65	89.9	91.2	
FC1 S			1.0	25.3	25.3	6.68	6.72	6.66	90.6	90.6	
FC1 M	16:55	Small wave	11.0	26.0	26.1	6.60	6.55	90.1	90.9	30.4	
FC1 B			21.0	26.3	26.0	6.59	6.54	6.52	89.8	90.8	
FC2 S			1.0	25.4	25.4	6.98	6.99	6.89	98.7	99.5	
FC2 M	16:20	Small wave	8.5	26.1	26.1	6.72	6.85	94.5	96.0	30.3	
FC2 B			16.0	25.9	26.0	6.64	6.72	6.68	91.4	92.1	

**Bold data with single underline indicates an exceedance to Action Level**  
**italic data with double underline indicates an exceedance to Limit Level**

Equipment used:	Dissolved Oxygen Meter:	EM 951	Calibration Check: 0mg/L ok	100% ok	Sampled By:
	Turbidity Meter:	EM 2355	Calibration Check: 4.61	4.63 NTU	Checked By:
	Salinity Meter:	EM 3694	Calibration Check: 58.7 mS		Date:
	Thermometer:	ET 951			

Project Contract No. CV/2000/3 Fill Bank At Tum Mun Area

Date of Sampling : 22/11/2004

Client: Ports-Ocean Construction Co., Ltd. Job No : 449.1.1

Station	Time	Sea Condition	Weather Condition:			Sampling Temperature, °C			Dissolved Oxygen, mg/L			Salinity, ‰			Turbidity, NTU			Title State	Site Elevation	Remarks
			a	b	Average	a	b	Average	a	b	Average	a	b	Average	a	b	Average			
FMI S			1.0	25.7	25.7	6.98	6.98	6.98	98.4	98.5	98.5	30.2	30.3	30.3	6.34	6.34	6.34	13	14	
FMI M	09:40	Small wave	17.0	8.5	25.4	25.3	6.74	6.70	90.5	90.9	90.9	30.3	30.4	30.4	6.71	6.70	6.70	14.9	14	13
FMI B			16.0	26.2	26.2	6.70	6.64	6.67	89.4	88.2	88.2	30.2	30.1	30.1	6.70	6.69	6.69	14.9	14	13
FHQ S			1.0	25.6	25.6	6.95	6.80	6.79	94.8	94.0	94.0	30.4	30.0	30.0	4.80	4.76	4.76	11	13	
FHQ M	09:55	Small wave	17.0	8.5	25.5	25.6	6.74	6.75	90.4	90.6	90.6	30.3	30.1	30.1	5.90	6.39	6.04	15	16	14.8
FHQ B			16.0	25.3	25.4	6.71	6.74	6.73	90.0	90.5	90.3	30.2	30.3	30.3	7.42	6.94	6.94	16	18	
FC1 S			1.0	25.6	25.6	6.99	6.97	6.89	99.8	99.6	99.6	30.1	30.2	30.2	5.22	4.46	4.46	13	14	
FC1 M	09:30	Small wave	22.0	11.0	25.6	25.6	6.80	6.78	93.2	93.0	93.0	30.2	30.3	30.3	6.24	6.22	6.22	5.74	18	16.2
FC1 B			21.0	25.5	25.5	6.90	6.89	6.90	96.7	96.7	96.7	30.4	30.1	30.1	6.14	6.17	6.17	17	17	
FC2 S			1.0	25.8	25.9	6.83	6.84	6.84	98.6	98.6	98.6	30.2	30.2	30.2	13.20	14.50	14.50	26	27	
FC2 M	10:05	Small wave	17.0	8.5	25.6	25.6	6.64	6.65	96.3	96.3	96.3	30.2	30.4	30.4	11.30	12.30	13.36	27	30	27.0
FC2 B			16.0	25.5	25.5	6.93	6.60	6.59	86.1	86.2	86.2	30.4	30.3	30.3	14.50	14.30	14.30	28	24	

Field data with single underline indicates an exceedance to Action Level  
Data with double underline indicates an exceedance to Limit Level

Equipment used:	Dissolved Oxygen Meter	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:
Turbidity Meter:		EM	2366	Calibration Check: 4.50, 453,	452 NTU	Checked By:
Salinity Meter:		EM	3694	Calibration Check: 58.7	58.7 mS	Date:
Thermometer:		ET	961			

Project Contract No. CV2020013 Fil Bank At Tien Man Area		Client: Pent-Ocean Construction Co., Ltd.		Job No.	44241						
Date of Sampling:	24/11/2014	Weather Condition:	Cloudy	Tide State:	Mid-Flood						
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Dissolved Oxygen, mg/L Average	Salinity, ppt	Turbidity, NTU	Suspended Solids, mg/L	Remarks
FMI S			1.0	25.6	25.6	7.51	7.62	82.9	81.7	31.5	20.50
FMI M	17:15	Big wave	16.0	9.0	25.7	25.7	7.47	7.54	82.2	31.8	16.60
FMI B			17.0	25.6	25.6	7.34	7.31	7.33	80.7	31.9	19.17
FMI S			1.0	25.4	25.4	7.80	7.79	7.75	84.5	32.0	11.50
FMI M	17:30	Big wave	18.0	9.0	25.5	25.5	7.71	7.69	83.5	32.4	13.10
FMI B			17.0	25.6	25.6	7.86	7.84	7.85	82.1	31.9	12.70
FC1 S			1.0	25.6	25.6	6.71	6.69	6.65	82.6	31.9	19.50
FC1 M	17:05	Big wave	24.0	12.0	26.4	6.51	6.30	6.06	80.0	32.0	21.40
FC1 B			23.0	25.4	25.4	6.62	6.70	6.66	79.7	32.1	19.10
FC2 S			1.0	25.6	25.6	8.01	8.11	91.0	90.7	32.1	14.00
FC2 M	17:45	Big wave	18.0	9.0	25.6	25.6	7.89	7.72	85.7	32.6	18.10
FC2 B			17.0	25.7	25.7	7.61	7.60	7.61	82.6	32.9	17.70

Bold data with single underline indicates an exceedance to Action Level  
Data over with double underline indicates an exceedance to Limit Level

Equipment used:	Dissolved Oxygen Meter:	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:
	Turbidity Meter:	EM	2365	Calibration Check: 4.55, 45.9	453 NTU	Checked By:
	Salinity Meter:	EM	3694	Calibration Check: 50.8	mS	Date:
	Thermometer:	ET	961			

Project: Contract No. Cxv2002H3 Fil Bank At Tien Mun Area 3B

Date of Sampling : 24/11/2004

Client: Pante-Ocean Construction Co., Ltd. Job No: 44241

Station	Time	Sea Condition	Sampling Depth, m			Temperature, °C			Dissolved Oxygen, mg/l			Salinity, ppt			Turbidity, NTU			Tide State:	Meteo:	Remarks
			a	b	a	b	Average	a	b	Average	a	b	Average	a	b	Average	Depth Average			
FMI S			1.0	25.8	25.7	7.80	7.82	7.76	87.0	86.7	86.6	32.5	32.6	7.43	7.52	17	16			
FMI M	11:45	Small wave	17.0	8.5	26.0	7.69	7.73	83.9	84.8	84.6	32.5	32.5	7.58	7.68	7.41	20	17	18.0		
FMI B			16.0	24.5	24.4	7.66	7.64	7.65	80.7	79.8	79.8	32.9	32.9	6.68	7.19	18	20			
FM2 S			1.0	22.1	22.1	6.16	6.32	6.27	78.1	80.6	77.2	32.6	32.6	5.63	5.47	14	12			
FM2 M	11:35	Small wave	17.0	8.5	22.2	22.1	6.21	6.40	74.0	76.1	74.0	32.7	32.7	8.53	9.16	7.77	25	29	21.5	
FM2 B			16.0	22.2	22.3	6.34	6.37	6.36	72.2	74.6	73.4	32.9	32.9	9.20	9.63	26	23			
FC1 S			1.0	30.2	30.1	8.13	8.14	8.00	91.1	91.0	90.3	32.6	32.6	6.03	6.30	19	17			
FC1 M	11:06	Small wave	22.0	11.0	26.4	7.06	7.06	89.3	89.7	89.7	32.6	32.6	7.68	8.01	7.99	19	17	19.3		
FC1 B			21.0	26.0	25.9	7.81	7.80	7.81	76.7	77.0	76.9	32.7	32.7	9.90	9.99	21	23			
FC2 S			1.0	22.6	22.6	6.71	6.72	6.62	84.1	84.4	82.7	32.6	32.6	8.49	8.66	19	20			
FC2 M	11:20	Small wave	17.0	8.5	22.6	6.52	6.51	81.1	81.0	81.0	32.7	32.7	9.50	9.00	9.41	20	23	19.5		
FC2 B			16.0	22.7	22.7	6.71	6.70	6.71	86.5	86.5	86.5	32.8	32.8	10.20	10.70	17	18			

**Bold data with single underline indicates an exceedance to Action Level**  
**Data with double underline indicates an exceedance to Limit Level**

Equipment used	Described Oxygen Meter:	EM	961	Calibration Check:	0mg/L ok	100% ok	Sampled By:
Turbidity Meter:		EM	2365	Calibration Check:	4.54, 46.1,	454 NTU	Checked By:
Salinity Meter:		EM	3094	Calibration Check:	58.7	mS	Date:
Thermometer:		ET	961				

Project Contract No. CIV/20013/Fil Bank At Tien Mun Area 3B		Client: Beta-Ocean Construction Co., Ltd. Job No.: 4694.1	
Date of Sampling:	26/11/2004	Weather Condition:	Cloudy
Station	Time	Sea Condition	Ambient Temperature, °C:
FMI 3	07:25	Small wave	27
FMI 4	07:25	Small wave	27
FMI 5	07:25	Small wave	27
FMO 2 S	07:15	Small wave	27
FMO 2 M	07:15	Small wave	27
FMO 2 B	07:15	Small wave	27
FFC 1 S	07:45	Small wave	27
FFC 1 M	07:45	Small wave	27
FFC 1 B	07:45	Small wave	27
FFC 2 S	07:00	Small wave	27
FFC 2 M	07:00	Small wave	27
FFC 2 B	07:00	Small wave	27
<u>Field data with single underline indicates an exceedance to Action Level</u>			
Data clear with double underline indicates an exceedance to Limit Level			
Equipment used	Dissolved Oxygen Meter:	EM 961	Calibration Check: 0mg/L ok 100% ok
	Turbidity Meter:	EM 2365	Calibration Check: 4.4B - 45.3 NTU
	Salinity Meter:	EM 3894	Calibration Check: 50.7 mS
	Thermometer:	ET 561	
			Sampled By:
			Checked By:
			Date:

**Table 1** Wind data with single underline indicates an exceedance to Action Level  
Double underline indicates an exceedance to Land Level

Project: Contract No. CV/2002/3 Fill Bank At Tuan Mun Area 38

Date of Sampling : 26/11/2004

Client: Perma-Ocean Construction Co., Ltd. Job No : 4494.1

Station	Time	Sea Condition	Weather Condition:			Sampling Temperature, °C			Dissolved Oxygen, mg/L			Salinity, ‰			Turbidity, NTU			Tide State			Site-Ebb		
			a	b	Average	a	b	Average	a	b	Average	a	b	Average	a	b	Average	a	b	Average	Remarks		
FMI S			1.0	23.9	23.9	7.60	7.59	7.59	50.2	50.9	50.9	31.7	31.7	31.7	6.49	6.54	6.54	18	20				
FMI M	12:45	Small wave	17.0	8.5	23.7	7.11	7.08	7.36	86.4	86.7	86.7	33.0	33.0	33.0	0.33	0.33	0.33	0.45	0.00	0.00	18	15	18.5
FMI B			16.0	23.6	23.6	7.09	7.01	7.06	84.1	83.7	83.7	32.9	32.9	32.9	9.09	9.11	9.11				20	20	
FHQ S			1.0	24.0	24.0	7.72	7.69	7.62	93.1	92.7	92.7	31.8	31.8	31.8	7.13	7.16	7.16				17	18	
FHQ M	12:55	Small wave	17.0	8.5	23.7	7.55	7.51	7.62	92.0	90.1	90.1	32.9	33.0	33.0	7.99	8.05	8.05	8.34	15	14	16.0		
FHQ B			16.0	23.5	23.5	7.49	7.32	7.41	90.4	89.7	89.7	33.1	33.1	33.1	9.02	9.07	9.07				15	17	
FC1 S			1.0	23.7	23.7	6.10	6.07	6.13	76.4	77.6	77.6	32.7	32.7	32.7	8.61	8.54	8.54				18	20	
FC1 M	12:30	Small wave	22.0	11.0	23.6	6.21	6.14	6.14	77.6	77.4	77.4	32.9	32.9	32.9	8.35	8.46	8.46	8.55	21	19	19.2		
FC1 B			21.0	23.5	23.5	6.36	6.57	6.47	78.9	75.6	77.3	32.9	32.9	32.9	8.66	8.66	8.66				20	17	
FC2 S			1.0	23.7	23.7	7.14	7.05	7.08	86.4	87.7	87.7	32.6	32.6	32.6	8.62	8.57	8.57				16	16	
FC2 M	13:10	Small wave	17.0	8.5	23.4	7.01	7.10	7.08	83.1	82.6	86.0	32.7	32.7	32.7	9.48	9.41	9.41	9.30	19	18	17.5		
FC2 B			16.0	23.4	23.4	6.99	6.87	6.93	82.7	81.4	82.1	32.8	32.8	32.8	9.96	9.78	9.78				19	17	

Field data with single underline indicates an exceedance to Action Level  
Underline with double underline indicates an exceedance to Limit Level

Equipment used:	Dissolved Oxygen Meter	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:
Turbidity Meter:	EM	2395	Calibration Check: 4.53	45.8.	449 NTU	Checked By:
Salinity Meter:	EM	3694	Calibration Check: 59.8	mS		Date:
Thermometer:	ET	961				

Project: Contract No. CIV/2020/3 Fil Bank At Tuen Mun Area 32

Date of Sampling	29/11/2004	Weather Condition	Sunny	Ambient Temperature, °C.	24	Tide State:	Mid-Flood
Client	Penta-Ocean Construction Co., Ltd.	Job No.:	4494.1				
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C	Dissolved Oxygen, mg/L	Salinity, ppt
			3	b	a	b	a
FM1 S	09:55	Small wave	1.0	26.9	26.8	7.23	7.14
FM1 M	09:55	Small wave	17.0	8.5	26.7	7.00	6.92
FM1 B	09:55	Small wave	16.0	26.4	26.4	6.71	6.70
FM2 S	09:45	Small wave	1.0	26.0	25.8	6.99	6.92
FM2 M	09:45	Small wave	17.0	8.5	25.7	25.8	6.82
FM2 B	09:45	Small wave	16.0	25.3	25.2	6.71	6.74
FC1 S	10:10	Small wave	1.0	25.6	25.6	6.82	6.86
FC1 M	10:10	Small wave	22.0	11.0	25.7	6.80	6.73
FC1 B	10:10	Small wave	21.0	25.5	25.5	6.74	6.65
FC2 S	09:30	Small wave	1.0	25.8	25.9	6.93	6.96
FC2 M	09:30	Small wave	17.0	8.5	25.7	25.8	6.89
FC2 B	09:30	Small wave	16.0	25.6	25.6	6.77	6.70

**Bold data with single underline** indicates an exceedance to Action Level  
Underlined data with double underline indicates an exceedance to Limit Level

Equipment used	Dissolved Oxygen Meter	EM	961	Calibration Check: 0mg/L ok	100% ok	Sampled By:	
	Turbidity Meter	EM	2366	Calibration Check: 4.62, 45.4,	4.67 NTU	Checked By:	
	Salinity Meter	EM	3694	Calibration Check: 59.8	mS	Date:	
	Thermometer	ET	961				

Project: Contract No. CV/2002/13 Fil Bank At Tum Mun Area 38			Client: Berth-Ocean Construction Co., Ltd. Job No.: 4434.1		
Date of Sampling:	29/11/2004	Weather Condition:	Sunny	Ambient Temperature, °C:	26
Station	Time	Sea Condition	Overall Depth, m	Sampling Depth, m	Temperature, °C
FH1 S			1.0	26.4	26.4
FH1 M	14:45	Small wave	17.0	8.5	25.8
FH1 B			16.0	25.5	25.6
FH2 S			1.0	25.3	25.2
FH2 M	14:55	Small wave	17.0	8.5	26.0
FH2 B			16.0	25.8	25.9
FC1 S			1.0	26.2	26.2
FC1 M	14:30	Small wave	22.0	11.0	26.1
FC1 B			21.0	26.1	26.2
FC2 S			1.0	25.9	25.8
FC2 M	15:10	Small wave	17.0	8.5	25.8
FC2 B			16.0	25.7	25.7
					Tide State: Mid-Ebb
					Suspended Solids, mg/L
					Depth Average
					Remarks
Sampling Depth, m			Dissolved Oxygen, mg/L	Dissolved Oxygen, %	Salinity, ppt
			a	b	Average
FH1 S			98.4	94.6	96.4
FH1 M			94.5	94.1	94.3
FH1 B			90.2	90.2	90.2
FH2 S			93.4	98.3	94.2
FH2 M			91.1	94.0	90.1
FH2 B			98.9	92.1	96.5
FC1 S			99.0	92.0	96.3
FC1 M			6.85	6.85	6.85
FC1 B			95.6	94.5	95.0
FC2 S			96.7	96.7	96.3
FC2 M			93.8	93.9	93.8
FC2 B			93.0	90.4	91.7
			a	b	Average
			3	3	3
			NTU	NTU	NTU

Bold data with single underline indicates an exceedance to Action Level  
Data with double underline indicates an exceedance to Limit Level

Equipment used	Dissolved Oxygen Meter:	EM 961	Calibration Check: 0mg/L ok	100% ok	Sampled By:
	Turbidity Meter:	EM 2365	Calibration Check: 451, 452,	461 NTU	Checked By:
	Salinity Meter:	EM 3694	Calibration Check: 58.8	mS	Date:
	Thermometer:	ET 961			

**Appendix VII**

**Complaint Log**

<b>CONTRACT No. CV/2002/13 – FILL BANK AT TUEN MUN AREA 38 - ENVIRONMENTAL COMPLAINTS LOG.</b>						
Complaint Log No.	Date of Receipt	Received From and Received By	Nature of Complaint	Date Investigated	Outcome	Date of Reply and to Whom
001	07.02.2004	From: Public By: Home Affairs Department	Cleanliness of public roads.	N/A	The situation was rectified.	N/A
002	29.06.2004	From: Public By: EPD	Dust generation in Fill Bank.	N/A	The situation was rectified.	N/A
003	31.07.2004	From: Public By: EPD	Dust generation at Lung Mun Road near Fill Bank.	07.08.2004	The situation was rectified.	N/A
004	13.08.2004	From: Public By: EPD	Dust emission within the site.	18.08.2004	The situation was rectified.	N/A
005	26.08.2004	From: Public By: EPD	Dust emission and debris leakage from dump trucks near Government Depot.	07.09.2004	Not site related.	N/A
-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-
-	-	-	-	-	-	-

## **Appendix VIII**

### **Cumulative Statistics on Complaints, Notifications of Summons and Successful Prosecutions**

**CONTRACT No. CV/2002/13 – FILL BANK AT TUEN MUN AREA 38****Cumulative Statistics on Complaints**

Environmental Parameters	Cumulative No. Brought Forward	No. of Complaints This Month	Cumulative Number to Date
Air	4	---	4
Noise	0	---	0
Water	0	---	0
Waste	1	---	1
Landscape & Visual	0	---	0
Total	0	---	5

**Appendix IX**  
**Master Construction Programme**

**Three month rolling programme (Mar 2004 - May 2004)**

Prepared by [Redacted] (Name No.)  
Reviewed by [Redacted]  
Approved by [Redacted] (Name No.)  
[Redacted] (Name No.)  
[Redacted] (Name No.)

ID	Task Name	Start Date	End Date	Early Finish	% Complete	Min. Due	Max Due	Step Due	Plan Due	Act. Due	Prog.	Spec.	Cust.
1	Commissioning Contract	03/03/04	03/03/04	03/03/04	100%	03/03/04	03/03/04						
2	Contract Completion	04/03/04	05/03/04	05/03/04	0%								
3	Completion of Section 1	04/03/04	04/03/04	03/03/04	70%								
4	Completion of Section 2	04/03/04	05/03/04	05/03/04	34%								
5	Handover of Portion E and F	04/03/04	04/03/04	03/03/04	100%								
6	Handover of Portion G	04/03/04	05/03/04	03/03/04	100%								
7	Handover of Portion D	04/03/04	04/03/04	03/03/04	100%								
8	Handover of Portion C	04/03/04	05/03/04	03/03/04	100%								
9	Handover of Portion H	04/03/04	03/03/04	03/03/04	100%								
10	Handover of Portion I	04/03/04	03/03/04	03/03/04	100%								
11	Handover of Portion J	04/03/04	05/03/04	03/03/04	100%								

Contract No. CIV/2003/17  
Pf Bank of Tuon Mai Area 30  
Date 1 March 2004

Related to Progress [Redacted]  
Closed Pd [Redacted]  
Submitted Pd for Each Location [Redacted]

Summary  
Billed Up To [Redacted]  
Billed Up Work [Redacted]

Page 1

Three units of aging in humans (Welti et al., 2004 - Welti, 2004)

Journal No. 07000013  
Post Bank of Taiwan  
Date: 1 March 2004

PUBLICATIONS RECEIVED


1

SOCIAL PREFERENCES


111

100

11



**Three month rolling programme (Mac 2004 - May 2004)**



Contact No: 01903 077313  
P.O. Box 100, Tayside Main House, 34  
Date: 1 May 2004


Summary  
Report  
Report Up Task  
Report Up Task  
Report Up Task

Initiated Progress  
Completed  
Initial PPN in Task Section

304  
Page 4

| These months milling programme (Mar 2024 - May 2024)

ID	Task Name	Start Date	Early Start	Early Finish	% Complete
45	W&H Quality Standard	03/03/24	03/03/24	03/03/24	20%
46	All Quality Systems Marketing	14/3	03/03/25	03/03/25	100%
47	All Quality Unitario	7/3/24	03/03/25	03/03/25	45%
48	Environment (EHS)	7/3/24	03/03/25	03/03/25	20%
49	Section 1 of the Works	09/3/24	03/03/25	03/03/25	100%
50	Create procurement programme for the latest systems and technology Contractor selection and end of sales (PSC) converted from incoterms base	16/3	03/03/25	03/03/25	100%
51	Takeover of existing data and transfer systems Consideration of re-allocating funds into a CHIO	16/3	03/03/25	03/03/25	100%
52	Intake of new systems in the SPCD Contractor profile (CHIO)	16	20/3/24	20/3/24	100%
53	Contractor profile (CHIO)	16	03/03/24	03/03/24	100%



Contract No. CH12345678  
File Number (Per Man Area No)  
Date: 1 March 2024

Task  
Progress  
Milestone  
Rate of Advance

Hold Up Progress  
Delayed Task  
Takeover with no live section

Page 5

Three month reading programme (Year 2004 - Start 2004)

ID	Task Name and task office (ERCC)	Duration of project	Start	Early Start	Early Finish	% Complete	2005			2004		
							Mar	Apr	May	Jun	Jul	Dec
63	New construction office and arch office (ERCC)	75d	03/01/00	03/01/00	03/01/00	100%						
67	Demolition of existing blocks	7d	03/01/00	03/08/00	03/08/00	100%						
68	Construction of foundation	25d	03/01/01	03/16/01	03/16/01	100%						
69	Excavation of foundation excavation	10d	03/17/01	03/27/01	03/27/01	100%						
70	Foundation backfill hydro test in line (ERCC)	10d	03/28/01	04/11/01	04/11/01	100%						
71	Construction of the new ERCC	10d	04/12/01	04/22/01	04/22/01	100%						
72	New bridge design	2d	04/23/01	04/25/01	04/25/01	100%						
73	Training event of new bridge and incident logbook	1d	05/01/01	05/01/01	05/01/01	100%						
74	Completion of new relationship	1d	05/01/01	05/01/01	05/01/01	100%						
75	Preparation of AP4	65d	03/31/02	09/11/02	09/11/02	100%						
76	Rehearsal	17d	03/31/02	04/17/02	04/17/02	100%						

Contact ref: 1400000012  
4th Davis Al Turner Main Street 201  
Date: 1 March 2004

<b>Software</b>	<b>Project Up To Date</b>	<b>Project Up To Standard</b>	<b>Project Up To Specification</b>
<b>Hardware</b>	<b>Project Up To Date</b>	<b>Project Up To Standard</b>	<b>Project Up To Specification</b>

Page 8

Scallop  
Lobster  
Shrimp  
Crab  
Clams  
Mussels  
Oysters  
Squid  
Octopus  
Caviar  
Trout  
Salmon  
Tuna  
Mackerel  
Sardines  
Herring  
Mackerel  
Sardines  
Herring

Three month rolling programme (Star 2004 - May 2004)

Task Name	Duration	Start Date	End Date	% Complete
T1 Fractional weightings	1d	05/01/04	05/02/04	100%
T2 Fractional weights	1d	05/01/04	05/02/04	100%
T3 Fractional weights	1d	05/01/04	05/02/04	100%
T4 Fractional weights	1d	05/01/04	05/02/04	100%
T5 Total weight to be won in the second hand	1d	05/01/04	05/02/04	100%
T6 Total weight to be won in the second hand	1d	05/01/04	05/02/04	100%
T7 Total weight to be won in the second hand	1d	05/01/04	05/02/04	100%
T8 Total weight to be won in the second hand	1d	05/01/04	05/02/04	100%
T9 Total weight to be won in the second hand	1d	05/01/04	05/02/04	100%
T10 Total weight to be won in the second hand	1d	05/01/04	05/02/04	100%
T11 Total weight to be won in the second hand	1d	05/01/04	05/02/04	100%
T12 Two days of Puzzles A	1d	05/01/04	05/02/04	100%
T13 Three days of Puzzles C	1d	05/01/04	05/02/04	100%
T14 Three days of Puzzles H	1d	05/01/04	05/02/04	100%
T15 Three days of Puzzles I	1d	05/01/04	05/02/04	100%
T16 Section 2 of the Walk	1d	05/01/04	05/02/04	100%
T17 Examination of Past & Future Capitalization	1d	05/01/04	05/02/04	100%

Carrie No: GY00020213  
Title at: Tuan Mun Anh 30  
Date: 1 March 2014

Worship  
Prayer Book  
Eucharist  
Meditation

Critical Path

Haus 1

四

11

1

11

Three month roving programme (Mar 2004 - May 2004)

ID	Task Name/Act.	Duration	Start Month	End Month	% Complete	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
79	Public Works operation between +15.00m to +16.50m OD	34d1	01/03/04	04/03/04	94%								
80	Earthwork	117d	03/03/04	03/05/04	65%								
81	Hydroseeding	81d	04/03/04	04/11/04	61%								
82	Public Works operation between +15.00m to +16.50m OD	34d1	01/03/04	04/03/04	44%								
83	Earthwork	27d4	02/03/04	09/03/04	74%								
84	Drainage at +17.00m OD	81d	04/03/04	04/10/04	74%								
85	Hydroseeding	62d	04/03/04	04/17/04	94%								
86	Public Works operation between +15.00m to +16.50m OD	34d1	01/03/04	04/03/04	74%								
87	Earthwork	24d5	04/03/04	06/03/04	4%								
88	Drainage at +17.00m OD	81d	04/03/04	04/10/04	74%								

Contract No: QJU000213  
File Back at Yuen Ma Wan, Kowloon  
Date: 1 March 2004

Format:  
Initial Up Load  
Initial Up Moderate  
Initial Up Moderate

Setup Up Progress  
Critical Path  
Successor Path to Each Section

Page 3

Three month rolling programme (Mar 2004 - May 2004)

ID	Task Name	Initial Planning	Breakdown	Estimated Delivery Date	% Complete	Start Date	Actual Start Date	SCB * Del.	Plan	Act.	Diff.	Del.
00	Initial Planning	2004-03-23	000001	2004-03-24	0%	2004-03-24	2004-03-24	0%	2004-03-24	2004-03-24	0	On
01	Management of documents	2004-03-25	000001	2004-03-26	0%	2004-03-26	2004-03-26	0%	2004-03-26	2004-03-26	0	On

Review by  
Performance  
Approvals

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004

2004</

The results follow from Theorem 2.04.

11

10

Temp  
Pressure  
Altitude

Introduction

D1-Subj

11

11

1

10

11

1


11

11

11









**Three month rolling programme (Year 2004 - May 2004)**

Role	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Role	100	100	100	100	100	100	100	100	100	100	100	100

Prepared by:  
Shane and  
Aermeddy

2004

2005

2006

2007

2008

2009

2010

2011

2012

2013

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

2024

2025

2026

2027

2028

2029

2030

2031

2032

2033

2034

2035

2036

2037

2038

2039

2040

2041

2042

2043

2044

2045

2046

2047



Contract No. CNT200115  
File Boxed at York Main House 20  
Date : March 2004

Summary  
Rotated Up File  
Rotated Up Minimum

2048

2049

2050

2051

2052

2053

2054

2055

2056

2057

2058

2059

2060

2061

2062

2063

2064

2065

2066

2067

2068

2069

2070

2071

2072

2073

2074

2075

2076

2077

2078

2079

2080

2081

2082

2083

2084

2085

2086

2087

2088

2089

2090

2091

2092

2093

2094

2095

2096

2097

2098

2099

2100

2101

2102

2103

2104

2105

2106

2107

2108

2109

2110

2111

2112

2113

2114

2115

2116

2117

2118

2119

2120

2121

2122

2123

2124

2125

2126

2127

2128

2129

2130

2131

2132

2133

2134

2135

2136

2137

2138

2139

2140

2141

2142

2143

2144

2145

2146

2147

2148

2149

2150

2151

2152

2153

2154

2155

2156

2157

2158

2159

2160

2161

2162

2163

2164

2165

2166

2167

2168

2169

2170

2171

2172

2173

2174

2175

2176

2177

2178

2179

2180

2181

2182

2183

2184

2185

2186

2187

2188

2189

2190

2191

2192

2193

2194

2195

2196

2197

2198

2199

2200

2201

2202

2203

2204

2205

2206

2207

2208

2209

2210

2211

2212

2213

2214

2215

2216

2217

2218

2219

2220

2221

2222

2223

2224

2225

2226

2227

2228

2229

2230

2231

2232

2233

2234

2235

2236

2237

2238

2239

2240

2241

2242

2243

2244

2245

2246

2247

2248

2249

2250

2251

2252

2253

2254

2255

2256

2257

2258

2259

2260

2261

2262

2263

2264

2265

2266

2267

2268

2269



Three month rolling programme (Mar 2004 - May 2004)

Month	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004	2004

Prepared by:  
Reviewed by:  
Approved by:

Contract No.: C00000000000000000000	Date:	Time:	Project:	Summary:	Printed by:
PNB Bank of Tamil Nadu Ltd	2004-03-01	14:57:59	Project 1	Received the Task Completed	Printed by Manager

Page 17



## **Appendix X**

**Monitoring Schedule for the following month**

**Fill Bank at Tuen Mun Area 38**  
**Environmental Monitoring Schedule**  
**December 2004**

Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	
			December 1 1 – hr TSP 24 – hr TSP WQM (Ebb: 15:08) (Flood: 10:46)	Site Inspection	2	3 WQM (Ebb: 07:00) (Flood: 17:33)	4
5	6 1 – hr TSP 24 – hr TSP WQM (Ebb: 08:22) (Flood: 15:21)	7	8 WQM (Ebb: 10:32) (Flood: 16:22)	9 Site Inspection	10	11 WQM (Ebb: 12:18) (Flood: 06:53)	
12 1 – hr TSP 24 – hr TSP WQM (Ebb: 13:55) (Flood: 08:46)	13	14	15 WQM (Ebb: 15:32) (Flood: 10:31)	16 Site Inspection	17 WQM (Ebb: 07:00) (Flood: 12:22)	18 1 – hr TSP 24 – hr TSP	
19 WQM (Ebb: 07:40) (Flood: 14:48)	20	21	22 WQM (Ebb: 09:48) (Flood: 15:51)	23 Site Inspection	24 1 – hr TSP 24 – hr TSP WQM (Ebb: 11:35) (Flood: 16:43)	25	
26 WQM (Ebb: 13:15) (Flood: 08:35)	27	28	29 WQM (Ebb: 14:20) (Flood: 09:41)	30 1 – hr TSP 24 – hr TSP Site Inspection Landscape Audit	31 WQM (Ebb: 15:38) (Flood: 10:48)		

- Notes :    1. 24 –hr TSP (to be monitored once every 6 days) at monitoring locations A1 & A2.  
           2. 1 hour TSP (to be monitored three times every six days when highest level of dust generation expected) at monitoring locations A1 & A2.  
           3. WQM - water quality monitoring three times per week, on mid-flood and mid-ebb tides. Days of monitoring to be separated by at least 36 hours. Monitoring locations FC1, FM1, FM2 & FC2.  
           4. Site inspections to be carried out once per week.  
           5. Auditing of landscape works to be carried out once per month.

**Appendix XI**  
**Wind Speed and Direction Data**

DATE MON	DATE DAY	TIME HR	TIME MIN	WS:AVG M/S	WS:MAX M/S	WD:AVG DEG	WD:SDV DEG
11	2	0	0	4.1	10	18	25
11	2	1	0	3.9	10	17	26
11	2	2	0	2.4	9	298	74
11	2	3	0	2	8	9	63
11	2	4	0	2.8	10	15	38
11	2	5	0	2.7	9	25	38
11	2	6	0	2.9	8	25	29
11	2	7	0	3.4	9	24	28
11	2	8	0	2	8	10	54
11	2	9	0	1	4	12	47
11	2	10	0	1.2	3	180	40
11	2	11	0	1	3	221	43
11	2	12	0	1.5	3	213	32
11	2	13	0	1.4	3	166	39
11	2	14	0	1.7	5	164	41
11	2	15	0	2.8	6	121	23
11	2	16	0	3	6	113	21
11	2	17	0	2.7	5	113	21
11	2	18	0	2.5	5	110	21
11	2	19	0	2.2	5	99	21
11	2	20	0	1.8	4	72	18
11	2	21	0	1.7	4	74	21
11	2	22	0	2.1	5	75	18
11	2	23	0	1.4	4	65	23
11	3	0	0	1.2	4	70	26
11	3	1	0	1.1	3	79	25
11	3	2	0	0.5	2	45	59
11	3	3	0	1	4	53	32
11	3	4	0	1.4	4	75	28
11	3	5	0	1.9	5	77	21
11	3	6	0	2.1	5	76	19
11	3	7	0	2.3	5	77	19
11	3	8	0	2	5	74	24
11	3	9	0	2.1	5	101	21
11	3	10	0	2.6	6	103	21
11	3	11	0	2.7	6	113	22
11	3	12	0	2.8	6	107	23
11	3	13	0	2.8	5	105	21
11	3	14	0	2.9	6	106	22
11	3	15	0	2.7	5	106	21
11	3	16	0	2.9	5	105	19
11	3	17	0	3.2	6	100	18
11	3	18	0	2.9	6	100	19
11	3	19	0	3	6	104	18
11	3	20	0	3	6	96	20
11	3	21	0	2.4	5	86	20
11	3	22	0	2.5	5	78	19
11	3	23	0	2.1	4	71	17
11	8	0	0	2.3	6	81	19
11	8	1	0	2.2	6	80	23
11	8	2	0	1.4	5	72	26
11	8	3	0	1	3	70	35
11	8	4	0	0.9	3	67	43
11	8	5	0	1	4	94	56
11	8	6	0	1.3	4	92	41
11	8	7	0	1.2	4	83	35
11	8	8	0	1.4	4	95	28
11	8	9	0	2.4	6	101	22
11	8	10	0	2.6	6	114	23
11	8	11	0	3	6	115	19
11	8	12	0	3	6	115	20
11	8	13	0	3	6	129	29
11	8	14	0	2.7	7	133	27
11	8	15	0	3	6	116	23
11	8	16	0	2.8	6	113	23
11	8	17	0	3.3	6	109	18
11	8	18	0	3.3	7	112	18
11	8	19	0	3.1	6	108	17
11	8	20	0	2.5	6	106	19
11	8	21	0	2.9	7	106	19
11	8	22	0	3.3	7	104	19
11	8	23	0	3.5	8	106	19
11	9	0	0	3.5	8	94	18
11	9	1	0	1.5	5	84	24
11	9	2	0	1.2	4	75	29
11	9	3	0	1.2	4	77	34
11	9	4	0	1.1	3	76	23
11	9	5	0	1.1	3	75	22

11	9	6	0	1.6	4	79	18
11	9	7	0	2	4	76	17
11	9	8	0	1.8	4	74	22
11	9	9	0	2.7	5	101	17
11	9	10	0	3.3	7	104	17
11	9	11	0	4.2	9	101	16
11	9	12	0	3.7	7	104	17
11	9	13	0	3.5	7	100	19
11	9	14	0	3.5	7	100	18
11	9	15	0	3.3	6	99	19
11	9	16	0	3.1	6	98	17
11	9	17	0	3.3	6	100	15
11	9	18	0	3.4	7	100	15
11	9	19	0	3.3	6	99	15
11	9	20	0	3.1	6	100	15
11	9	21	0	3.1	7	97	16
11	9	22	0	3.1	7	98	17
11	9	23	0	2.9	6	92	20
11	13	0	0	2	6	86	29
11	13	1	0	1.9	5	97	28
11	13	2	0	3.1	6	102	22
11	13	3	0	3.5	8	97	18
11	13	4	0	3.4	8	93	20
11	13	5	0	4.4	11	96	18
11	13	6	0	4.5	9	95	17
11	13	7	0	3.8	8	92	17
11	13	8	0	4.4	9	96	18
11	13	9	0	4.9	9	99	16
11	13	10	0	4.6	9	99	16
11	13	11	0	4	8	102	18
11	13	12	0	3.6	9	113	21
11	13	13	0	2.8	6	113	22
11	13	14	0	2.6	5	105	21
11	13	15	0	2.3	5	106	21
11	13	16	0	2.1	5	138	26
11	13	17	0	1.6	3	132	33
11	13	18	0	1.4	3	97	30
11	13	19	0	1.3	3	71	17
11	13	20	0	1.5	4	74	17
11	13	21	0	1.8	4	66	21
11	13	22	0	2	5	87	16
11	13	23	0	2.1	4	90	17
11	14	0	0	2.3	5	96	17
11	14	1	0	2.3	5	90	19
11	14	2	0	1.9	4	73	20
11	14	3	0	1.8	4	79	19
11	14	4	0	1.5	4	84	20
11	14	5	0	0.4	3	16	48
11	14	6	0	0.1	1	294	28
11	14	7	0	0	0	287	18
11	14	8	0	0	0	293	24
11	14	9	0	1.2	3	131	20
11	14	10	0	1.1	3	124	23
11	14	11	0	1.1	3	114	45
11	14	12	0	1.3	3	148	50
11	14	13	0	1.7	4	229	44
11	14	14	0	2	4	233	28
11	14	15	0	1.7	3	223	27
11	14	16	0	1.8	4	235	23
11	14	17	0	1.4	4	209	42
11	14	18	0	1.8	4	121	36
11	14	19	0	2	4	85	16
11	14	20	0	2.5	5	85	14
11	14	21	0	2.6	5	94	15
11	14	22	0	2.5	4	91	13
11	14	23	0	1.1	4	71	24
11	19	0	0	1.3	5	345	46
11	19	1	0	1.6	7	6	47
11	19	2	0	3.9	10	9	27
11	19	3	0	4	11	13	26
11	19	4	0	4.3	10	9	25
11	19	5	0	4.8	11	7	25
11	19	6	0	5	11	1	21
11	19	7	0	4.7	10	3	23
11	19	8	0	4.9	12	4	22
11	19	9	0	2.4	11	74	78
11	19	10	0	1.4	6	224	89
11	19	11	0	2.2	5	132	27
11	19	12	0	1.8	5	199	53
11	19	13	0	1.5	7	137	71
11	19	14	0	2	10	288	65

11	19	15	0	2.8	7	291	28
11	19	16	0	2.3	6	292	27
11	19	17	0	1.9	6	252	23
11	19	18	0	1.2	4	249	45
11	19	19	0	0.1	2	298	69
11	19	20	0	0.2	2	350	58
11	19	21	0	1.6	3	43	8
11	19	22	0	1.6	3	49	9
11	19	23	0	1.6	3	57	13
11	20	0	0	1.7	3	56	12
11	20	1	0	1.5	3	63	13
11	20	2	0	1.7	4	64	14
11	20	3	0	1.6	4	55	18
11	20	4	0	1.4	4	41	16
11	20	5	0	1.3	3	40	18
11	20	6	0	1.1	3	40	16
11	20	7	0	0.7	4	64	23
11	20	8	0	0.9	4	86	23
11	20	9	0	1.6	4	100	26
11	20	10	0	1.5	4	114	37
11	20	11	0	1.4	4	153	52
11	20	12	0	2.1	6	234	35
11	20	13	0	3.2	7	241	26
11	20	14	0	2.5	6	242	22
11	20	15	0	2.1	5	280	38
11	20	16	0	1.8	5	283	36
11	20	17	0	1.5	4	233	30
11	20	18	0	0.7	3	182	52
11	20	19	0	1.4	4	103	26
11	20	20	0	1.5	4	71	28
11	20	21	0	1.6	4	58	13
11	20	22	0	1.5	3	59	14
11	20	23	0	1.3	3	51	13
11	25	0	0	0.8	3	306	93
11	25	1	0	0.3	2	69	58
11	25	2	0	0.3	1	27	49
11	25	3	0	0.1	1	344	41
11	25	4	0	0.1	1	318	57
11	25	5	0	0.9	3	314	19
11	25	6	0	0.9	2	319	12
11	25	7	0	0.4	1	320	57
11	25	8	0	0.3	2	284	53
11	25	9	0	1	3	220	52
11	25	10	0	1.2	4	146	77
11	25	11	0	1.3	5	4	88
11	25	12	0	1.3	5	2	80
11	25	13	0	1.4	4	150	81
11	25	14	0	2.1	5	243	29
11	25	15	0	1.5	4	206	31
11	25	16	0	1.8	5	110	38
11	25	17	0	1.5	3	91	28
11	25	18	0	0.7	2	154	67
11	25	19	0	1.2	3	60	45
11	25	20	0	0.7	2	38	47
11	25	21	0	1.4	4	70	23
11	25	22	0	1.3	3	62	23
11	25	23	0	1.2	3	60	14
11	26	0	0	1.2	2	59	10
11	26	1	0	3	10	26	44
11	26	2	0	2.1	6	231	52
11	26	3	0	2.1	7	29	48
11	26	4	0	1.9	6	232	59
11	26	5	0	1.6	6	274	55
11	26	6	0	1.2	4	330	66
11	26	7	0	1	5	324	59
11	26	8	0	1.5	5	310	39
11	26	9	0	4.6	12	350	28
11	26	10	0	4.2	12	351	31
11	26	11	0	3.8	12	358	40
11	26	12	0	4	11	15	33
11	26	13	0	2.9	10	14	54
11	26	14	0	2.4	9	0	71
11	26	15	0	2.4	10	340	56
11	26	16	0	2.2	8	5	58
11	26	17	0	2.6	9	321	42
11	26	18	0	1.3	6	255	88
11	26	19	0	1.4	8	289	82
11	26	20	0	1.7	7	258	60
11	26	21	0	1.9	6	256	53
11	26	22	0	1.9	9	265	52
11	26	23	0	1.5	7	229	68