

VW-VES

VW-VES (HK) Limited

Our Ref: HKSTF-VWVE-EPD-EIA-LE-160707-002

(By hand)

7 July 2016

The EIA Ordinance Register Office
Environmental Protection Department
27/F Southorn Centre
130 Hennessy Road
Wan Chai, Hong Kong

Attn: Mr Alex Tang


Dear Sir

**Contract No. EP/SP/58/08 – Sludge Treatment Facilities
Environmental Monitoring Results in Operation Phase - Landfill Gas Monitoring (May
& June 2016)**

We refer to the Clause 8.2.17 of the EM&A Manual and would like to submit herewith three hard copies and one electronic copy of the captioned for your information and record.

Should you have any queries, please do not hesitate to contact our Mr WB Chu on 2910 9666. Thank you for your kind attention.

Yours faithfully
For and on behalf of
VW-VES (HK) LIMITED



Francois Rudloff
Operation Manager

FR/EZ/WB/hk

Attachment: Landfill Gas Monitoring Record (3 hard copies + 1CD)

cc: EPD – Davie Kan w/ 1 hard copy & w/o CD
Jacobs (ER) – Leslie Swann w/ 1 hard copy & w/o CD

Sludge Treatment Facilities

Office: Nim Wan Road, Tsang Tsui, Tuen Mun, New Territories, Hong Kong
Correspondence: Unit 7601, The Center, 99 Queen's Road Central, Hong Kong
Tel: +852 2910 9600 • Fax: +852 2430 8011

www.veolia.com

operated by  VEOLIA

Sludge Treatment Facilities
 Re : Landfill Gas Monitoring

| Date | Gases | Measurement | Location | | | Remarks |
|-----------|----------------|-------------|------------------|---------|---------|---------|
| | | | Monitoring Wells | | | |
| | | | No. 1 | No. 2 | No. 3 | |
| 17-May-16 | Oxygen | > 19% | 20.90% | 20.90% | 20.90% | ok |
| | Methane | < 10% LEL | 0% | 0% | 0% | ok |
| | Carbon Dioxide | < 0.5% | 400 ppm | 400 ppm | 400 ppm | ok |

Sludge Treatment Facilities
 Re : Landfill Gas Monitoring

| Date | Gases | Measurement | Location | | | Remarks |
|-----------|----------------|-------------|------------------|---------|---------|---------|
| | | | Monitoring Wells | | | |
| | | | No. 1 | No. 2 | No. 3 | |
| 17-Jun-16 | Oxygen | > 19% | 20.90% | 20.90% | 20.90% | ok |
| | Methane | < 10% LEL | 0% | 0% | 0% | ok |
| | Carbon Dioxide | < 0.5% | 400 ppm | 400 ppm | 400 ppm | ok |