

## **Appendix G**

### **Total Odour Emission Rate Extracted from EIA report**

Odour Monitoring Report for Harbour Area Treatment Scheme  
Stage 2A (Operational Phase) (April 2022)



Option 2 - Decentralized Design							
CEPT Facilities (Odd No. Units) & Flow Distribution Channel)	146162.21	S-O2-DO1	12	1.86	20	1	4384.87
CEPT Facilities (Even No. Units) & NWKPS + NWKPS O/F chamber	136086.21	S-O2-DO2	12	1.86	20	1	4082.59
Sludge Treatment Facilities (include Sludge Storage Tanks, Sludge Dewatering Building 1 & 2, Existing and New Sludge Cake Silos)	19057.82	S-O2-DO3	6	2.40	12.58	3	571.73
Stage 1 MPS & Riser Shaft	6518.89	S-O2-DO4	18	1.13	12.28	4	195.57
Stage 2A MPS & Riser Shaft	6518.89	S-O2-DO5	18	1.13	12.28	4	195.57
NWKPTW	19963.88	S-O2-DO6	13	2.26	12.28	8	598.92
Flow Distribution Chambers	2688.01	S-O2-DO7	4.5	0.32	10.48	2	80.64
New Flow Distribution Chamber							
Chlorination Contact Tank	37776.64	S-C-DO1	11	1.13	7.2	4	1133.30
Drop Shaft and Chamber 15A	2630.22	S-C-DO2	4	0.57	8.84	2	263.02

**Total: 11,506.21**

- Note: (1) CEPT facilities include Influent upflow structure, distribution channel, flocculation tanks, sedimentation tanks & effluent weirs, drop shafts, scum pit and rapid mixing tank of sedimentation tanks  
(2) MPS is Main Pumping Station  
(3) NWKPTW, NWKPS & NWKO/F chambers are North West Kowloon PTW, NWKPTW Pumping Station & NWKPTW Overflow Chamber, respectively  
(4) The emission rate included a 1.31 ambient temperature correction factor.