

VW-VES

VW-VES (HK) Limited

Our Ref: HKSTF-VWVE-EPD-EIA-LE-170809-001

(By hand)

9 August 2017

The EIA Ordinance Register Office
Environmental Protection Department
27/F Southorn Centre
130 Hennessy Road
Wan Chai, Hong Kong

Attn: Mr Alex Tang

Dear Sir

**Contract No. EP/SP/58/08 – Sludge Treatment Facilities
Environmental Monitoring Results in Operation Phase - Landfill Gas Monitoring
(July 2017) Re-submission**

Further to our letter dated 3 August 2017 (ref. HKSTF-VWVE-EPD-EIA-LE-170803-001), we would like to submit herewith the revised landfill gas monitoring reports for your information and record.

Should you have any queries, please do not hesitate to contact our Mr WB Chu on 2910 9666. Thank you for your kind attention.

Yours faithfully
For and on behalf of
VW-VES (HK) LIMITED



Francois Rudloff
Operation Manager

FR/WB/fw


Attachment: Landfill Gas Monitoring Record (3 hard copies + 1CD)

cc: EPD – C K Chen w/ 1 hard copy & w/o CD
EPD site – K Ho w/ 1 hard copy & w/o CD
Jacobs (ER) – Leslie Swann w/ 1 hard copy & w/o CD

T ■ PARK

No. 25 Nim Wan Road, Tsang Tsui, Tuen Mun, New Territories, Hong Kong
Tel: +852 2910 9600 • Fax: +852 2430 8011

www.veolia.com

operated by  **VEOLIA**

Sludge Treatment Facilities
 Re : Landfill Gas Monitoring

Date	Gases	Measurement	Location			Remarks
			Monitoring Wells			
			No. 1	No. 2	No. 3	
21-Jul-17	Oxygen	> 19%		20.90%	20.90%	ok
	Methane	< 10% LEL		0%	0%	ok
	Carbon Dioxide	< 0.5%		400 ppm	400 ppm	ok

Sludge Treatment Facilities
 Re : Landfill Gas Monitoring

Date	Gases	Measurement	Location			Remarks
			Monitoring Wells			
			No. 1	No. 2	No. 3	
31-Jul-17	Oxygen	> 19%	20.90%			ok
	Methane	< 10% LEL	0%			ok
	Carbon Dioxide	< 0.5%	400 ppm			ok