

# VW-VES

VW-VES (HK) Limited

Our Ref: HKSTF-VWVE-EPD-EIA-LE-171206-001

(By hand)

6 December 2017

The EIA Ordinance Register Office  
Environmental Protection Department  
27/F Southorn Centre  
130 Hennessy Road  
Wan Chai, Hong Kong

Attn: Mr Alex Tang


Dear Sir

**Contract No. EP/SP/58/08 – Sludge Treatment Facilities  
Environmental Monitoring Results in Operation Phase - Landfill Gas Monitoring  
(November 2017)**

We refer to the Clause 8.2.17 of the EM&A Manual and would like to submit herewith three hard copies and one electronic copy of the captioned for your information and record.

Should you have any queries, please do not hesitate to contact our Mr WB Chu on 2910 9666. Thank you for your kind attention.

Yours faithfully  
For and on behalf of  
VW-VES (HK) LIMITED



---

Vincent Deleu  
Project Manager

VD/WB/fw

Attachment: Landfill Gas Monitoring Record (3 hard copies + 1CD)

cc: EPD – C K Chen w/ 1 hard copy & w/o CD  
EPD site – K Ho w/ 1 hard copy & w/o CD  
Jacobs (ER) – Leslie Swann w/ 1 hard copy & w/o CD

**T • PARK**

No. 25 Nim Wan Road, Tsang Tsui, Tuen Mun, New Territories, Hong Kong  
Tel: +852 2910 9600 • Fax: +852 2430 8011

[www.veolia.com](http://www.veolia.com)

operated by  **VEOLIA**

Sludge Treatment Facilities  
Re : Landfill Gas Monitoring

<u>Date</u>	<u>Gases</u>	<u>Measurement</u>	<u>Location</u>			<u>Remarks</u>
			<u>Monitoring Wells</u>			
			<u>No. 1</u>	<u>No. 2</u>	<u>No. 3</u>	
22-Nov-17	Oxygen	> 19%	20.90%	20.90%	20.90%	ok
	Methane	< 10% LEL	0%	0%	0%	ok
	Carbon Dioxide	< 0.5%	200 ppm	300 ppm	300 ppm	ok