

Your Ref: -
Our Ref: 60627779/C/FYW2005271

By Email (kkleung04@dsd.gov.hk)

Drainage Services Department
44/F, Revenue Tower,
5 Gloucester Road,
Wan Chai, Hong Kong

Attn: Mr. K K Leung

27 May 2020

Dear Sir,

Contract No. CM 12/2019
Expansion of Sha Tau Kok Sewage Treatment Works –
Environmental Team Services for Construction Phase (2020-2021)
Proposal for Changes of the Environmental Monitoring Audit Requirements (Operation phase
of odour monitoring)

We are pleased to submit the revised Proposal for Changes of the Environmental Monitoring Audit Requirements (Operation phase of odour monitoring) which is certified by the Environmental Team Leader and verified by Independent Environmental Checker for your onward submission.

Should you have any queries, please feel free to contact the undersigned at 3922 9366.

Yours faithfully,
AECOM Asia Co. Ltd.


Y W Fung
Environmental Team Leader

Encl.

cc DSD
Black & Veatch Hong Kong Limited
ANEWR Consulting Limited
ANEWR Consulting Limited
ANEWR Consulting Limited

H C Yeung (hcyung@dsd.gov.hk)
Anthony Leung (re_em2@dc1803.com.hk)
James Choi (jpschoi@anewr.com)
Adi Lee (aymlee@anewr.com)
Hazel Chan (hyychan@anewr.com)

ANEWR

Drainage Services Department
42/F, Revenue Tower
5 Gloucester Road
Wan Chai
Hong Kong

Your reference:

Our reference: HKDSD206/50/106518

Date: 27 May 2020

Attention: Mr K K Leung

BY EMAIL & POST
(email: kkleung04@dsd.gov.hk)

Dear Sirs

Agreement No.: CM 14/2018
Independent Environmental Checker Services for
Expansion of Sha Tau Kok Sewage Treatment Works
Proposal for Changes of the Environmental Monitoring
Audit Requirements (Operation phase of odour monitoring)

We refer to emails of 26 and 27 May 2020 from AECOM Asia Co. Ltd attaching the revised Proposal for Changes of the Environmental Monitoring Audit Requirements (Operation phase of odour monitoring).

We have no further comment and hereby verify the captioned Proposal in accordance with Clause 3.1 of the Environmental Permit no. EP-517/2017/A.

Should you have any queries, please do not hesitate to contact the undersigned or our Mr Adi Lee at 2618 2831.

Yours faithfully
ANEWR CONSULTING LIMITED



James Choi
Independent Environmental Checker

CPSJ/LYMA/CYYH/lhnh

cc DSD – Ms Roxana Yeung (email: hcoyeung@dsd.gov.hk)
Black & Veatch Hong Kong Limited – Mr Anthony Leung (email: re_em2@dc1803.com.hk)
Black & Veatch Hong Kong Limited – Mr Alaster Chan (email: are_em2@dc1803.com.hk)
AECOM – Mr YW Fung (email: yw.fung@aecom.com)
AECOM – Ms Lemon Lam (email: lemon.lam@aecom.com)

ANewR Consulting Limited
Unit 517, 5/F, Tower A, Regent Centre
63 Wo Yi Hop Road, Kwai Chung, Hong Kong
Tel: (852) 2618 2831 Fax: (852) 3007 8648
Email: info@anewr.com
Web: www.anewr.com



Proposal for Changes of the Environmental Monitoring Audit Requirements (Operation phase of odour monitoring)

In accordance with Section 3.3.1 and 3.3.2 of the EM&A Manual for the Expansion of Sha Tau Kok Sewage Treatment Works (AEIAR-207/2017), the following changes for the Odour monitoring during operation phase are proposed for health and safety concerns.

Reference in EM&A Manual	Original Monitoring Requirement	Reason for Proposed Changes	Proposed Alternative Method																																																																																																			
Section 3.3.1	<p>In accordance with EIA recommendations, commissioning test for the TSTP and STKSTW is recommended to be performed prior to their operation to ascertain the effectiveness of the deodorization systems at the TSTP and STKSTW during the operation phase. Exhaust air flow rate, temperature of exhaust, odour concentration at the outlet of the deodorization systems should be monitoring during the commissioning test. The exhaust air flow rate, temperature of exhaust odour concentrations presented in Table 3.1 should be maintained. The recommended method for the odour monitoring is presented in Table 3.2. (Table 3.1 and 3.2 of EM&A Manual are extracted below)</p> <p style="text-align: center;">Table 3.1 – Design Parameter of Exhaust Stack and Odour Emission Rates of TSTP and STKSTW</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">Design Parameter</th> <th rowspan="2">Unit</th> <th colspan="2">STKSTW</th> <th colspan="2">TSTP</th> </tr> <tr> <th>STKSTW No.1</th> <th>STKSTW No.2</th> <th>TSTP No.1</th> <th>TSTP No.2</th> </tr> </thead> <tbody> <tr> <td>Location</td> <td>-</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>No. of emission points</td> <td>-</td> <td>15.65</td> <td>14.3</td> <td>14.3</td> <td>14.3</td> </tr> <tr> <td>Building height</td> <td>m</td> <td>17.65</td> <td>14.3</td> <td>14.3</td> <td>14.3</td> </tr> <tr> <td>Stack height</td> <td>m</td> <td>1.40</td> <td>0.15</td> <td>0.15</td> <td>0.25</td> </tr> <tr> <td>Equivalent stack diameter</td> <td>m</td> <td>70.370</td> <td>46.722</td> <td>3.952</td> <td>0.293</td> </tr> <tr> <td>Exit temperature</td> <td>°C</td> <td>19.52</td> <td>12.98</td> <td>1.10</td> <td>2.50</td> </tr> <tr> <td>Total flowrate @ exit temp.</td> <td>m³/s</td> <td>14.44</td> <td>15.53</td> <td>13.15</td> <td>13.15</td> </tr> <tr> <td>Exit velocity</td> <td>m/s</td> <td>1.0</td> <td>1.0</td> <td>1.0</td> <td>2.0</td> </tr> <tr> <td>Maximum H₂S emission concentration at inlet</td> <td>ppm</td> <td>99.3</td> <td>99.3</td> <td>99.5</td> <td>99.9</td> </tr> <tr> <td>% of odour removal</td> <td>%</td> <td>0.07</td> <td>0.07</td> <td>0.05</td> <td>0.1</td> </tr> <tr> <td>Mitigated H₂S emission concentration at exhaust</td> <td>ppm</td> <td>148.9</td> <td>148.9</td> <td>106.4</td> <td>212.8</td> </tr> <tr> <td>Mitigated odour emission concentration at exhaust</td> <td>OU/m³</td> <td>148.9</td> <td>148.9</td> <td>106.4</td> <td>212.8</td> </tr> <tr> <td>Mitigated odour emission rate</td> <td>OU/s</td> <td>4846.4 (8)</td> <td>116.8</td> <td>549.2</td> <td>549.2</td> </tr> </tbody> </table> <p>(8) Same emission point for STKSTW No.1 and STKSTW No.2. (9) Combined emission rate for STKSTW No.1 and STKSTW No.2.</p> <p style="text-align: center;">Table 3.2 – Odour Monitoring Methodology</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Monitoring Location</th> <th>Parameter</th> <th>Recommended Method</th> </tr> </thead> <tbody> <tr> <td>Stack of TSTP or STKSTW</td> <td>Exhaust air flow rate</td> <td>Air balance</td> </tr> <tr> <td rowspan="2">Odour</td> <td>Temperature of exhaust</td> <td>grab sampling using Teflon bag</td> </tr> <tr> <td>Odour</td> <td>Cyclical paramassizer flow meter Laboratory analysis Four-wheel Dynamic Olfactometer according to European Standard Method (EN 13725)</td> </tr> </tbody> </table>	Design Parameter	Unit	STKSTW		TSTP		STKSTW No.1	STKSTW No.2	TSTP No.1	TSTP No.2	Location	-					No. of emission points	-	15.65	14.3	14.3	14.3	Building height	m	17.65	14.3	14.3	14.3	Stack height	m	1.40	0.15	0.15	0.25	Equivalent stack diameter	m	70.370	46.722	3.952	0.293	Exit temperature	°C	19.52	12.98	1.10	2.50	Total flowrate @ exit temp.	m ³ /s	14.44	15.53	13.15	13.15	Exit velocity	m/s	1.0	1.0	1.0	2.0	Maximum H ₂ S emission concentration at inlet	ppm	99.3	99.3	99.5	99.9	% of odour removal	%	0.07	0.07	0.05	0.1	Mitigated H ₂ S emission concentration at exhaust	ppm	148.9	148.9	106.4	212.8	Mitigated odour emission concentration at exhaust	OU/m ³	148.9	148.9	106.4	212.8	Mitigated odour emission rate	OU/s	4846.4 (8)	116.8	549.2	549.2	Monitoring Location	Parameter	Recommended Method	Stack of TSTP or STKSTW	Exhaust air flow rate	Air balance	Odour	Temperature of exhaust	grab sampling using Teflon bag	Odour	Cyclical paramassizer flow meter Laboratory analysis Four-wheel Dynamic Olfactometer according to European Standard Method (EN 13725)	<p>As refer to the latest construction programme, the operation of TSTP will be commissioned in July 2020. The odour commissioning test shall be performed in May 2020.</p> <p>In view of the latest development of Coronavirus Disease 2019 (COVID-19) which might transmit through aerosols and might not be settled in the upcoming few months.</p> <p>Due to the health and safety concerns, the odour monitoring methodology (by forced-choice dynamic olfactometer*) recommended in the Table 3.2 EM&A Manual seems to be not suitable.</p> <p>*The dynamic olfactometry is a standardized way of measuring odour concentrations using the human sense of smell by panelists.</p>	<p>H₂S is the dominant odorant (often present in higher concentrations than other odorants from sewage treatment works) and can provide an indication of the overall odour concentration (1).</p> <p>With reference to the mitigated odour emission concentration at exhaust and mitigated H₂S emission concentration at exhaust are equivalent based on 1OU= 0.0047ppm of H₂S. It is proposed to adopt measurement of H₂S as an alternative method.</p> <p>The measured H₂S at the exhausts will be checked against with the requirements of mitigated H₂S emission concentration at exhaust (i.e. 0.05ppm at TSTP No.1 and 0.1ppm at TSTP No.2) as stated in Table 3.1 of EM&A Manual to assess the effectiveness of the deodorization units.</p> <p>Note: As stated in Table 3.1, while in maximum inlet emission, the mitigated H₂S emission concentration measured at exhausts (i.e. 0.05ppm at TSTP No.1 and 0.1ppm at TSTP No.2) are equivalent to achieve the corresponding 99.5% and 99.8% of odour removal efficiency.</p> <p>Reference: (1) Peter J. and Simon A. P., Hydrogen sulphide measurement, in Odours in Wastewater Treatment Measurement, Modelling and Control, R. Stuetz and F. B. French (eds), IWA Publishing, London, 2001, ISBN 1 900222 46 9, p.120-129.</p>
Design Parameter	Unit			STKSTW		TSTP																																																																																																
		STKSTW No.1	STKSTW No.2	TSTP No.1	TSTP No.2																																																																																																	
Location	-																																																																																																					
No. of emission points	-	15.65	14.3	14.3	14.3																																																																																																	
Building height	m	17.65	14.3	14.3	14.3																																																																																																	
Stack height	m	1.40	0.15	0.15	0.25																																																																																																	
Equivalent stack diameter	m	70.370	46.722	3.952	0.293																																																																																																	
Exit temperature	°C	19.52	12.98	1.10	2.50																																																																																																	
Total flowrate @ exit temp.	m ³ /s	14.44	15.53	13.15	13.15																																																																																																	
Exit velocity	m/s	1.0	1.0	1.0	2.0																																																																																																	
Maximum H ₂ S emission concentration at inlet	ppm	99.3	99.3	99.5	99.9																																																																																																	
% of odour removal	%	0.07	0.07	0.05	0.1																																																																																																	
Mitigated H ₂ S emission concentration at exhaust	ppm	148.9	148.9	106.4	212.8																																																																																																	
Mitigated odour emission concentration at exhaust	OU/m ³	148.9	148.9	106.4	212.8																																																																																																	
Mitigated odour emission rate	OU/s	4846.4 (8)	116.8	549.2	549.2																																																																																																	
Monitoring Location	Parameter	Recommended Method																																																																																																				
Stack of TSTP or STKSTW	Exhaust air flow rate	Air balance																																																																																																				
Odour	Temperature of exhaust	grab sampling using Teflon bag																																																																																																				
	Odour	Cyclical paramassizer flow meter Laboratory analysis Four-wheel Dynamic Olfactometer according to European Standard Method (EN 13725)																																																																																																				

Reference in EM&A Manual	Original Monitoring Requirement	Reason for Proposed Changes	Proposed Alternative Method
Section 3.3.2	<p>Weekly monitoring of odour emission at the exhausts at TSTP and STKSTW by taking odour samples is recommended to be conducted in the first two months of the first year of the operation. The monitoring parameter will include exhaust flow rate, temperature of exhaust and odour concentrations, following the recommended monitoring method as presented in Table 3.2. The monitoring results should be compared with that presented in Table 3.1. Provided that the monitoring results show no non-compliance on a weekly basis during the first two months, it is recommended to reduce the frequency to monthly in the subsequent four months and further reduce to quarterly in the remaining six months of the first year if no non-compliance is found. (Extracted Table 3.1 and 3.2 of EM&A Manual are presented in above)</p>	<p>The TSTP will be operated in July 2020.</p> <p>Regular odour monitoring will be performed in the first-year operation of TSTP as below:</p> <ul style="list-style-type: none"> • Weekly basis in the first two months • Monthly basis in the subsequent four months (if no non-compliance is found) • Quarterly in the remaining six months (if no non-compliance is found) <p>In view of the latest development of COVID-19 which might transmit through aerosols and might not be settled in the upcoming few months.</p> <p>Due to the health and safety concerns, the odour monitoring methodology (by forced-choice dynamic olfactometer*) recommended in the Table 3.2 EM&A Manual seems to be not suitable.</p> <p><i>*The dynamic olfactometry is a standardized way of measuring odour concentrations using the human sense of smell by panelists.</i></p>	<p>It is proposed to adopt measurement of H₂S as an alternative method.</p> <p>The measured H₂S at the exhausts will be checked against with the requirement of mitigated H₂S emission concentration at exhaust (i.e. 0.05ppm at TSTP No.1 and 0.1ppm at TSTP No.2) as stated in Table 3.1 of EM&A Manual to monitor the performance of deodorization units at the first-year operation of TSTP.</p> <p>Note: As stated in Table 3.1, while in maximum inlet emission, the mitigated H₂S emission concentration measured at exhausts (i.e. 0.05ppm at TSTP No.1 and 0.1ppm at TSTP No.2) are equivalent to achieve the corresponding 99.5% and 99.8% of odour removal efficiency.</p>

1 METHODOLOGY FOR PROPOSED ODOUR MONITORING

1.1 Monitoring Parameter and Duration

- 1.1.1 15-minute Hydrogen Sulphide (H₂S) concentration (in parts per million) will be measured by portable H₂S analyzer at the exhaust of TSTP No.1 and TSTP No.2. The exhaust air flow rate, ambient temperature, temperature of exhaust, weather conditions and wind speed will be recorded during the measurement. The details of H₂S measurement is presented in below table:

Table 1.1 Details of H₂S Measurement

Measurement Locations	Measurement Parameters
At the Exhaust of TSTP No.1 and TSTP No.2	15-minute H ₂ S Measurement (every 5 minutes measure one reading) - Average value of the three 5-minute readings will be used to justify the compliance. Exhaust air flow rate, ambient temperature, temperature of exhaust, weather conditions and wind speed will be recorded.

1.2 Monitoring Equipment

- 1.2.1 The details of H₂S analyzer equipment is presented in **Table 1**. The specification of the H₂S analyzer is presented in **Annex A**. The verification test report of H₂S analyzer is presented in **Annex B**.

Table 1.2 Details of H₂S Analyzer Equipment

H ₂ S Analyzer Model	Capable Range of measuring H ₂ S concentration
Jerome 631X	3ppb to 50ppm

Jerome 631-X Hydrogen Sulfide Analyzer

Features:

Rugged and easy to operate
Inherently stable gold film sensor
Pressure sensitive membrane switch operation
Rechargeable internal battery pack for portability
Wide detection range allows for multiple applications
Automatic LCD backlight during low light conditions
Survey mode for rapid source detection of hydrogen sulfide concentrations
Microprocessor ensures a linear response throughout the entire range of the sensor

Specifications:

Resolution	0.001 at Range 0 to 1 ppm at Range 3
Detection Range	0.003-50 ppm
Precision	5% Relative Standard Deviation
Accuracy	Range 0: ± 0.003 ppm at 0.050 ppm Range 1: ± 0.03 ppm at 0.50 ppm Range 2: ± 0.3 ppm at 5.0 ppm Range 3: ± 2 ppm at 25 ppm
Response Time	Sample Mode: Survey Mode: 10-50 ppm in 13 seconds 10-50 ppm in 3 seconds 1.0-10.0 ppm in 16 seconds 1.0-10.0 ppm in 6 seconds 0.10-1.00 ppm in 25 seconds 0.10-1.00 ppm in 15 seconds 0.001-0.100 ppm in 30 seconds 0.001-0.100 ppm in 20 seconds
Flow Rate	150 cc/min or 0.15 l/min
Power Requirements	100-120 V~, 50/60 Hz, 1 A or 220-240 V~, 50/60 Hz, 1 A
Internal Battery Pack	Rechargeable nickel-cadmium
Environmental Range	0-40°C, noncondensing, nonexplosive
Interfaces	RS-232 PC using Jerome Communications Software
Dimensions	631-X: 6" W x 13" L x 4" H / 16 cm W x 33 cm L x 10 cm H 631-XE: 7" W x 14" L x 7" H / 18 cm W x 35 cm L x 18 cm H
Weight	631-X: 7 lbs / 3 kg 631-XE: 8 lbs / 3.5 kg
Warranty	1 year, factory parts and labor
Marks	European Communities (CE) for 220-240 V~ model only

Options:

Functional Test Module for sensor operation verification in the field (30 or 250 ppb)
Data Logger to record field monitoring information
Maintenance Kit for routine maintenance and upkeep
Hard or Soft Field Carrying Case for versatile handling and additional storage
Jerome Communications Software Kit for downloading information from the data logger to a PC or for unattended, fixed-point sampling
Option Board for external fresh air solenoid support, auto-zeroing, DC power operation, timed regeneration, 4-20 mA or 0-2 V analog output, and timed sampling

Applications:

Leak Detection	Applied Research Projects
Quality Control	Scrubber Efficiency Testing
Ambient Air Analysis	Hydrogen Sulfide Source Detection
Regulatory Compliance	Control Room Corrosion Monitoring
Nuisance Odor Monitoring	Accuracy Check for other Hydrogen Sulfide Monitors and Control Systems



Calibration Certificate

Certificate No.: CC0071910

1. Description

Calibration item :	a) Hydrogen Sulfide (H ₂ S)
Equipment description :	Gold Film Hydrogen Sulfide Analyzer
Manufacturer :	ARIZONA INSTRUMENT LLC
Type / Model No. :	Jerome® 631X
Serial No. :	1914
Assigned equipment no. :	N/A
Adjustment :	N/A
Remark :	Received with good condition

2. Customer information

Customer :	AECOM
Address :	8/F, Tower 2, Grand Central Plaza, 138 Shatin Rural Committee Road, Shatin, N.T. HK
Date of receipt :	4 October 2019

3. Date of performance of the calibration

Date of calibration :	10 October 2019
-----------------------	-----------------

Approved Signatory
WM Ling

Company Chop:



Certificate issue date: 11 October 2019

1. The certificate shall not be reproduced except in full, without written approval of CAL LAB LTD
2. The certificate is issued subject to the latest Terms and Conditions, available at our web site

CT-BEG-02
Page 1 of 3
cc0071910



4. Result of Calibration

a) Hydrogen Sulfide (H₂S)

Reference Setting ; ppm	Measured reading ; ppm	Error of indication ; % FS
0	0.000	0.0
0.5	0.46	-0.1
1.0	0.96	-0.1
5.0	4.2	-1.6
10.0	9.1	-1.8

Estimated expanded uncertainty: 2.1 % FS

Technical Requirement: ± 5 ppm

Hydrogen Sulfide (H₂S) - Repeatability

Reference reading ; ppm	RSD ; %
10.0	1.6

Technical Requirement: ± 2 %

Hydrogen Sulfide (H₂S) - Response Time

Reference reading ; ppm	Response time ; second
10.0	13

Technical Requirement:
 ≤ 30 seconds (Pump)

Note: The technical requirement is refer to JIG 695-2003

1. The certificate shall not be reproduced except in full, without written approval of CALLAB LTD
2. The certificate is issued subject to the latest Terms and Conditions, available at our web site

CT-006-04

Page 2 of 3
cc0071910

Cal Lab Limited
Address: Room 2103, Technology Plaza, 29-35 Sha Tsui Road, Tsuen Wan, NT, Hong Kong
Tel: (852)25680106 Fax(852)30116194 Email: info@callab.com.hk Website: callab.com.hk



5. Reference method for calibration

Hydrogen Sulfide	JJG 695-2003
------------------	--------------

6. Environment condition of calibration

Temperature ; °C	24.5 °C
Relative humidity ; %RH	43 %RH

7. Reference equipment used in the calibration

Item	Model	Serial No.	Expiry date	Traceable to
Hydrogen Sulfide	N/A	L193414080	28 Jan 2020	NIM

- Note1: The estimated expanded uncertainties have been calculated in "Evaluation and expression of uncertainty in measurement" and give an internal estimated to have a level of confidence of 95%. A coverage factor of 2 is assumed unless explicitly stated.
- Note2: The standard (s) and instrument used in the calibration are traceable to national or international recognized standard and are calibrated on a schedule to maintain the accuracy and good condition.
- Note3: The result reported in this certificate refer to the condition of the instrument on the date of calibration and carry no implication regarding the long term stability of the instrument.
- Note4: The result shows in this calibration certificate relate only to the item calibrated, and the result only applies to the calibration item as received.

Calibrated by: *James Yeung*

Date: 10 October 2019

Checked by: *William*

Date: 10 October 2019

*** End of Certificate ***

CT-END-02

1. The certificate shall not be reproduced except in full, without written approval of CAL LAB LTD
2. The certificate is issued subject to the latest Terms and Conditions, available at our web site

Page 3 of 3
cc0071910

CAL Lab Limited
Address: Room 2108, Technology Plaza, 29-35 Sha Tsui Road, Tsuen Wan, NT, Hong Kong
Tel: (852)25680106 Fax: (852)26116184 Email: info@callab.com.hk Website: callab.com.hk