

**Environmental Impact Assessment (EIA) Ordinance (Cap. 499)**  
**Application for Permission to Apply Directly for Environmental Permit**  
**(Application No. DIR – 226/2013)**

**Project Title – Temporary Sewage Pumping Station Ancillary to Tung Chung Area 56**  
**Public Housing Development**

**Condition Imposed under Section 5(12) of the Ordinance**  
**for Permission to Apply Directly for Environmental Permit**

1. All measures described in the Project Profile (No. PP – 481/2013) submitted by the applicant on 07 February, 2013 shall be fully implemented.
2. To minimize odour impact during operation of the Project, the inlet chamber, wet well and the screening shall be enclosed with covers inside the structure; and a deodorizer with a forced ventilation system shall be installed and properly maintained.
3. To minimize noise impact during operation of the Project, the pump sets and mechanically raked screens shall be located in a reinforced concrete structure with a soundproof door. Silencers shall be provided for the exhaust fans.
4. To avoid emergency sewage overflow during operation of the Project, one standby pump and dual power supply shall be provided. A Supervisory Control and Data Acquisition system shall be provided to transmit signals showing irregularity or operational problem of the pumping station to the Siu Ho Wan Sewage Treatment Works.
5. To mitigate landscape and visual impacts, vertical greening and roof greening shall be provided and properly maintained during operation of the Project.

Note:

Under section 17 of the EIA Ordinance, the applicant may appeal to the Appeal Board against the above conditions within 30 days of the receipt of this notice of the Directors' decision.

Environmental Protection Department  
March 2013