

CLP POWER HONG KONG LIMITED

**132kV Overhead Pole Line and
Underground Cable from the Existing Po Lam
Substation to the Existing Tui Min Hoi
Substation – Circuit No. 2**

Final EIA Report

October 1999

**MAUNSELL ENVIRONMENTAL
MANAGEMENT CONSULTANTS LTD**
Room 1213-1219, Grand Central Plaza, Tower 2
138 Shatin Rural Committee Road, Shatin, NT, Hong Kong
Tel: (852) 2893 1551 Fax: (852) 2891 0305
Email: emc@maunsell.com.hk

Maunsell

CONTENT

Page

1	INTRODUCTION.....	1
1.1	Background of the Project	1
1.2	Purpose of the EIA Study.....	1
1.3	The Approach.....	3
1.4	Report structure	3
2	PROJECT CHARACTERISTICS	4
2.1	Scope of Work	4
2.2	Site Location.....	4
2.3	Consideration of Alternatives	4
2.4	Construction Activities and Programme.....	4
2.5	Construction Method of the Project.....	5
3	ECOLOGICAL IMPACT	7
3.1	Introduction.....	7
3.2	Environmental Legislation and Criteria.....	7
3.3	Assessment Methodology.....	9
3.4	Baseline Conditions	9
3.5	Impact Assessment	21
3.6	Mitigation Measures	23
3.7	Residual Impacts.....	25
4	HAZARD TO HEALTH.....	26
4.1	Background.....	26
4.2	Environmental Legislation and Guidelines	26
4.3	Assessment Methodology.....	27
4.4	Baseline Conditions	27
4.5	Prediction and Evaluation of Impacts.....	27
4.6	Mitigation of Adverse Impacts	28
5	LANDSCAPE AND VISUAL IMPACT ASSESSMENT.....	29
5.1	Introduction.....	29
5.2	Landscape and Visual Impact Assessment Methodology	29
5.3	Description of the Proposed Development	34
5.4	Scope and Contents.....	35
5.5	Legislation, Guidelines and Planning Policy.....	37
5.6	Identification of Baseline Landscape and Visual Conditions	41
5.7	Identification of Sources of Impact	53
5.8	Assessment of Potential Landscape Impacts	55
5.9	Assessment of Potential Visual Impacts.....	59
5.10	Mitigation Proposals.....	66

5.11	Residual Impacts.....	67
6	WATER QUALITY IMPACT.....	68
6.1	Introduction.....	68
6.2	Environmental Legislation, Policies, Plans, Standards and Criteria	68
6.3	Description of Assessment Methodologies	69
6.4	Description of the Environment.....	70
6.5	Identification of Environmental Impacts	73
6.6	Prediction and Evaluation of Environmental Impacts	74
6.7	Mitigation of Adverse Environmental Impacts	77
6.8	Definition and Evaluation of Residual Environmental Impacts.....	79
7	IMPACT ON CULTURAL HERITAGE.....	80
7.1	Introduction.....	80
7.2	Methodology.....	80
7.3	Baseline conditions	80
7.4	Impact Assessment	82
7.5	Mitigation Measures	82
8	ENVIRONMENTAL MONITORING AND AUDIT	83
8.1	Introduction.....	83
8.2	Environmental Monitoring and Audit Requirements.....	83
8.3	Environmental Monitoring and Audit Manual.....	86
9	CONCLUSIONS AND RECOMMENDATIONS.....	87
9.1	Ecology.....	87
9.2	Hazard to Health.....	87
9.3	Landscape and Visual Factor.....	87
9.4	Water Quality.....	89
9.5	Cultural Heritage	90
10	IMPLEMENTATION SCHEDULE OF RECOMMENDED MITIGATION MEASURES	91

LIST OF TABLES

Table 3.1	List of Bird Species Recorded Within the Study Area.....	16
Table 3.2	Rare/Protected Plant Species in Feng-Shui Woods	20
Table 3.3	Potential Habitat Loss due to Construction of Alternative Powerline Alignment.....	24
Table 4.1	Guidelines on Limits of Exposure to 50 Hz Power Frequency Electric and Magnetic Fields Issued by ICNIRP	26
Table 4.2	Electric and Magnetic Field Calculated for the Circuit, Po Lam – Tui Min Hoi No. 2	27
Table 4.3	Electric and Magnetic Field Measurements for Existing Overhead Lines and Underground Cables of 132kV.....	28
Table 5.1	The Matrix Used to Assess Landscape Impacts.....	32

Table 5.2	Categories of Receivers	32
Table 5.3	Sensitivity of Receiver Group	33
Table 6.1	Water Quality Objectives for Ho Chung Sub-zone of Port Shelter WCZ.....	69
Table 6.2	River water quality trends in the Ho Chung River based on the results of the Seasonal Kendall Test (Source: EPD, 1996)	71
Table 6.3	Pollution load reductions in the Ho Chung River as at the end of 1996 (Source: EPD, 1996).....	72
Table 6.4	Summary of Water Quality Monitoring Results for the four sampling stations along Ho Chung River during the baseline field survey in November 1998.....	73
Table 6.5	Summary of water quality monitoring results in the Ho Chung River in 1997 and 1998 (Source: EPD).....	73
Table 6.6	Action / Limit Levels for DO and SS	78
Table 10.1	Implementation Schedule of Recommended Mitigation Measures.....	92

LIST OF FIGURES

1.1	Location Plan of the Proposed Overhead Pole Line and Underground Cable
1.2	Two Existing Pairs of 33 kV Powerlines
2.1	Tentative Construction Programme
2.2	The Proposed Single and H-pole Supports
3.1a	Habitat Map for Powerline Alignment (A1-A10)
3.1b	Habitat Map for Powerline Alignment (A10-A16)
3.1c	Habitat Map for Powerline Alignment (A17-A24)
3.1d	Habitat Map for Powerline Alignment (A25-A36)
3.1e	Habitat Map for Powerline Alignment (A37-A45)
3.1f	Habitat Map for Powerline Alignment (A44-A56)
3.1g	Habitat Map for Powerline Alignment (Underground Cable Section to Tui Min Hoi)
3.1h	Location of Rare Plant at Pak Kong
3.1i	Habitat Types Along the Powerline Alignment
3.1j	Location of Rare Plant at Pak Kong
3.1k	Habitat Types Along the Powerline Alignment
3.1l	Habitat Types and Rare/Protected Plants Along the Powerline Alignment
3.1m	Habitat Types and Rare/Protected Plants Along the Powerline Alignment
3.1n	Habitat Types and Rare/Protected Plants Along the Powerline Alignment
3.2a	Burrow of Small Indian Civet in Shrubland at Pole A51
5.1	Photographs of Typical 132kV Overhead Powerline Poles
5.2	Elevation of Typical 132kV Overhead Powerline Poles
5.3	Outline Zoning Plan Areas and the Proposed Powerline Alignment
5.4	Proposed Powerline Alignment shown in Context of Landscape Protection Designations (1 of 2)
5.5	Proposed Powerline Alignment shown in Context of Landscape Protection Designations (2 of 2)
5.6	Landscape Character Areas
5.7	Panoramic photographs of Landscape Along the Proposed Powerline Alignment (1 of 2)

- : 5.8 Panoramic photographs of Landscape Along the Proposed Powerline Alignment (2 of 2)
- : 5.9 Zone of Visual Influence for the Proposed 132kV Powerline
- : 5.10 Key Views within the Zone of Visual Influence
- : 5.11 Conceptual Cross-Section Showing Potential Vegetation Clearance Associated with Both Pole Construction Work Sites and the Maintenance of Safety Clearances between Conductors and Adjacent Vegetation
- : 5.12 Photomontage of Proposed Powerline on sideslopes of Razor Hill (as seen from Tseung Kwan O Village)
- : 5.13 Photomontage of Proposed Powerline on southern slopes of Hebe Hill
- : 5.14 Photomontage of Proposed Powerline on sideslopes of Lower Hebe Hill (as seen from Ta Ku Ling Village)
- : 5.15 Photomontage of Proposed Powerline at rear of Nam Pin Wai Village
- : 5.16 Typical View of the Eastern Slopes of Buffalo Hill As Seen From The Edge of Hiram's Highway and Typical Cross-Section through Buffalo Hill and the Adjacent Coastal Plain
- : 5.17 Photomontage of Proposed Powerline at rear of Pak Kong Village
- : 6.1 Locations of Water Quality Monitoring Stations

ANNEXES

- Annex A Plant Lists
- Annex B Species List of Stream Macroinvertebrates
- Annex C Calculated EMF Profiles for H-Pole and Single Pole Configurations
- Annex D Technical Checklists on TM Annexes 11 & 20

REFERENCES