

APPENDIX 3B:

**Details of Operational Phase
Air Quality Assessment**

H₂S build-up in Sewerage System Leading to Ha Tsuen PS and San Wai STW

Assumptions for H₂S Buildup in Sewer

pH	7.00
BOD ₅	250 mg/L
Temperature	30 °C

H₂S Buildup Equations

A. Equations for Pumping Main

A1. H₂S flux from wall slimes

Pomeroy's equation
 $G = M [BOD_5] 1.07^{T-20}$

where

G = H₂S flux (g/m²-h)

T = temp in °C

M = coefficient (m/h)

1.00E-03 (for normal pressure mains)

G used in estimation = 0.492 g/m²-h

A2. H₂S buildup mass balance equation

$C_s = 4G(1+0.4D)t/D$

where

C_s = H₂S concentration build-up (mg/L)

D = diameter (m)

t = retention time (h)

B. Equations for Gravity Sewer

B1. Solving for P and w

Sample Calculations

theta = half of angle subtended at centre (degree)	109.4 degree	(to be calculated)
d = depth of flow (m)	0.200 m	(to be found by varying "design velocity")
D = pipe diameter (m)	0.300 m	
w = surface width of flow (m)	0.283 m	\
P = wetted perimeter (m)	0.573 m	useful in using the Pomeroy and
A = cross-sectional area of flow (m ²)	0.050 m ²	Parjurst equation (calculating a and b)
r = Hydraulic radius (m)	0.087 m	/
Average flow (m ³ /s)	0.100 m ³ /s	
Design velocity (m/s)	2.0 m/s	

B2. Pomeroy and Parkurst equation

$S_2 = [(aS_1 - b)e^{-at} + b]/a$ (for gravity sewer with known retention time)

where

S₂ = [H₂S] at the end of section (mg/L)

S₁ = [H₂S] at the start of section (mg/L)

$a = [N(SV)^{3/8}]/dm$

$b = (M'[BOD_5] 1.07^{T-20})/r$

t = retention time (h)

N = constant used in H₂S build-up equation 0.96 (for partially filled pipes under average condition)

S = total energy head gradient

V = sewage velocity (m/s)

dm = mean hydraulic depth (m) = A/w


M' = specific H₂S flux (m/h) 0.00032 (for partially filled pipes under average condition)

[BOD₅] = 5-day biochemical oxygen demand (mg/L)

T = temp in °C

H₂S build-up in Sewerage System Leading to Ha Tsuen PS and San Wai STW


H₂S Buildup in Lau Fau Shan, Tin Shui Wai and Ha Tsuen



Area/Location	Upstream	Point	Sewer	Q (m ³ /day)	Retention (h)	[H ₂ S] _{init} (mg/L)	[H ₂ S] _{final} (mg/L)	H ₂ S flow (g/day)
Lau Fau Shan	C3.3	C3.2	Pumping	172	0.16	0	2.219	382
	C3.2	C1.2	Gravity	1055	0.23	0.362	0.968	1022
	C1.4	C1.3	Pumping	91	0.31	0	4.300	391
	C1.3	C1.2	Gravity	91	0.10	4.300	1.450	132
	C1.2	TSW PS	Gravity	1146	0.07	1.007	1.125	1289
Tin Shui Wai Phase 2	TSW II	TSW PS	Gravity	37667	0.14	0	0.139	5250
	TSW PS	HT PS	Pumping	38813	0.07	0.168	1.422	55189
Tin Shui Wai Phase 1	TSW I	HT PS	Gravity	41782	0.29	0	0.371	15517
Ha Tsuen	HT	HT PS	Gravity	4484	0.32	0	0.601	2696

H₂S build-up in Sewerage System Leading to Ha Tsuen PS and San Wai STW


H₂S Buildup in Yuen Long and Hung Shui Kiu



Area/Location	Upstream	Point	Sewer	Q (m ³ /day)	Retention (h)	[H ₂ S] _{init} (mg/L)	[H ₂ S] _{final} (mg/L)	H ₂ S flow (g/day)
Yuen Long	Area 13/14	PSS PS	Gravity	17660	0.63	0	0.569	10055
	YL Town	PSS PS	Gravity	25852	0.14	0	0.124	3211
	PSS PS	HT PS	Pumping	43512	0.41	0.305	1.440	62671
Hung Shui Kiu	HSK	HT PS	Gravity	32308	0.34	0	0.276	8906

H₂S build-up in Sewerage System Leading to Ha Tsuen PS and San Wai STW

H₂S Buildup in Au Tau, Yuen Long South and Tong Yan Sun Tsuen




Area/Location	Upstream	Point	Sewer	Q (m ³ /day)	Retention (h)	[H ₂ S] _{init} (mg/L)	[H ₂ S] _{final} (mg/L)	H ₂ S flow (g/day)
Au Tau	A1.11	A1.10	Gravity	8343	0.20	0	0.308	2566
	A1.12	A1.10	Gravity	526	0.16	0	0.749	394
	AT PS	YL South	Pumping	8869	0.23	0.334	1.438	12754
Yuen Long South	Area 13	YL South	Gravity	2308	0.17	0	0.426	983
	YL South	YLS PS	Gravity	14500	0.57	0.947	1.000	14495
	YLS PS	TYST	Pumping	14500	0.19	1.000	1.679	24345
Tong Yan Sun Tsuen	TYST	HT PS	Gravity	47053	0.36	0.517	0.646	30414

CE 62/2000 San Wai STW and Ha Tsuen PS - EIA
 Air Quality - Operational Phase Odour Impact Assessment


H₂S build-up in Sewerage System Leading to Ha Tsuen PS and San Wai STW

H₂S Buildup from Ha Tsuen PS to San Wai STW



Area/Location	Upstream	Point	Sewer	Q (m ³ /day)	Retention (h)	[H ₂ S] _{init} (mg/L)	[H ₂ S] _{final} (mg/L)	H ₂ S flow (g/day)	Reference Sheet
Ha Tsuen PS	TSW PS HT TSW I	HT PS	Pumping	38813	-	-	1.422	55189	LFS+TSW+ HT
		HT PS	Gravity	4484	-	-	0.601	2696	
		HT PS	Gravity	41782	-	-	0.371	15517	
	PSS PS HSK	HT PS	Pumping	43512	-	-	1.440	62671	TL+HSK
		HT PS	Gravity	32308	-	-	0.276	8906	
		TYST	HT PS	Gravity	47053	-	-	0.646	30414
Ha Tsuen PS	As above	HT PS	-	207952	-	-	0.843	175393	This sheet
San Wai STW	Ha Tsuen PS	SW STW	Pumping	207952	0.41	0.843	1.849	384533	

H₂S build-up in Sewerage System Leading to Ha Tsuen PS and San Wai STW



CE 62/2000 San Wai STW and Ha Tsuen PS - EIA
Air Quality - Operational Phase Odour Impact Assessment

H₂S Emission Estimation in San Wai STW

Basis of Estimation

Sewage Flow Conditions

ADWF	207952 m ³ /day
Flow velocity	1.3 m/s
Inlet Pipe Diameter (2 in parallel)	1200 mm
[H ₂ S]	1.849 mg/L or g/m ³

Assumptions - Raw Sewage and H₂S emission within STW

1. Depth of unit is assumed to be 2m
2. Width of channels 2m except the main channels connecting from inlet chamber and to detritors/rapid mix&floc tanks (4 to 5m wide)
3. Raw Sewage:

pH	7.00
BOD ₅	250 mg/L
Temperature	30 °C

List of Odour Emitting Inventories

Name	Phase of Treatment	Odour Potential	Calculation Method	Reference
Primary Sedimentation Tank	Primary	Medium	Open Channel	ASCE 1989
Rapid Mix & Flocculation Tank	Primary	Medium	Open Channel	ASCE 1989
Fine Screen	Preliminary	Medium	Open Channel	ASCE 1989
Sludge Holding Tank	Sludge Treatment	High	Assume = Max of Open Channels	-
Sludge Dewatering House	Sludge Treatment	High	Assume = Max of Open Channels	-
Extg. Solid Handling House	Sludge Treatment	High	Assume = Max of Open Channels	-
Detritors	Primary	Medium	Open Channel	ASCE 1989
Inlet Chamber	Primary	High	Open Channel	ASCE 1989
Other Odour Emission Inventories				
Channels connection inlet chamber to fine screen		High	Open Channel	ASCE 1989
Channels connection fine screen to detritors		High	Open Channel	ASCE 1989
Channels connection detritors to rapid mix & flocculation tank		High	Open Channel	ASCE 1989

Open channel H₂S release equation

Manning's equation (employed to estimate S based on R, V and n)

$$V = R^{2/3} S^{1/2} / n$$

R = hydraulic mean radius = X-sectional area/wetted perimeter

n = Manning's equation 0.013 (Default value)

Dissociated equilibria for H₂S in aqueous solution

Fraction of H₂S in molecular form 0.49 (@ 30°C and pH = 7.00)

H₂S emission rate equation

$$\phi = 0.69(SV)^{3/8} [H_2S]$$

where

phi = H₂S flux (g/m²-h)

S = total energy head gradient

V = sewage velocity (m/s)

[H₂S] = soluble H₂S in molecular form (mg/L) 0.906 mg/L

CE 62/2000 San Wai STW and Ha Tsuen PS - EIA
 Air Quality - Operational Phase Odour Impact Assessment

H₂S Emission Estimation in San Wai STW

Emission Rate for Units

Open Channels					
Unit Operations	Inlet Chamber	Fine Screen	Detritors	Mix & Floc	Sedi. Tanks
Unit Specification					
Number of unit(s)	1	1	5	2	10
Effective Length (m)	7.2	14.92	8	68	68
Effective Width (m)	4.8	6.56	9.6	8	8
Depth (m) of unit	2	2	2	2	2
Surface area (m ²)	34.56	97.82	384.00	1033.60	5331.20
X-sectional area (m ²)	9.6	13.12	19.2	16	16
H₂S flux estimation					
Velocity (m/s)	0.3	0.3	0.1	0.1	0.01
R	1.09	1.24	1.41	1.33	1.33
S (from Manning's equation)	1.35E-05	1.14E-05	1.07E-06	1.15E-06	1.15E-08
Soluble [H ₂ S] in molecular form (mg/L or g/m ³)	0.906	0.906	0.906	0.906	0.906
phi (g/m ² -h)	5.95E-03	5.57E-03	1.52E-03	1.56E-03	1.17E-04
Emission rate in unit area (ug/m ² -s)	1.652	1.548	0.422	0.434	0.033
Emission rate (ug/s)	57.10	151.43	162.04	448.79	173.59

Sludge Treatment Facilities			
Unit Operations	Sldg. Hold.	Sldg. Dewat.	Extg. Hse.
Unit Specification			
Number of unit(s)	3	1	1
Effective Length (m)	11.2	22.4	16
Effective Width (m)	21.6	10.4	14.4
Surface area (m ²)	708.48	232.96	230.40
Emission rate in unit area (ug/m ² -s)	1.652	1.652	1.652
Emission rate (ug/s)	1170.46	384.87	380.64

CE 62/2000 San Wai STW and Ha Tsuen PS - EIA
Air Quality - Operational Phase Odour Impact Assessment

H₂S Emission Estimation in San Wai STW

Emission Rate for Connection Channels

Inlet Chamber to Fine Screen

Effective Length (m)	7
Effective Width (m)	5
Depth (m)	2
Surface area (m ²)	35
X-sectional area (m ²)	10
H₂S flux estimation	
Velocity (m/s)	0.3
R	1.11
S (from Manning's equation)	1.32E-05
Soluble [H ₂ S] in molecular form (mg/L or g/m ³)	0.906
phi (g/m ² -h)	5.89E-03
Emission rate in unit area (ug/m ² -s)	1.637
Emission rate (ug/s)	57.29

Fine Screen to Detritors

Connection Specification	Stream #1	Stream #2	Stream #3	Stream #4	Stream #5	Stream #6	Stream #7
Effective width (m)	5	2	2	2	4	2	2
Depth (m)	2	2	2	2	2	2	2
Surface area (m ²)	56	4	18	33	65	3	3
X-sectional area (m ²)	10	4	4	4	8	4	4
H₂S flux estimation							
Velocity (m/s)	0.3	0.2	0.2	0.2	0.2	0.2	0.2
R	1.11	0.67	0.67	0.67	1.00	0.67	0.67
S (from Manning's equation)	1.32E-05	1.16E-05	1.16E-05	1.16E-05	6.76E-06	1.16E-05	1.16E-05
Soluble [H ₂ S] in molecular form (mg/L or g/m ³)	0.906	0.906	0.906	0.906	0.906	0.906	0.906
phi (g/m ² -h)	5.89E-03	4.82E-03	4.82E-03	4.82E-03	3.94E-03	4.82E-03	4.82E-03
Emission rate in unit area (ug/m ² -s)	1.637	1.339	1.339	1.339	1.094	1.339	1.339
Emission rate (ug/s)	91.67	5.36	24.11	44.20	71.08	4.02	4.02

Detritors to Mix&Floc Tanks

Connection Specification	Stream #1	Stream #2	Stream #3	Stream #4	Stream #5	Stream #6
Effective width (m)	2	2	2	2	2	5
Depth (m)	2	2	2	2	2	2
Surface area (m ²)	24	24	27	16	17	50
X-sectional area (m ²)	4	4	4	4	4	10
H₂S flux estimation						
Velocity (m/s)	0.2	0.2	0.20	0.2	0.2	0.3
R	0.67	0.67	0.67	0.67	0.67	1.11
S (from Manning's equation)	1.16E-05	1.16E-05	1.16E-05	1.16E-05	1.16E-05	1.32E-05
Soluble [H ₂ S] in molecular form (mg/L or g/m ³)	0.906	0.906	0.906	0.906	0.906	0.906
phi (g/m ² -h)	4.82E-03	4.82E-03	4.82E-03	4.82E-03	4.82E-03	5.89E-03
Emission rate in unit area (ug/m ² -s)	1.339	1.339	1.339	1.339	1.339	1.637
Emission rate (ug/s)	32.14	32.14	36.16	21.43	22.77	81.85

CE 62/2000 San Wai STW and Ha Tsuen PS - EIA
Air Quality - Operational Phase Odour Impact Assessment

H₂S Emission Estimation in San Wai STW

Summary and Deodourisation Requirement

Sources of H ₂ S	Emission rate	H ₂ S flux
Primary Sedimentation Tank	173.59 ug/s	0.033 ug/m ² -s
Rapid Mix & Flocculation Tank	448.79 ug/s	0.434 ug/m ² -s
Fine Screen	151.43 ug/s	1.548 ug/m ² -s
Sludge Holding Tank	1170.46 ug/s	1.652 ug/m ² -s
Sludge Dewatering House	384.87 ug/s	1.652 ug/m ² -s
Extg. Solid Handling House	380.64 ug/s	1.652 ug/m ² -s
Detritors	162.04 ug/s	0.422 ug/m ² -s
Inlet Chamber	57.10 ug/s	1.652 ug/m ² -s
Connections (Inlet Chamber->Fine Screen)	57.29 ug/s	1.637 ug/m ² -s
Connections (Fine Screen->Detritors)	244.44 ug/s	from 1.094 to 1.637 ug/m ² -s
Connections (Detritors->Rapid M/F Tanks)	226.49 ug/s	from 1.339 to 1.637 ug/m ² -s
Total Emission	3457.12 ug/s	

Deodourisation Unit Loading

Total Area	8428.02 m ²
Headspace	0.5 m
Air Change per Hour	6.0
Required Ventilation Rate	7.02 m ³ /s
H ₂ S emission rate	3457.12 ug/s
[H ₂ S] _{in}	492.23 ug/m ³
[H ₂ S] _{in}	0.3591 ppmv

Deodourisation Unit Emission Requirement

Emission gas exit velocity	10 m/s
Removal efficiency required	96%
Design exit gas [H ₂ S]	138.28 ug/s
Exit gas flowrate	7.02 m ³ /s
[H ₂ S] _{out}	19.69 ug/m ³
[H ₂ S] _{out}	0.0144 ppmv
Exhaust Air Velocity	10 m/s
Point Source Diameter	0.946 m
Emission Height of DO Unit Exhaust	5 m

CE 62/2000 San Wai STW and Ha Tsuen PS - EIA
Air Quality - Operational Phase Odour Impact Assessment

H₂S Emission Estimation in Ha Tsuen PS

Basis and Estimation

Sewage Flow Conditions

ADWF	207952 m ³ /day
[H₂S]	0.843 mg/L or g/m ³

Assumptions - Raw Sewage and H₂S emission within PS

- Exposed area of wetwell = 280 m² per wetwell (as measured from the basemap)
- Depth of sewage is assumed to be 2m
- Henry's constant for H₂S @ 30°C and 1 atm = 2.21 mg/L (in aqueous) per mg/L (in atmosphere) [m_{H₂S}*H=y_{H₂S}*P]
- Raw Sewage:

pH	7.00
BOD ₅	250 mg/L
Temperature	30 °C

H₂S Estimation in Ha Tsuen PS

Reference

Compilation of Air Pollutant Emission Factors, AP-42, Fifth Edition, Volume I: Stationary Point and Area Sources
 Chapter 4: Evaporation Loss Sources, Section 4.3 Waste Water Collection, Treatment And Storage

Dimensions of the Unit

A = Surface area (m ²)	280 m ²
D = Depth of sewage (m)	2 m

Parameters

rho _A = Air density (g/cm ³)	1.18E-03 g/cm ³
rho _W = Water density (g/cm ³)	0.996 g/cm ³
R = Universal gas constant (atm-m ³ /gmol-K)	8.21E-05 atm-m ³ /gmol-K
T = Temperature of water (K)	303 K
U ₁₀ = Wind speed at 10 m above the liquid surface (m/s)	2 m/s
mu _A = Air viscosity (g/cm-s)	1.86E-04 g/cm-s
mu _W = Water viscosity (g/cm-s)	7.98E-03 g/cm-s
D _A = Diffusivity of H ₂ S in air (m/s)	0.181 m/s
D _{ether} = Diffusivity of ether in water (cm ² /s)	9.68E-06 cm ² /s
D _W = Diffusivity of H ₂ S in water (cm ² /s)	1.83E-05 cm ² /s
H = Henry's law coefficient of constituent (atm-m ³ /gmol)	0.0206 atm-m ³ /gmol
Q = Sewage flowrate (m ³ /s)	207952 m ³ /s
C ₀ = Initial H ₂ S concentration (mg/L)	0.843 mg/L

Calculations leading to emission rate

$U^* = (0.01)(U_{10})(6.1 + 0.63(U_{10})^{0.5})$ (Ibid, p.4.3-9)	where U* = Friction velocity (m/s)	0.0543 m/s
$Sc_L = \mu_{W}/(\rho_{W} \times D_{W})$ (Ibid, p.4.3-9)	where Sc _L = Liquid side Schmidt number	436.82 (dimensionless)
$F/D = 2(A/\pi)^{0.5}/D$ (Ibid, p.4.3-9)	where F/D = Fetch to depth ratio	9.44 (dimensionless)
$k_l = (2.78 \times 10^{-6})(D_{W}/D_{ether})^{2/3}$ (Ibid, p.4.3-9)	where k _l = Liquid phase mass transfer coefficient (m/s)	4.26E-06 m/s
$Sc_G = \mu_{A}/(\rho_{A} \times D_{A})$ (Ibid, p.4.3-9)	where Sc _G = Gas side Schmidt number	0.871 (dimensionless)
$d_e = 2(A/\pi)^{0.5}$ (Ibid, p.4.3-9)	where d _e = Effective diameter (m)	18.88 m
$k_g = (4.82 \times 10^{-3})(U_{10})^{0.78}(Sc_G)^{-0.67}(d_e)^{-0.11}$ (Ibid, p.4.3-9)	where k _g = Gas phase mass transfer coefficient (m/s)	6.57E-03 m/s
$K_{eq} = H/(RT)$ (Ibid, p.4.3-10)	where K _{eq} = Partition coefficient	0.827 (dimensionless)
$K = k_l K_{eq} k_g / (K_{eq} k_g + k_l)$ (Ibid, p.4.3-10)	where K = Overall mass transfer coefficient (m/s)	4.25E-06 m/s
$C_L = QC_0 / (KA + Q)$ (Ibid, p.4.3-10)	where C _L = H ₂ S concentration in the liquid phase (g/m ³)	0.843 g/m ³
$N = 10^6 KC_L A$ (Ibid, p.4.3-10)	where N = H ₂ S emission (ug/s)	1004.23 ug/s

H₂S emission rate **3.59 ug/m²-s**

CE 62/2000 San Wai STW and Ha Tsuen PS - EIA
Air Quality - Operational Phase Odour Impact Assessment

H₂S Emission Estimation in Ha Tsuen PS

Summary and Deodourization Requirement

Ventilation Rate Estimation

	Existing Wetwell	Expanded Wetwell
Space with emission		
Emission Area (m ²)	280 m ²	280 m ²
Headspace of Emission Area (m)	2 m	2 m
Volume of Air in Wetwells (m ³)	560 m ³	560 m ³
Space over the building (measured from the basemap)		
Length of Wetwell (m)	27 m	29 m
Width of Wetwell (m)	22 m	21 m
Wetwell Area (m ²)	594 m ²	609 m ²
Height of Building Ceiling (m)	4.15 m	4 m
Volume of Air in whole Building (m ³)	2465.1 m ³	2496 m ³
Total Volume of Air in Building (m³)	3025.1 m³	3056 m³
Air Change per Hour	6	6
Ventilation Rate (m ³ /hr)	18150.6 m ³ /hr	18336 m ³ /hr
Ventilation Rate (m ³ /s)	5.04 m ³ /s	5.09 m ³ /s

Deodourization Requirement

Emission rate (ug/s)	1004.23 ug/s	1004.23 ug/s
[H ₂ S] _{in} (ug/m ³)	199.18 ug/m ³	197.17 ug/m ³
[H ₂ S] _{in} (ppmv)	0.14530 ppmv	0.14383 ppmv
H ₂ S removal efficiency	97%	97%
H ₂ S emission after deodourization (ug/s)	30.13 ug/s	30.13 ug/s
[H ₂ S] _{out} (ug/m ³)	5.98 ug/m ³	5.91 ug/m ³
[H ₂ S] _{out} (ppmv)	0.00436 ppmv	0.00432 ppmv
Exhaust Air Velocity	8.00 m/s	8.00 m/s
Point Source Diameter	0.896 m	0.900 m
Emission Height of DO Unit Exhaust	8 m	4 m