

Appendix 3B

Part 1: Calculation of Odour Emission Rate (Unmitigated Scenario)

Odour sources to be open: inlet works, grit chambers, equalisation tank, SBR, sludge thickeners, sludge digesters.

Odour Sources to be covered: screenings and grits storage area, return liquor pumping station.

Sewage Characteristics:

Temp	=	30 °C	or	86.00 F
ORP (mV)	=	50 mV	(for septic sewage)	
A (m ³)	=	0.5 x surface area of tank		
V (air change per hour)	=	5		
Cf	=	0.52 for 5 Air Change Per Hour (ACPH)		
DF (OUm ⁻³)	=	$1.6 \times (T/10)^{4.9} \times (ORP + 200)^{-0.59}$		
E (OUs ⁻¹)	=	DF x A x (V/3600) x Cf		

Source ID			DF (OUm ⁻³)	E (OUs ⁻¹)	E (OUm ⁻² s ⁻¹)
S1	Inlet Works				
	L (m)	=	7.4		
	W (m)	=	1.5		
	No. of duty units	=	1 (+ 1 standby)		
	Area (m ²)	=	11.0	2335.49	9.30 0.8434
S2	Grit Chambers				
	Diameter (m)	=	2.1		
	No. of duty units	=	1 (+ 1 standby)		
		Area (m ²)	=	3.6	2335.49
S3	Equalization Tanks				
	L (m)	=	15.7		
	W (m)	=	13.0		
	No. of duty units	=	1		
	Area (m ²)	=	204.1	2335.49	172.13 0.8434
S4 to S7, S7a	SBR A to E				
	L (m)	=	15.5		
	W (m)	=	7.0		
	No. of units	=	5		
	Area (m ²)	=	542.5	2335.49	457.53 0.8434
S8	Sludge Thickener				
	Diameter (m)	=	5.0		
	No. of duty units	=	1 (+ 1 standby)		
		Area (m ²)	=	19.6	2335.49
S9	Sludge Digester				
	L (m)	=	8.6		
	W (m)	=	6.6		
	No. of duty units	=	1 (+ 1 standby)		
	Area (m ²)	=	56.8	2335.49	47.87 0.8434

Source ID	DF (OUm ⁻³) E (OUs ⁻³) E (OUm ⁻² s ⁻¹)			
S10	Vent of Deodourisation Unit			
	For screenings and grit storage area:			
	L (m)	=	12.5	
	W (m)	=	8.5	
	No. of duty units	=	1	
	Area (m ²)	=	106.3	
	A (m ³)	=	53.1	
	V (ACPH)	=	5	
	Air flow rate (m ³ /hr)	=	265.6	
			2335.49	89.61
	Return Liquor Pumping Station			
	L (m)	=	4.70	
	W (m)	=	3.0	
	No. of duty units	=	1	
	Area (m ²)	=	14.1	
	A (m ³)	=	7.1	
	V (ACPH)	=	5	
	Air flow rate (m ³ /hr)	=	35.3	
			2335.49	11.89
	For Emission from Deodourisation Units:			
	<u>Inlet</u>	Total E (OUs ⁻¹)	=	101.50
		DF (OUm ⁻³)	=	2335.49
		H ₂ S conc. (ppm)	=	1.17
<u>Outlet</u>	Total E (OUs ⁻¹)	=	0.51	
(assume 99.5% removal efficiency)	DF (OUm ⁻³)	=	11.68	
	H ₂ S conc. (ppm)	=	0.0058	
	Total air flow rate (m ³ /hr)	=	300.9	
	Dia of pipe (m)	=	0.30	
	Pipe area (m ²)	=	0.07	
	Exit velocity (m/s)	=	1.18	

P1	Peng Chau Sewage Pumping Station (Provided by DSD)			
	<u>Inlet</u>	H ₂ S conc. (ppm)	=	5.00
		DF (OUm ⁻³)	=	10000
	<u>Outlet</u>	H ₂ S conc. (ppm)	=	0.025
	(99.5% removal efficiency)	DF (OUm ⁻³)	=	50
		Vent pipe dimensions (m)	=	0.6 x 0.6
		Vent pipe area (m ²)	=	0.36
		Air flow rate (m ³ /h)	=	1505
		Total Outlet E (OUs ⁻¹)	=	20.90
		Exit velocity (m/s)	=	1.16
		Exit height (m)	=	3.00

Appendix 3B

Part 2: Calculation of Odour Emission Rate (Mitigated Scenario)

Odour sources to be covered: inlet works, grit chambers, equalisation tank, SBR, sludge thickeners, sludge digesters, screenings and grits storage area, return liquor pumping station.

Sewage Characteristics:

Temp	=	30 °C	or	86.00 F
ORP (mV)	=	50 mV	(for septic sewage)	
A (m ³)	=	0.50 x surface area of tank		
V (air change per hour)	=	5		
Cf	=	0.52 for 5 Air Change Per Hour (ACPH)		
DF (OUm ⁻³)	=	$1.6 \times (T/10)^{4.9} \times (ORP + 200)^{-0.59}$		
E (OUS ⁻¹)	=	DF x A x (V/3600) x Cf		

Source ID		DF (OUm ⁻³)	E (OUS ⁻³)	E (OUm ⁻² s ⁻¹)	
SM1	Vent of Deodourisation Unit				
	For inlet works:				
	L (m)	=	7.4		
	W (m)	=	1.5		
	No. of duty units	=	1 (+ 1 standby)		
	Area (m ²)	=	11.0		
	A (m ³)	=	5.5		
	V (ACPH)	=	5.0		
	Air flow rate (m3/hr)	=	27.6	2335.49	9.30
	For Grit Chambers:				
	Diameter (m)	=	2.1		
	No. of duty units	=	1 (+ 1 standby)		
	Total Area (m ²)	=	3.6		
	A (m ³)	=	1.8		
	V (ACPH)	=	5.0		
	Air flow rate (m3/hr)	=	8.9	2335.49	3.00
	For equalisation tank:				
	L (m)	=	15.7		
	W (m)	=	13.0		
	No. of duty units	=	1		
	Area (m ²)	=	204.1		
	A (m ³)	=	102		
	V (ACPH)	=	5		
	Air flow rate (m3/hr)	=	510.3	2335.49	172.13
	For SBR:				
	L (m)	=	15.5		
	W (m)	=	7.0		
	No. of duty units	=	5 (one of which is for future expansion)		
	Total Area (m ²)	=	542.5		
	A (m ³)	=	271		
	V (ACPH)	=	5		
	Air flow rate (m3/hr)	=	1356.3	2335.49	457.53
	For sludge thickeners:				
Diameter (m)	=	5.0			
No. of duty units	=	1.0 (+ 1 standby)			
Total Area (m ²)	=	19.6			
A (m ³)	=	10			
V (ACPH)	=	5			
Air flow rate (m3/hr)	=	49.1	2335.49	16.55	
For sludge digesters:					
L (m)	=	8.6			
W (m)	=	6.6			
No. of duty units	=	1 (+ 1 standby)			
Area (m ²)	=	56.8			
A (m ³)	=	28			
V (ACPH)	=	5			
Air flow rate (m3/hr)	=	141.9	2335.49	47.87	

Source ID		DF (OUm ⁻³)	E (OU ^s ⁻³)	E (OUm ⁻² s ⁻¹)
	For screenings and grit storage area:			
	L (m)	=	12.5	
	W (m)	=	8.5	
	No. of duty units	=	1	
	Area (m ²)	=	106.3	
	A (m ³)	=	53	
	V (ACPH)	=	5	
	Air flow rate (m ³ /hr)	=	265.6	2335.49 89.61
	Return Liquor Pumping Station			
	L (m)	=	4.70	
	W (m)	=	3.0	
	No. of duty units	=	1	
	Area (m ²)	=	14.1	
	A (m ³)	=	7.1	
	V (ACPH)	=	5	
	Air flow rate (m ³ /hr)	=	35.3	2335.49 11.89
	For Emission from Deodourisation Units:			
<u>Inlet</u>	Total E (OU ^s ⁻¹)	=		807.88
	DF (OUm ⁻³)	=		2335.49
	H ₂ S conc. (ppm)	=		1.17
<u>Outlet</u> (assume 99.5% removal efficiency)	Total E (OU ^s ⁻¹)	=		4.04
	DF (OUm ⁻³)	=		11.68
	H ₂ S conc. (ppm)	=		0.0058
	Total air flow rate (m ³ /hr)	=		2394.80
	Dia of pipe (m)	=		0.40
	Pipe area (m ²)	=		0.13
	Exit velocity (m/s)	=		5.30

P1	Peng Chau Sewage Pumping Station (Provided by DSD)			
<u>Inlet</u>	H ₂ S conc. (ppm)	=		5.00
	DF (OUm ⁻³)	=		10000.00
<u>Outlet</u> (99.5% removal efficiency)	H ₂ S conc. (ppm)	=		0.025
	DF (OUm ⁻³)	=		50.00
	Vent pipe dimensions (m)	=	0.6 x 0.6	
	Vent pipe area (m ²)	=		0.36
	Air flow rate (m ³ /h)	=		1505.00
	Total Outlet E (OU ^s ⁻¹)	=		20.90
	Exit velocity (m/s)	=		1.16
	Exit height (m)	=		3.00

Appendix 3B

Part 3: Calculation of Odour Emission Rate (Unmitigated Scenario) (when Drying Bed is Used)

Odour sources to be open: sludge drying Bed.

Odour sources to be covered: inlet works, grit chambers, equalisation tank, SBR, sludge thickeners, sludge digesters, screenings and grits storage area, return liquor pumping station.

Sewage Characteristics:

Temp	=	30 °C	or	86.00 F
ORP (mV)	=	50 mV	(for septic sewage)	
A (m ³)	=	0.50 x surface area of tank		
V (air change per hour)	=	5		
Cf	=	0.52 for 5 Air Change Per Hour (ACPH)		
DF (OUm ⁻³)	=	$1.6 \times (T/10)^{4.9} \times (ORP + 200)^{-0.59}$		
E (OUs ⁻¹)	=	DF x A x (V/3600) x Cf		

Source ID		DF (OUm ⁻³)	E (OUs ⁻³)	E (OUm ⁻² s ⁻¹)	
SM1	Vent of Deodourisation Unit				
	For inlet works:				
	L (m)	=	7.4		
	W (m)	=	1.5		
	No. of duty units	=	1 (+ 1 standby)		
	Area (m ²)	=	11.0		
	A (m ³)	=	5.5		
	V (ACPH)	=	5.0		
	Air flow rate (m3/hr)	=	27.6	2335.49	9.30
	For Grit Chambers:				
	Diameter (m)	=	2.1		
	No. of duty units	=	1 (+ 1 standby)		
	Total Area (m ²)	=	3.6		
	A (m ³)	=	1.8		
	V (ACPH)	=	5.0		
	Air flow rate (m3/hr)	=	8.9	2335.49	3.00
	For equalisation tank:				
	L (m)	=	15.7		
	W (m)	=	13.0		
	No. of duty units	=	1		
	Area (m ²)	=	204.1		
	A (m ³)	=	102		
	V (ACPH)	=	5		
	Air flow rate (m3/hr)	=	510.3	2335.49	172.13
	For SBR:				
	L (m)	=	15.5		
	W (m)	=	7.0		
	No. of duty units	=	5 (one of which is for future expansion)		
	Total Area (m ²)	=	542.5		
	A (m ³)	=	271		
	V (ACPH)	=	5		
	Air flow rate (m3/hr)	=	1356.3	2335.49	457.53
	For sludge thickeners:				
Diameter (m)	=	5.0			
No. of duty units	=	1.0 (+ 1 standby)			
Total Area (m ²)	=	19.6			
A (m ³)	=	10			
V (ACPH)	=	5			
Air flow rate (m3/hr)	=	49.1	2335.49	16.55	
For sludge digesters:					
L (m)	=	8.6			
W (m)	=	6.6			
No. of duty units	=	1 (+ 1 standby)			
Area (m ²)	=	56.8			
A (m ³)	=	28			
V (ACPH)	=	5			
Air flow rate (m3/hr)	=	141.9	2335.49	47.87	

Source ID		DF (OUm ⁻³)	E (OUS ⁻³)	E (OUm ⁻² s ⁻¹)
	For screenings and grit storage area:			
	L (m)	=	12.5	
	W (m)	=	8.5	
	No. of duty units	=	1	
	Area (m ²)	=	106.3	
	A (m ³)	=	53	
	V (ACPH)	=	5	
	Air flow rate (m3/hr)	=	265.6	2335.49 89.61
	Return Liquor Pumping Station			
	L (m)	=	4.70	
	W (m)	=	3.0	
	No. of duty units	=	1	
	Area (m ²)	=	14.1	
	A (m ³)	=	7.1	
	V (ACPH)	=	5	
	Air flow rate (m3/hr)	=	35.3	2335.49 11.89
	For Emission from Deodourisation Units:			
<u>Inlet</u>	Total E (OUS ⁻¹)	=		807.88
	DF (OUm ⁻³)	=		2335.49
	H2S conc. (ppm)	=		1.17
<u>Outlet</u> (assume 99.5% removal efficiency)	Total E (OUS ⁻¹)	=		4.04
	DF (OUm ⁻³)	=		11.68
	H2S conc. (ppm)	=		0.0058
	Total air flow rate (m3/hr)	=		2394.80
	Dia of pipe (m)	=		0.40
	Pipe area (m2)	=		0.13
	Exit velocity (m/s)	=		5.30
S2	Drying Bed			
	L (m)	=	18.00	
	W (m)	=	10.0	
	No. of duty units	=	2	
	Area (m ²)	=	360.0	2335.49 303.61 0.8434

P1	Peng Chau Sewage Pumping Station (Provided by DSD)			
<u>Inlet</u>	H ₂ S conc. (ppm)	=		5.00
	DF (OUm ⁻³)	=		10000.00
<u>Outlet</u> (99.5% removal efficiency)	H2S conc. (ppm)	=		0.025
	DF (OUm ⁻³)	=		50.00
	Vent pipe dimensions (m)	=		0.6 x 0.6
	Vent pipe area (m ²)	=		0.36
	Air flow rate (m ³ /h)	=		1505.00
	Total Outlet E (OUS ⁻¹)	=		20.90
	Exit velocity (m/s)	=		1.16
	Exit height (m)	=		3.00

Appendix 3B

Part 4: Calculation of Odour Emission Rate (Mitigated Scenario) (when Drying Bed is Used)

Odour sources to be covered: inlet works, grit chambers, equalisation tank, SBR, sludge thickeners, sludge digesters, sludge drying bed, screenings and grits storage area, return liquor pumping station.

Sewage Characteristics:

Temp	=	30 °C	or	86.00 F
ORP (mV)	=	50 mV	(for septic sewage)	
A (m ³)	=	0.50 x surface area of tank		
V (air change per hour)	=	5		
Cf	=	0.52 for 5 Air Change Per Hour (ACPH)		
	=	0.26 for 10 Air Change Per Hour (ACPH)		
DF (OUm ⁻³)	=	1.6 x (T/10) ^{4.9} x (ORP + 200) ^{-0.59}		
E (OUs ⁻¹)	=	DF x A x (V/3600) x Cf		

Source ID		DF (OUm ⁻³)	E (OUs ⁻³)	E (OUm ⁻² s ⁻¹)	
SM1	Vent of Deodourisation Unit				
	For inlet works:				
	L (m)	=	7.4		
	W (m)	=	1.5		
	No. of duty units	=	1 (+ 1 standby)		
	Area (m ²)	=	11.0		
	A (m ³)	=	5.5		
	V (ACPH)	=	5.0		
	Air flow rate (m3/hr)	=	27.6	2335.49	9.30
	For Grit Chambers:				
	Diameter (m)	=	2.1		
	No. of duty units	=	1 (+ 1 standby)		
	Total Area (m ²)	=	3.6		
	A (m ³)	=	1.8		
	V (ACPH)	=	5.0		
	Air flow rate (m3/hr)	=	8.9	2335.49	3.00
	For equalisation tank:				
	L (m)	=	15.7		
	W (m)	=	13.0		
	No. of duty units	=	1		
	Area (m ²)	=	204.1		
	A (m ³)	=	102		
	V (ACPH)	=	5		
	Air flow rate (m3/hr)	=	510.3	2335.49	172.13
	For SBR:				
	L (m)	=	15.5		
	W (m)	=	7.0		
	No. of duty units	=	5 (one of which is for future expansion)		
	Total Area (m ²)	=	542.5		
	A (m ³)	=	271		
	V (ACPH)	=	5		
	Air flow rate (m3/hr)	=	1356.3	2335.49	457.53
	For sludge thickeners:				
Diameter (m)	=	5.0			
No. of duty units	=	1.0 (+ 1 standby)			
Total Area (m ²)	=	19.6			
A (m ³)	=	10			
V (ACPH)	=	5			
Air flow rate (m3/hr)	=	49.1	2335.49	16.55	
For sludge digesters:					
L (m)	=	8.6			
W (m)	=	6.6			
No. of duty units	=	1 (+ 1 standby)			
Area (m ²)	=	56.8			
A (m ³)	=	28			
V (ACPH)	=	5			
Air flow rate (m3/hr)	=	141.9	2335.49	47.87	

Source ID		DF (OUm ⁻³)	E (OUs ⁻³)	E (OUm ⁻² s ⁻¹)
	For screenings and grit storage area:			
	L (m)	=	12.5	
	W (m)	=	8.5	
	No. of duty units	=	1	
	Area (m ²)	=	106.3	
	A (m ³)	=	53	
	V (ACPH)	=	5	
	Air flow rate (m3/hr)	=	265.6	2335.49 89.61
	Return Liquor Pumping Station			
	L (m)	=	4.70	
	W (m)	=	3.0	
	No. of duty units	=	1	
	Area (m ²)	=	14.1	
	A (m ³)	=	7.1	
	V (ACPH)	=	5	
	Air flow rate (m3/hr)	=	35.3	2335.49 11.89
	Drying Bed			
	L (m)	=	18.00	
	W (m)	=	10.0	
	No. of duty units	=	2	
	Area (m ²)	=	360.0	
	A (m ³)	=	180	
	V (ACPH)	=	10 (recommended by the engineer to ensure sludge drying efficiency)	
	Air flow rate (m3/hr)	=	1800.0	2335.49 303.61
	For Emission from Deodourisation Units:			
<u>Inlet</u>	Total E (OUs ⁻¹)	=		1111.50
	DF (OUm ⁻³)	=		2335.49
	H2S conc. (ppm)	=		1.17
<u>Outlet</u> (assume 99.5% removal efficiency)	Total E (OUs ⁻¹)	=		5.56
	DF (OUm ⁻³)	=		11.68
	H2S conc. (ppm)	=		0.0058
	Total air flow rate (m3/hr)	=		4194.80
	Dia of pipe (m)	=		0.40
	Pipe area (m2)	=		0.13
	Exit velocity (m/s)	=		9.28

P1	Peng Chau Sewage Pumping Station (Provided by DSD)			
<u>Inlet</u>	H ₂ S conc. (ppm)	=		5.00
	DF (OUm ⁻³)	=		10000.00
<u>Outlet</u> (99.5% removal efficiency)	H ₂ S conc. (ppm)	=		0.025
	DF (OUm ⁻³)	=		50.00
	Vent pipe dimensions (m)	=	0.6 x 0.6	
	Vent pipe area (m ²)	=		0.36
	Air flow rate (m ³ /h)	=		1505.00
	Total Outlet E (OUs ⁻¹)	=		20.90
	Exit velocity (m/s)	=		1.16
	Exit height (m)	=		3.00