









**Appendix 6.4 Model Results for Gazetted and Non-Gazetted Beaches**

Note: Shaded and bolded - value exceeded the assessment criteria

ID	Indicator Point	Scenario	Bottom		Depth Averaged					
			10%ile DO (mg/L)	10%ile DO (mg/L)	GM <i>E.coli</i> (no./100mL)	Mean			Max 4-d Mean UIA (mg/L)	Maximum TRC (mg/L)
						PO <sub>4</sub> (mg/L)	TIN (mg/L)	UIA (mg/L)		
<b>Non-Gazetted Beaches</b>										
<b>Assessment Criteria (for Semi-enclosed Bay in Southern WCZ)</b>			<b>≥ 2</b>	<b>≥ 4</b>	<b>≤ 180</b>	<b>≤ 0.01</b>	<b>≤ 0.1</b>	<b>≤ 0.021</b>	<b>≤ 0.035</b>	<b>≤ 0.008</b>
U3	Discovery Bay	2014 - Without HATS Stage 2A (1a)	6.75	7.47	1	<b>0.01103</b>	<b>0.1844</b>	0.004	0.006	0.0000
		2014 - Early Phase of HATS Stage 2A (1b)	6.51	7.28	1	0.00955	<b>0.1853</b>	0.004	0.006	0.0000
		2021 - Without HATS Stage 2A (2a)	6.73	7.47	1	<b>0.01123</b>	<b>0.1904</b>	0.004	0.006	0.0000
		2021 - Late Phase of HATS Stage 2A (2b)	6.76	7.51	1	<b>0.01014</b>	<b>0.1898</b>	0.004	0.006	0.0000
		2021- Sensitivity Test - Stage 2A - Change of Storm Loading (2c)	6.76	7.51	1	<b>0.01013</b>	<b>0.1898</b>	0.004	0.006	0.0000
		2021 - Sensitivity Test - Stage 2A - Change of Sewage Flow Interception (2d)	6.77	7.52	1	0.00962	<b>0.1800</b>	0.004	0.006	0.0000
		Ultimate - Sensitivity Test - Stage 2A - Use of HATS Design Flow Rate (2e)	6.72	7.49	1	<b>0.01080</b>	<b>0.2028</b>	0.004	0.006	0.0000
		2021 - Sensitivity Test - Stage 2A - enhanced P-removal (2f)	6.70	7.43	1	0.00715	<b>0.1977</b>	0.004	0.006	0.0000
		2021 - Early Phase of HATS Stage 2B (3a)	6.89	7.65	1	0.00901	<b>0.2217</b>	0.004	0.005	0.0000
		Ultimate - Late Phase of HATS Stage 2B (3b)	6.87	7.64	1	0.00965	<b>0.2401</b>	0.004	0.005	0.0000
		2021 - Emergency Scenario due to heavy rainfall (overflow) (A)	-	-	1	<b>0.01014</b>	<b>0.1899</b>	0.004	0.006	-
		2021 - Emergency Scenario due to power failure at SCISTW (B)	-	-	1	<b>0.01014</b>	<b>0.1899</b>	0.004	0.006	-
		2021 - Emergency Scenario due to failure at Stage 2 PTWs (C)	-	-	1	<b>0.01014</b>	<b>0.1898</b>	0.004	0.006	-
		2014 - Emergency Scenario due to modification works at pumping station (D)	-	-	1	<b>0.01113</b>	<b>0.1851</b>	0.004	0.006	-
		2014 - Emergency Scenario due to modification works at NWK PS (E)	-	-	1	<b>0.01106</b>	<b>0.1845</b>	0.004	0.006	-