

NSR ID.	Floor	Floor Level, mPD	Noise Criteria, dB(A)	Predicted Noise Level (PNL), dB(A)	Exceedance PNL > Criteria
P29	7/F	36.6	70	72.1	Y
	8/F	39.6	70	72.1	Y
	9/F	42.6	70	72.0	Y
	10/F	45.6	70	72.0	Y
	11/F	48.6	70	71.9	Y
	12/F	51.6	70	71.9	Y
	13/F	54.6	70	71.8	Y
	14/F	57.6	70	71.8	Y
	15/F	60.6	70	71.7	Y
	16/F	63.6	70	71.7	Y
	17/F	66.6	70	71.7	Y
	18/F	69.6	70	71.6	Y
	19/F	72.6	70	71.6	Y
20/F	75.6	70	71.6	Y	
21/F	78.6	70	71.6	Y	
22/F	81.6	70	71.6	Y	
HT3	7/F	39.7	70	70.0	N
	8/F	42.5	70	70.2	N
	9/F	45.3	70	70.4	N
	10/F	48.1	70	70.5	Y
	11/F	50.9	70	70.6	Y
	12/F	53.7	70	70.7	Y
	13/F	56.5	70	70.9	Y
	15/F	59.3	70	71.0	Y
	16/F	62.1	70	71.0	Y
	17/F	64.9	70	71.1	Y
	18/F	67.7	70	71.1	Y
	19/F	70.5	70	71.2	Y
	20/F	73.3	70	71.2	Y
	21/F	76.1	70	71.2	Y
	22/F	78.9	70	71.2	Y
	23/F	81.7	70	71.1	Y
	25/F	84.5	70	71.1	Y
	27/F	90.1	70	71.0	Y
	28/F	92.9	70	71.0	Y
	29/F	95.7	70	71.0	Y
	30/F	98.5	70	70.9	Y
	31/F	101.3	70	70.9	Y
	32/F	104.1	70	70.8	Y
	33/F	106.9	70	70.8	Y
	35/F	109.7	70	70.8	Y
	36/F	112.5	70	70.8	Y
	37/F	115.3	70	70.7	Y
	38/F	118.1	70	70.7	Y
	39/F	120.9	70	70.7	Y
	40/F	123.7	70	70.6	Y
	41/F	126.5	70	70.6	Y
	42/F	129.3	70	70.6	Y
	43/F	132.1	70	70.5	Y
	45/F	134.9	70	70.5	Y
	46/F	137.7	70	70.5	Y
47/F	140.5	70	70.4	N	
48/F	143.3	70	70.4	N	
49/F	146.1	70	70.3	N	
50/F	148.9	70	70.3	N	
51/F	151.7	70	70.3	N	
52/F	154.5	70	70.2	N	
55/F	160.1	70	70.1	N	
56/F	162.9	70	70.1	N	
57/F	165.7	70	70.1	N	
58/F	168.5	70	70.0	N	
59/F	171.3	70	70.0	N	
60/F	174.1	70	70.0	N	
61/F	176.9	70	69.9	N	
62/F	179.7	70	69.9	N	
63/F	182.5	70	69.8	N	
65/F	185.3	70	69.8	N	
66/F	188.1	70	69.8	N	
67/F	190.9	70	69.7	N	
68/F	193.7	70	69.7	N	
69/F	196.5	70	69.7	N	
70/F	199.3	70	69.6	N	
71/F	202.1	70	69.6	N	
72/F	204.9	70	69.6	N	
73/F	207.7	70	69.6	N	
75/F	210.5	70	69.5	N	

NSR ID.	Floor	Floor Level, mPD	Noise Criteria, dB(A)	Predicted Noise Level (PNL), dB(A)	Exceedance PNL > Criteria
HT3	76/F	213.3	70	69.5	N
	77/F	216.1	70	69.4	N
	78/F	218.9	70	69.4	N
	79/F	221.7	70	69.4	N
	80/F	224.5	70	69.4	N
HT1	7/F	39.7	70	71.8	Y
	8/F	42.5	70	71.7	Y
	9/F	45.3	70	71.5	Y
	10/F	48.1	70	71.3	Y
	11/F	50.9	70	71.2	Y
	12/F	53.7	70	71.1	Y
	13/F	56.5	70	71.0	Y
	15/F	59.3	70	70.8	Y
	16/F	62.1	70	70.8	Y
	17/F	64.9	70	70.6	Y
	18/F	67.7	70	70.6	Y
	19/F	70.5	70	70.5	Y
	20/F	73.3	70	70.5	Y
	21/F	76.1	70	70.5	Y
	22/F	78.9	70	70.4	N
	23/F	81.7	70	70.3	N
	25/F	84.5	70	70.3	N
	27/F	90.1	70	70.2	N
	28/F	92.9	70	70.2	N
	29/F	95.7	70	70.1	N
	30/F	98.5	70	70.0	N
	31/F	101.3	70	70.0	N
	32/F	104.1	70	69.9	N
	33/F	106.9	70	69.9	N
	35/F	109.7	70	69.8	N
	36/F	112.5	70	69.8	N
	37/F	115.3	70	69.7	N
	38/F	118.1	70	69.6	N
	39/F	120.9	70	69.6	N
	40/F	123.7	70	69.5	N
	41/F	126.5	70	69.5	N
	42/F	129.3	70	69.4	N
	43/F	132.1	70	69.4	N
	45/F	134.9	70	69.3	N
	46/F	137.7	70	69.3	N
	47/F	140.5	70	69.3	N
	48/F	143.3	70	69.3	N
	49/F	146.1	70	69.2	N
	50/F	148.9	70	69.3	N
	51/F	151.7	70	69.2	N
	52/F	154.5	70	69.2	N
	55/F	160.1	70	69.2	N
	56/F	162.9	70	69.2	N
	57/F	165.7	70	69.2	N
	58/F	168.5	70	69.1	N
	59/F	171.3	70	69.1	N
	60/F	174.1	70	69.1	N
	61/F	176.9	70	69.0	N
62/F	179.7	70	69.0	N	
63/F	182.5	70	69.0	N	
65/F	185.3	70	68.9	N	
66/F	188.1	70	68.9	N	
67/F	190.9	70	68.9	N	
68/F	193.7	70	68.9	N	
69/F	196.5	70	68.8	N	
70/F	199.3	70	68.8	N	
71/F	202.1	70	68.8	N	
72/F	204.9	70	68.8	N	
73/F	207.7	70	68.7	N	
75/F	210.5	70	68.7	N	
76/F	213.3	70	68.6	N	
77/F	216.1	70	68.6	N	
78/F	218.9	70	68.6	N	
79/F	221.7	70	68.6	N	
80/F	224.5	70	68.5	N	

Note: **Bold** figures with shaded boxes denote exceedance of relevant noise criteria