

Sewage Flow for Aberdeen Preliminary Treatment Works

Year\PDZ	40	41	43	44	45	46	47	49	349	TSW Water Park Development	Future Hotels under Preliminary Planning	50	51	ADWF Total (m ³ /day)	Catchment inflow factor	Revised ADWF total (m ³ /day)	Contributing Population	Peaking Factor	Peak Flow (l/s)
2011	1389	1098	172	4710	2328	5710	16058	7827	2072	0	0	1578	4189	47130	1.3	61269	226923	2.7	1944
2013	1319	1064	211	4825	2310	5805	16343	8497	2258	0	0	1486	3268	47386	1.3	61602	228157	2.7	1954
2016	1213	1013	270	4999	2284	5948	16770	9503	2538	0	0	1349	1886	47771	1.3	62102	230008	2.7	1969
2021	1153	923	290	5070	2191	5914	16302	12038	2783	780.5	505.6	1456	3614	53019	1.3	68925	255279	2.7	2170