

NOTES :

**Cold Catastrophic Failure of Fuel Oil Road Tanker During Filling (Sinopec HK Oil Terminal Chai Wan)**

		<i>Ignition Prob.</i>	<i>Event Outcome</i>	<i>Outcome Probability</i>
1.00E+0	<b>Oil Release</b>	yes 0.004	Pool Fire	4.00E-3
		no 0.996	Unignited Release	9.96E-1
				<b>1.00</b>

**Cold Partial Failure of Fuel Oil Road Tanker During Filling (Sinopec HK Oil Terminal Chai Wan)**

		<i>Ignition Prob.</i>	<i>Event Outcome</i>	<i>Outcome Probability</i>
1.00E+0	<b>Oil Release</b>	yes 0.004	Pool Fire	4.00E-3
		no 0.996	Unignited Release	9.96E-1
				<b>1.00</b>

Consultant



**Allied Environmental Consultants Limited**  
ACOUSTICIANS & ENVIRONMENTAL ENGINEERS

Project No. : 1158

File Name :

Project :  
Chai Wan Government Complex and Vehicle Depot

Drawing Title :  
Event Trees for Catastrophic and Partial Failure of Fuel Oil Road Tanker (Sinopec HK Oil Terminal)

Drawing No : Figure 10.10      Revision : 3

Scale : NTS      Date : May 2015

DO NOT SCALE OFF DRAWING. THIS DRAWING IS NOT FOR CONSTRUCTION PURPOSES UNLESS EXPRESSLY STATED. ALL RIGHTS RESERVED AND REPRODUCTION IN ANY FORM MUST BE APPROVED BY ALLIED ENVIRONMENTAL CONSULTANTS LIMITED.