



NOTES :

Catastrophic Failure of LPG Vessel



*Fireball effects are negligible for the underground storage tank. Instead Flash Fire is considered.

Partial Failure of LPG Vessel



* Vertical Jetfire is considered for partial failure of the underground storage tank.

Consultant



Allied Environmental Consultants Limited
ACOUSTICIANS & ENVIRONMENTAL ENGINEERS

Project No. : 1158

File Name :

Project :
Chai Wan Government Complex and Vehicle Depot

Drawing Title :
Event Trees for Catastrophic and Partial Failure of LPG Vessel

Drawing No : Figure 10.13 Revision : 2

Scale : NTS Date : May 2015

DO NOT SCALE OFF DRAWING. THIS DRAWING IS NOT FOR CONSTRUCTION PURPOSES UNLESS EXPRESSLY STATED. ALL RIGHTS RESERVED AND REPRODUCTION IN ANY FORM MUST BE APPROVED BY ALLIED ENVIRONMENTAL CONSULTANTS LIMITED.