
## NOTES:

## Catastrophic Failure of Petrol Tanker

		lgnition Probability	Delay Ignition	VCE	Event Outcome	Outcome Probability
1.00E+0	Petrol Release	yes 0.08			Fireball	8.00E-2
		no 0.92	yes 0.5	yes 0.2	VCE	9.20E-2
			no 0.5	no 0.8	Flash Fire	3.68E-1
					Unignited Release	4.60E-1
						1.00

Partial Failure of Petrol Tanker





Project No. : 1158

Drainati

Chai Wan Government Complex and Vehicle Depot

Drawing Title :

Event Trees for Catastrophic and Partial Failure of Petrol Road Tanker

Drawing No	Figure 10.18	Revision:	3
Scale :	NTS	Date :	May 2015

DO NOT SCALE OFF DRAWING. THIS DRAWING IS NOT FOR CONSTRUCTION PURPOSES UNLESS EXPRESSLY STATED. ALL RIGHTS RESERVED AND REPRODUCTION IN ANY FORM MUST BE APPROVED BY ALLIED ENVIRONMENTAL CONSULTANTS LIMITED.