Emission Inventory for AERMOD Model (Industrial Emission)

	Source	Type	Y	v	Release	Exit	Exit Velocity	Stack	Period of	Emission Rate				
Emission Source	oource	туре	~	1	Height	Temperature	Exit velocity	Diameter	Emission	NOx	TSP	RSP	FSP	Remarks
	ID		(m)	(m)	(m)	(K)	(m/s)	(m)	(hr)	(g/s)				
Prince of Wales Hospital	PWH1	POINT	838729.4	826583.8	36	393	0.8	0.45	24 hr	2.686E-02	1.41E-03	1.41E-03	1.41E-03	Release height, exit temperature, exit velocity and operation period were provided by Prince of Wales Hospital (PWH). Due to the lack of information, stack diameter was referenced to the information provided by PWH for another chimney of the hospital. All TSP emissions were assumed for RSP and FSP as a conservative approach.
	PWH2	POINT	838745.5	826648.7	56	483	0.8	0.45	2411	1.615E+00	8.46E-02	8.46E-02	8.46E-02	Exit temperature and operation period were provided by PWH. Due to the lack of information, emission rate, exit velocity and stack diameter were referenced to the information provided by PWH for the other chinneys of the hospital. Release height was identified by observation. All TSP emissions were assumed for RSP and FSP as a conservative approach.
Diamond Hill Crematorium	DHC1	POINT	839438.8	822851.4	30.2	373	10.02	0.24	0.27 0.24 0.27 0.27 21:00)	5.272E-02	1.387E-02	1.387E-02	1.387E-02	Emission rates and exhaust parameters (including release height, exit temperature, exit velocity and stack diameter) were referenced to the information presented in the SP licenses. NO ₂ emissions were assumed to be 20% of NOx with reference to Table 4.7 of the Reprovisioning of Diamond Hill Crematorium EIA Report, and TSP emissions were assumed for RSP and FSP as a conservative approach.
	DHC2	POINT	839438.8	822849.8	30.2	373	10.21	0.27		6.797E-02	1.789E-02	1.789E-02	1.789E-02	
	DHC3	POINT	839438.7	822848.3	30.2	373	10.02	0.24		5.272E-02	1.387E-02	1.387E-02	1.387E-02	
	DHC4	POINT	839442.8	822850.9	30.2	373	10.21			6.797E-02	1.789E-02	1.789E-02	1.789E-02	
	DHC5	POINT	839442.8	822849.5	30.2	373	10.02	0.24		5.272E-02	1.387E-02	1.387E-02	1.387E-02	
	DHC6	POINT	839442.6	822848.2	30.2	373	7.92	0.27		5.272E-02	1.387E-02	1.387E-02	1.387E-02	
Fu Shan Crematorium	FSC1	POINT	835288.6	826080.1	20.5	373	8.51	0.27	14 hr (7:00 - 21:00)	-	5.278E-02	5.278E-02	5.278E-02	
	FSC2	POINT	835290.9	826078.2	20.5	373	8.52	0.25		-	4.722E-02	4.722E-02	4.722E-02	
	FSC3	POINT	835289.3	826079.5	20.5	373	8.52	0.25		-	4.722E-02	4.722E-02	4.722E-02	
	FSC4	POINT	835290.1	826078.8	20.5	373	8.52	0.25	-	4.722E-02	4.722E-02	4.722E-02		

Detailed Calculation of Chimney Emission from Prince of Wales Hospital

According to Prince of Wales Hospital, there are 3 chimneys in the hospital. 2 chimneys fall within the 500m study area, while 1 chimney falls outside the 500m study area and therefore was not included in the assessment. The 2 chimneys within the 500m study area serve the use of calorifier and steam boiler respectively. Both equipment operate 24-hr a day.

NOx Emission factor =	0.22 6.448E-05	g/kWh g/BTU	Reference made to the approved <i>Provision of a Poultry Slaughtering Centre in Sheung Shui</i> EIA Report 1kWh = 3412.14BTU			
Particulate Matter Emission factor =	7.6 0.007451 3.380E-06 1.153E-02	lb/10 ⁶ scf lb/MMBTU g/BTU g/kwh	Reference made to AP-42 Chapter 1.4, as the Towngas involve high % of natural gas To convert from lb/10 ⁶ scf to lb/MMBTU, divided by 1020 1kWh = 3412.14BTU			
For the chimney PWH1, Towngas consumption =	1500000 416.667	BTU/hr BTU/s	Information from Prince of Wales Hospital			
NOx Emission rate of the chimney =	2.686E-02	g/s				
Particulate Matter Emission rate of the chimney =	1.408E-03	g/s				
For the chimney PWH2, Towngas consumption =	26422	kWh/hr	Due to the lack of information from PWH, the Pok Oi Hospital (POH) towngas consumption extracted from the approved <i>Housing Sites in Yuen Long</i> <i>South</i> EIA Report was multiplied by the ratio of number of beds of PWH (i.e. 1749-870=879, excluding the Main Clinical Block as it has its own boiler and chimney which is outside of the 500m study area) to the number of beds of POH (i.e. 768) according to the Hereital Authority Statistical Poppet 2010 2000			
NOx Emission rate of the chimney = 1.61		g/s	the Hospital Authority Statistical Report 2019-2020.			
Particulate Matter Emission rate of the chimney =	8.46E-02	g/s				





