

Appendix 3.10
Emission Inventory and
Calculation on Chimneys

Calculation of Boiler Emissions in North District Hospital

North District Hospital Boiler (NDHC01-03)

| | | | | |
|--|---|--|--------------------|---|
| Monthly Consumption | = | 5,863,104 MJ | | Note 1 |
| | = | 1,628,640 kWh | | 1kWh = 3.6MJ |
| Consumption per Boiler | = | 542,880 kWh | | 3 boilers |
| Consumption Rate per Boiler | = | 0.2027 kWh/s | ...(1) | Note 2 |
| | = | 2,626.84 MJ/hr | ...(2) | |
| NOx Emission Factor | = | 220 mg/kWh | | Note 3 |
| | = | 0.22 g/kWh | ...(3) | |
| NOx Emission Rate: | = | 0.0892 g/s | ...(4)=(3)*(1) | Note 4 |
| PM Emission Factor From Gas Combustion | = | 7.6 lb/10 ⁶ scf | | Note 5 |
| | = | 121.60 kg/10 ⁶ m ³ | ...(5) | To convert from lb/10 ⁶ scf to kg/10 ⁶ m ³ , multiply by 16. |
| Heating Value of Natural Gas (Calorific Value) | = | 1020 Btu/scf | | Note 6 |
| | = | 38.00 MJ/m ³ | ...(6) | |
| PM (TSP/RSP/FSP) Emission Rate | = | 16809.72 kg/10 ⁶ hr | ...(7)=(2)/(6)*(5) | Note 4 |
| | = | 0.0047 g/s | | 1kg=1000g; 1hour=3600seconds |

Note:

[1] 2019 monthly fuel consumption is provided by North District Hospital. Highest monthly fuel consumption is adopted as conservative approach.

[2] Assume 24 hours operation per day as a conservative approach .

[3] Reference from Section 3.5.1 of AEIAR142/2009 "Provision of a Poultry Slaughtering Centre in Sheung Shui".

[4] The emission rate is multiplied by 2 times as a conservative approach.

[5] The emission factor as PM(Total) on Table 1.4-2 of Chapter 1.4, USEPA AP42, Fifth Edition, Volume I is adopted as Towngas has similar combustion characteristics to natural gas.

[6] Reference from Town Gas Characteristics in Towngas Website. (<https://www.towngas.com/en/About-Us/Hong-Kong-Gas-Business/Gas-Production>)

Emission Inventory on Chimneys

| Building (Name) | Model ID (#) | X (HK1980) | Y (HK1980) | Source (Type) | Operation (Hours) | Base (mPD) | Stack Height (mAG) | Stack Diameter (m) | Exit Temp. (K) | Stack Velocity (m/s) | Emission Rates | | | | Use on Phase | | Remarks | |
|---|-----------------|---------------|---------------|------------------|----------------------|---------------|-----------------------|-----------------------|-------------------|-------------------------|---------------------------|-------------------|--------------------|--------------|--------------|--------------|-------------|--|
| | | | | | | | | | | | NOx (g/s) | RSP/PM10 (g/s) | FSP/PM2.5 (g/s) | TSP (g/s) | Design/Base | Construction | | |
| North District Hospital | NDHC01 | 830849.00 | 839680.00 | POINT | 24-Hour | 15.2 | 64.52 | 0.60 | 333 | 7 | 0.0892 | 0.0047 | 0.0047 | 0.0047 | ✓ | ✓ | [1],[3],[4] | |
| | NDHC02 | 830850.00 | 839681.00 | POINT | 24-Hour | 15.2 | 64.52 | 0.60 | 333 | 7 | 0.0892 | 0.0047 | 0.0047 | 0.0047 | ✓ | ✓ | | |
| | NDHC03 | 830851.00 | 839682.00 | POINT | 24-Hour | 15.2 | 64.52 | 0.60 | 333 | 7 | 0.0892 | 0.0047 | 0.0047 | 0.0047 | ✓ | ✓ | | |
| North District Hospital Expansion | NDHE01 | 830778.00 | 839734.00 | POINT | 24-Hour | 12.0 | 64.52 | 0.60 | 333 | 7 | 0.0892 | 0.0047 | 0.0047 | 0.0047 | ✓ | | [2],[3],[4] | |
| | NDHE02 | 830780.00 | 839732.00 | POINT | 24-Hour | 12.0 | 64.52 | 0.60 | 333 | 7 | 0.0892 | 0.0047 | 0.0047 | 0.0047 | ✓ | | | |
| | NDHE03 | 830782.00 | 839730.00 | POINT | 24-Hour | 12.0 | 64.52 | 0.60 | 333 | 7 | 0.0892 | 0.0047 | 0.0047 | 0.0047 | ✓ | | | |
| | | | | | | | | | | | Use on Design/Base Phase | ✓ | ✓ | ✓ | | | | |
| | | | | | | | | | | | Use on Construction Phase | | ✓ | ✓ | ✓ | | | |

Note:

- [1] Information provided by North District Hospital.
- [2] No information on North District Hospital Expansion, for conservative, assume the same as North District Hospital.
- [3] For those chimneys where the operators did not provide any information, their exit velocities and temperatures are assumed to be 7m/s and 373K advised by EPD.
- [4] For Hospital Boilers, for conservative approach, assume PM listed = TSP = RSP = FSP as no reference shall be made on Hong Kong situations.