

Appendix 3.10 Calculation of Odour Emission Source at EPP, FWPF and SPS

Proposed Effluent Polishing Plant

Design of Deodorization System

DO 1 (Inlet Works + Primary Treatment)

Location	Nos.	Air Phase Height (m)	Total Odour Emission Area (m2)	Air Phase Volume (m3)	Aeration Rate (m3/hr) (if any)	Air Exchange Rate (Air Changes / hr)	SOER (ou/m2/s)	Unmitigated Odour Emission Rate (ou/s)	Flow Rate (m3/hr)	Total Flow Rate (m3/s)	Velocity (m/s)	Number of Exhaust Point (nos.)	Height of the Deodorizer Exhaust Point (mAG)	Diameter of the Deodorizer Exhaust Point (m)	Removal Efficiency (%)	Mitigated Odour Emission Rate (ou/s)	Temperature at exhaust point (C)								
Inlet Works																									
Inlet Well	1	4	121	485		3	3.26	394.96	1,454	25.23	7.50	1	33	2.07	97%	668	Ambient								
Coarse Screen Channel	4	4	166	665		3	3.51	583.20	1,994																
Distribution Channel (screen - wet well)	1	4.5	92	415		3	3.26	300.92	1,246																
Wet Well	2	4.5	185	831		3	3.26	601.85	2,492																
Distribution Channel (wet well - fine screen)	1	2	157	314		3	3.26	511.57	942																
Fine Screen Channel	4	2.5	185	462		3	3.51	648.00	1,385																
Distribution Channels (fine screen - grit trap) A	1	2.5	98	245		3	3.26	319.73	736																
Distribution Channels (fine screen - grit trap) B	1	2.5	87	216		3	3.26	282.12	649																
Distribution Channels (fine screen - grit trap) C	1	2.5	170	425		3	3.26	554.83	1,276																
Grit Trap Influent Channels	3	2.5	71	177		3	3.26	230.21	530																
Grit Trap	3	2.5	243	607		3	3.26	791.09	1,820																
Grit Trap effluent Channels	3	2.5	100	249		3	3.26	325.00	748																
Distribution Channel (grit trap to Distribution chamber) wide	1	2.5	81	202		3	3.26	263.31	606																
Distribution Channel (grit trap to Distribution chamber) narrow	1	2.5	32	81		3	3.26	105.32	242																
Coarse Screening Skip Area	1	3	93	280		12	3.51	328.05	3,365																
Screening and Grit Skip Area	1	3	323	969		12	3.51	1134.00	11,631																
Conveyors	6	0.3	42	12		3	3.51	145.80	37																
Equalization Tank	1	3.5	1,236	4,325		3	3.26	4028.61	12,976																
Distribution Chamber	1	1.5	136	203		3	3.26	441.98	610																
Primary Treatment																									
Inlet Channel	1	4	110	438		3	3.26	357.35	1,315																
Scum Tank	2	1	17	17		3	4.03	69.75	52																
Influent Distribution Channel	1	4	202	808		3	3.26	658.27	2,423																
Scum "Y" Channel	2	1.5	37	55		3	1.54	56.86	166																
Skimmer Tank Area	2	2	295	591		3	4.03	1190.40	1,772																
Primary Sedimentation Tank Area	2	3	1,163	3,489		3	4.03	4687.20	10,468																
Primary Sedimentation Tank Inspection Area	1	3	729	2,188		12	4.03	2938.80	26,252																
PST Effluent Channel	1	6	202	1,212		3	1.54	310.96	3,635																
								sub-total	22,260	90,821															

DO 2 (Sludge + Sidestream)

Location	No. of Units (Duty)	Air Phase Height (m)	Total Odour Emission Area (m2)	Air Phase Volume (m3)	Aeration Rate (m3/hr) (if any)	Air Exchange Rate (Air Changes / hr)	SOER (ou/m2/s)	Unmitigated Odour Emission Rate (ou/s)	Flow Rate (m3/hr)	Total Flow Rate (m3/s)	Velocity (m/s)	Number of Exhaust Point (nos.)	Height of the Deodorizer Exhaust Point (mAG)	Diameter of the Deodorizer Exhaust Point (m)	Removal Efficiency (%)	Mitigated Odour Emission Rate (ou/s)	Temperature at exhaust point (C)								
Thickening & Dewatering House																									
Sludge Blend Tanks	2	1.5	69	104		3	3.98	275.54	312	5.94	7.5	1	33	1.00	97%	222	Ambient								
Thickening Centrifuges	2	1	18	18		3	3.98	73.48	55																
Thickened Sludge Holding Tanks	2	1	307	307		3	3.98	1221.55	921																
Centrate Buffer Tanks	2	1	65	65		3	3.98	257.17	194																
Digested sludge holding tank	2	1.5	335	503		6	3.98	1333.61	3,016																
Dewatering Centrifuges	2	1	18	18		3	3.98	73.48	55																
Dryer Centrifuges	1	1	9	9		3	3.98	36.74	28																
Dryer	1	1	46	46		3	3.98	183.69	138																
Sludge Silo (Dewatering)	3	1	61	61		3	0.43	26.05	182																
Dried Sludge Silo (Drying)	4	1	69	69		3	0.43	29.77	208																
Sludge Skip Room	1	3	318	954		12	3.51	1115.78	11,444																
Conveyors	6	0.3	91	27		3	3.51	320.76	82																
Side Stream																									
Anammox Process Tanks	1	1.81	790	1,433		3	2.73	2157.17	4,298																
Thickened Sludge Tank Wet Well	1	2	18	36		3	3.98	70.85	107																
Sludge Mixing Tank Wet Well	1	2	18	36		3	3.98	70.85	107																
Anammox Sludge Storage Tank	1	2	39	78		3	3.98	154.94	234																
								sub-total	7,401	21,380															

Appendix 3.10 Calculation of Odour Emission Source at EPP, FWPF and SPS

Proposed Effluent Polishing Plant

Design of Deodorization System

DO 3 (Bioreactor)

Location	No. of Units (Duty)	Air Phase Height (m)	Total Odour Emission Area (m ²)	Air Phase Volume (m ³)	Aeration Rate (m ³ /hr) (if any)	Air Exchange Rate (Air Changes / hr)	SOER (ou/m ² /s)	Unmitigated Odour Emission Rate (ou/s)	Flow Rate (m ³ /hr)	Total Flow Rate (m ³ /s)	Velocity (m/s)	Number of Exhaust Point (nos.)	Height of the Deodorizer Exhaust Point (mAG)	Diameter of the Deodorizer Exhaust Point (m)	Removal Efficiency (%)	Mitigated Odour Emission Rate (ou/s)	Temperature at exhaust point (C)						
Bioreactor																							
Outlet Channel (PST to Fine Screen)	1	1	48	48		3	1.65	79.96	145	29.52	7.5	1	33	2.24	97%	217	Ambient						
Fine Screen Chamber	4	2	277	554		3	3.51	972.00	1,662														
Fine Screen Effluent Channel A	2	1.5	88	132		3	1.65	144.69	395														
Fine Screen Effluent Channel B	1	1.5	115	173		3	1.65	190.38	519														
Fine Screen Effluent Channel C	1	1.5	169	253		3	1.65	278.72	760														
Pre- Anoxic Tank	3	2	945	1,890		3	1.65	1559.25	5,670														
Aerobic Tank	3	2	1,192	2,384	89,723	3	1.65	1967.05	89,723														
Post- Anoxic Tank	3	2	276	552		3	1.65	455.78	1,657														
Bioreactor Effluent Channel A	2	2	502	1,004		3	1.65	828.55	3,013														
Bioreactor Effluent Channel B	1	2	457	914		3	1.65	753.92	2,742														
sub-total								7,230	106,286														

DO 4 (Membrane Bioreactor Building)

Location	No. of Units (Duty)	Air Phase Height (m)	Total Odour Emission Area (m ²)	Air Phase Volume (m ³)	Aeration Rate (m ³ /hr) (if any)	Air Exchange Rate (Air Changes / hr)	SOER (ou/m ² /s)	Unmitigated Odour Emission Rate (ou/s)	Flow Rate (m ³ /hr)	Total Flow Rate (m ³ /s)	Velocity (m/s)	Number of Exhaust Point (nos.)	Height of the Deodorizer Exhaust Point (mAG)	Diameter of the Deodorizer Exhaust Point (m)	Removal Efficiency (%)	Mitigated Odour Emission Rate (ou/s)	Temperature at exhaust point (C)
MBR Building																	
Inlet Channel	1	1	291	291		3	1.65	479.77	872	27.29	7.5	1	33	2.15	97%	123	Ambient
Membrane Tank	10	1	1,717	1,717	95,908	3	1.65	2832.92	95,908								
Deoxygenation zone	1	1	485	485		3	1.65	799.62	1,454								
sub-total								4,112	98,234								

DO 5 (Food Waste)

Location	No. of Units (Duty)	Air Phase Height (m)	Total Odour Emission Area (m ²)	Air Phase Volume (m ³)	Aeration Rate (m ³ /hr) (if any)	Air Exchange Rate (Air Changes / hr)	SOER (ou/m ² /s)	Unmitigated Odour Emission Rate (ou/s)	Flow Rate (m ³ /hr)	Total Flow Rate (m ³ /s)	Velocity (m/s)	Number of Exhaust Point (nos.)	Height of the Deodorizer Exhaust Point (mAG)	Diameter of the Deodorizer Exhaust Point (m)	Removal Efficiency (%)	Mitigated Odour Emission Rate (ou/s)	Temperature at exhaust point (C)
Food Waste Reception																	
Food Waste Bunker	2	5.00	238.43	1192.15		3	3.98	948.95	3,576	1.05	7.5	1	33	0.42	97%	36	Ambient
Food Waste Dilution Tank	1	1.00	27.69	27.69		3	3.98	110.22	83								
Digester																	
Sludge Buffer Tank	1	1.00	36.92	36.92		3	3.98	146.95	111								
sub-total								1,206	3,770								

Remarks:

[1] SOER Reference: Shek Wu Hui effluent polishing plant https://www.epd.gov.hk/eia/register/report/eiareport/eia_2132013/eia/pdf/appendix/appendix_3-8.pdf. The SOER from SWHEPP was adopted because SWHEPP receives similar nature of sewage without seawater flushing, adopts the same sewage treatment process of proposed EPP. Among Hong Kong's sewage treatment works with the above similar nature of sewage and treatment process, SWHEPP is of the nearest order of capacity compared to proposed EPP.

[2] The odour removal efficiency for deodorization units is referenced from Scottish Executive Environment Group Code of Practice on Assessment and Control of Odour Nuisance from Waste Water Treatment Works which is appended in this Appendix.

[3] The adopted SOER for Food Waste Reception Building is referenced from SOER from sludge in Shek Wu Hui EPP with sludge digestion process. Compared to the SOER adopted for food waste (3.68 OU/m²/s) for North Lantau RTS Building Area in the approved Organic Waste Treatment Facilities Phase 1 (OWTF-P1) EIA Report (AEIAR-149/2010), and its subsequent Environmental Review Report for Variation of Environmental Permit (VEP-488/2015), SWHEPP's sludge SOER of 3.98 OU/m²/s is higher and more conservative. It is therefore adopted in this assessment.

[4] Detailed calculations of SOER of Annamox, referenced from Appendix 3.7 of YLSEPP EIA Report (AEIA-237/2022), are shown in last page of Appendix 3.10.

[5] Dimensions of odour emission area, air phase volume, air exchange rate and exhaust parameters are based on engineering design.

Appendix 3.10 Calculation of Odour Emission Source at EPP, FWPF and SPS

Proposed Effluent Polishing Plant

Exhaust Design

Deodouriser	Description	Source Type	Exhaust Location		Exhaust Diameter (m)	Height (mAG)	Exit Temperature (K)	Exit Velocity (m/s)
			X	Y				
EPP_DO1	Exhaust point (Inlet Works + PST)	POINTCAP	825097.11	839152.71	2.07	33.00	Ambient	7.5
EPP_DO2	Exhaust point (Sludge + Side Stream)	POINTCAP	824745.29	839062.78	1.00	33.00	Ambient	7.5
EPP_DO3	Exhaust point (BR)	POINTCAP	824955.70	839226.23	2.24	33.00	Ambient	7.5
EPP_DO4	Exhaust point (MBR Building)	POINTCAP	825023.18	839112.82	2.15	33.00	Ambient	7.5
EPP_DO5	Exhaust point (Food Waste)	POINTCAP	824665.88	839101.06	0.42	33.00	Ambient	7.5

Remark:

1. The exhaust parameters are provided by engineer.

Conversion of 1-hour Average to 5-second Average Concentration

Deodouriser	Emission Rate (OU/s)	Stability Class	Conversion Multiplier	Emission Rate with 5-second Peak Factor (OU/s)	Reference
EPP_DO1	668	A, B, C, D, E, F	2.3	1535.95	- Approved Methods for the Modelling and Assessment of Air Pollutants in New South Wales.
EPP_DO2	222	A, B, C, D, E, F	2.3	510.70	- Katestone Scientific 1995, The Evaluation of Peak-to-Mean Ratios for Odour Assessments, volumes I and II, Katestone Scientific Pty Ltd, Brisbane.
EPP_DO3	217	A, B, C, D, E, F	2.3	498.89	- Katestone Scientific 1998, Peak-to-Mean Concentration Ratios for Odour Assessments, Katestone Scientific Pty Ltd, Brisbane.
EPP_DO4	123	A, B, C, D, E, F	2.3	283.75	
EPP_DO5	36	A, B, C, D, E, F	2.3	83.22	

Emission Source Listing in AERMOD

Source ID	Type	X	Y	Exhaust Diameter (m)	Height (mAG)	Exit Temperature (K)	Exit Velocity(m/s)	Emission Rate with 5-second Peak Factor (OU/s)
EPP_DO1	POINTCAP	825097.11	839152.71	2.07	33.00	Ambient	7.5	1535.95
EPP_DO2	POINTCAP	824745.29	839062.78	1.00	33.00	Ambient	7.5	510.70
EPP_DO3	POINTCAP	824955.70	839226.23	2.24	33.00	Ambient	7.5	498.89
EPP_DO4	POINTCAP	825023.18	839112.82	2.15	33.00	Ambient	7.5	283.75
EPP_DO5	POINTCAP	824665.88	839101.06	0.42	33.00	Ambient	7.5	83.22

Appendix 3.10 Calculation of Odour Emission Source at EPP, FWPF and SPS

Proposed Food Waste Pre-treatment Facility

Pollutant Concentration to Odour Concentration

Pollutant	Odour threshold k (ppm) [1][2]	Molar Mass M (g/mol)	Volume of Gas V_T (m ³ /mol) [3]	At Temperature T (Celcius)	Odour threshold in Mass Concentration k_c (mg/m ³)
NH ₃	0.037	17.0305	24.4513	25	0.0258
H ₂ S	0.00047	34.0810	24.4513	25	0.0007

Remark:

[1] Reference from Ammonia Fact Sheet, AERISA

[2] Reference from Hydrogen Sulphide Fact Sheet, AERISA

[3] Volume of Gas at Standard Temperature and Pressure is 22.4 m³/mol. By Ideal Gas Law, $V_T = 22.4 / 273 * (273 + T)$, where T is the temperature in Celcius

[4] $k_c = k * M / V$

Summary of Monitoring Data from Food Waste Pre-treatment Facility of the Food Waste / Sludge Anaerobic Co-Digestion Tai Po Pilot Plant

Data Summary	H ₂ S Concentration at Inlet (ppm)	H ₂ S Concentration at Outlet (ppm)	NH ₃ Concentration at Inlet (ppm)	NH ₃ Concentration at Outlet (ppm)
Min	0.0631723	0.0100155	0.5221730	0.0689271
Max	0.5737897	0.0897909	4.4088579	1.6821527
Average	0.1954407	0.0366411	1.8604502	0.3091344

Remark:

Hourly monitoring data was recorded from Jan 2020 to Jan 2023.

Other Operation Details:

Design flow rate of DO system

(m³/hr): 12000

Processing capacity (tpd): 50

Odour Emission Rate of Each Exhaust Point in Food Waste Pre-treatment Facility

Pollutant	Emission Concentration C_x (ppb) [1]	Molar Mass M (g/mol)	Volume of Gas V_T (m ³ /mol) [2]	At Temperature T (Celcius)	Mass concentration C (mg/m ³) [3]	Equivalent Odour Concentration C_{OU} (OU/m ³) [4]	Flow Rate Q (m ³ /s) [1]	Odour Emission Rate E_{OU} (OU/s) [5]
NH ₃	1682.1527	17.0305	24.4513	25	1.1716	45.4636	3.3333	151.5453
H ₂ S	89.7909	34.0810	24.4513	25	0.1252	191.0445	3.3333	636.8150

Remark:

[1] Reference from Monitoring Data from Food Waste Pre-treatment Facility of the Food Waste / Sludge Anaerobic Co-Digestion Tai Po Pilot Plant. The maximum concentration is adopted.

[2] Volume of Gas at Standard Temperature and Pressure is 22.4 m³/mol. By Ideal Gas Law, $V_T = 22.4 / 273 * (273 + T)$, where T is the temperature in Celcius

[3] $C = C_x / 1000 * M / V_T$

[4] $C_{OU} = C / k_c$

[5] $E_{OU} = C_{OU} * Q$

[6] Continuous monitoring of actual H₂S and NH₃ concentrations after commissioning is required.

Appendix 3.10 Calculation of Odour Emission Source at EPP, FWPF and SPS

Proposed Food Waste Pre-treatment Facility

Exhaust Design

Deodouriser	Description	Source Type	Exhaust Location		Exhaust Diameter (m)	Height (mAG)	Exit Temperature (K)	Exit Velocity (m/s)
			X	Y				
FWPF1a	Exhaust point	POINT	824662.37	839134.79	0.80	10.00	Ambient	6.6
FWPF1b	Exhaust point	POINT	824662.37	839134.79	0.80	10.00	Ambient	6.6
FWPF2a	Exhaust point	POINT	824580.35	839099.98	0.80	10.00	Ambient	6.6
FWPF2b	Exhaust point	POINT	824580.35	839099.98	0.80	10.00	Ambient	6.6

Remark:

- Two units of food waste pre-treatment facility (50 tpd each) of the Food Waste / Sludge Anaerobic Co-Digestion Tai Po Pilot Plant is employed to account for the proposed capacity of 100 tpd.
- The exhaust parameters are provided by engineer.

Conversion of 1-hour Average to 5-second Average Concentration

Deodouriser	Emission Rate (OU/s)	Stability Class	Conversion Multiplier	Emission Rate with 5-second Peak Factor (OU/s)	Reference
FWPF1a	637	A, B, C, D, E, F	2.3	1464.67	- Approved Methods for the Modelling and Assessment of Air Pollutants in New South Wales. - Katestone Scientific 1995, The Evaluation of Peak-to-Mean Ratios for Odour Assessments, volumes I and II, Katestone Scientific Pty Ltd, Brisbane. - Katestone Scientific 1998, Peak-to-Mean Concentration Ratios for Odour Assessments, Katestone Scientific Pty Ltd, Brisbane.
FWPF1b	152	A, B, C, D, E, F	2.3	348.55	
FWPF2a	637	A, B, C, D, E, F	2.3	1464.67	
FWPF2b	152	A, B, C, D, E, F	2.3	348.55	

Emission Source Listing in AERMOD

Source ID	Type	X	Y	Exhaust Diameter (m)	Height (mAG)	Exit Temperature (K)	Exit Velocity(m/s)	Emission Rate with 5-second Peak Factor (OU/s)
FWPF1a	POINT	824662.37	839134.79	0.80	10.00	Ambient	6.63	1464.67
FWPF1b	POINT	824662.37	839134.79	0.80	10.00	Ambient	6.63	348.55
FWPF2a	POINT	824580.35	839099.98	0.80	10.00	Ambient	6.63	1464.67
FWPF2b	POINT	824580.35	839099.98	0.80	10.00	Ambient	6.63	348.55

Proposed Sewage Pumping Station (OU.1.2, OU.3.2, OU.5.7)

Design of Sewage Pumping Station

Location	Total Odour Emission Area (m ²) ¹	SOER (ou/m ² ·s)	Unmitigated Odour Emission Rate (ou/s)	Removal Efficiency (%)	Mitigated Odour Emission Rate (ou/s)
SPS at OU.5.7	954.00	3.26	3110.04	95	155.502
SPS at OU.3.2	563.50	3.26	1837.01	95	91.8505
SPS at OU.1.2	322.50	3.26	1051.35	95	52.5675

Remark:

- The area of wet well is provided by design engineer.
- SOER of the inlet well / wet well of the Proposed EPP is adopted to represent the raw sewage.

Exhaust Design

Deodouriser	Description	Source Type	Exhaust Location		Exhaust Diameter (m)	Height (mAG)	Exit Temperature (K)	Exit Velocity (m/s)
			X	Y				
SPS1	Exhaust point of SPS at Site OU.5.7	POINTHOR	825509.39	839378.40	2.00	4.35	Ambient	5.0
SPS2	Exhaust point of SPS at Site OU.3.2	POINTHOR	826578.39	840033.99	2.00	4.35	Ambient	5.0
SPS3	Exhaust point of SPS at Site OU.1.2	POINTHOR	825472.87	841653.66	2.00	4.35	Ambient	5.0

Remark:

- The exhaust parameters are provided by engineer.


Conversion of 1-hour Average to 5-second Average Concentration

Deodouriser	Emission Rate (OU/s)	Stability Class	Conversion Multiplier	Emission Rate with 5-second Peak Factor (OU/s)	Reference
SPS1	156	A, B, C, D, E, F	2.3	357.65	- Approved Methods for the Modelling and Assessment of Air Pollutants in New South Wales. - Katestone Scientific 1995, The Evaluation of Peak-to-Mean Ratios for Odour Assessments, volumes I and II, Katestone Scientific Pty Ltd, Brisbane.
SPS2	92	A, B, C, D, E, F	2.3	211.26	- Katestone Scientific 1998, Peak-to-Mean Concentration Ratios for Odour Assessments, Katestone Scientific Pty Ltd, Brisbane.
SPS3	53	A, B, C, D, E, F	2.3	120.91	

Emission Source Listing in AERMOD

Source ID	Type	X	Y	Exhaust Diameter (m)	Height (mAG)	Exit Temperature (K)	Exit Velocity(m/s)	Emission Rate with 5-second Peak Factor (OU/s)
SPS1	POINTHOR	825509.39	839378.40	2.00	4.35	Ambient	5.00	357.65
SPS2	POINTHOR	826578.39	840033.99	2.00	4.35	Ambient	5.00	211.26
SPS3	POINTHOR	825472.87	841653.66	2.00	4.35	Ambient	5.00	120.91

ISO A1 594mm x 841mm
 Approved:
 Checked:
 Designer:
 Project Management Initials:
 Plot File by: haquan.zhao 11/09/2023
 PATH P:\PROJECTS\60670882\DRAWING\REPORT\A34\A34_524.dgn



LEGEND:

- PROJECT BOUNDARY
- 500m ASSESSMENT AREA
- LOCATION OF ODOUR EMISSION SOURCE



PROJECT
 項目
 FIRST PHASE DEVELOPMENT OF THE NEW TERRITORIES NORTH – SAN TIN / LOK MA CHAU DEVELOPMENT NODE – INVESTIGATION

CLIENT
 業主
土木工程拓展署
 Civil Engineering and Development Department
規劃署
 Planning Department

CONSULTANT
 工程顧問公司
 AECOM Asia Company Ltd.
 www.aecom.com

SUB-CONSULTANTS
 分判工程師/顧問公司

ISSUE/REVISION
 修訂

I/R	DATE	DESCRIPTION	CHK.
修訂	日期	內容描述	核對

STATUS
 階段

SCALE
 比例
 A3 1 : 25000

DIMENSION UNIT
 尺寸單位
 METRES

KEY PLAN
 索引圖

PROJECT NO.
 項目編號
 60670882


AGREEMENT NO.
 協議編號
 CE 20/2021

SHEET TITLE
 圖紙名稱
 LOCATION OF ODOUR EMISSION SOURCES (OVERVIEW)

SHEET NUMBER
 圖紙編號
 60670882/A34/Appendix 3.10

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility, and disclaims any liability whatsoever, for any part, that is used or relied on in this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.

ISO A1 594mm x 841mm
 Approved:
 Checked:
 Designer:
 Project Management Initials:
 Plot File by: haiquan.zhao 11/14/2023
 PATH: P:\PROJECTS\60670882\DRAWING\REPORT\A34\A34_525.dgn



ISSUE/REVISION
項目

IR	DATE	DESCRIPTION	CHK.


STATUS
階段

SCALE
比例

DIMENSION UNIT
尺寸單位

A3 1 : 4000 METRES

KEY PLAN A3 1 : 150000
索引圖



PROJECT NO.
項目編號

AGREEMENT NO.
協議編號

60670882 CE 20/2021

SHEET TITLE
圖紙名稱




LOCATION OF ODOUR EMISSION SOURCES (PROPOSED EPP, FWPF AND SPS)

SHEET NUMBER
圖紙編號

60670882/A34/Appendix 3.10.1


SHEET 1 OF 3

NOTE:
 1. THIS DRAWING TO BE READ IN CONJUNCTION WITH DRAWING NOS. 60670882/A34/Appendix 3.10.1 TO 3.10.3.

LEGEND:
 PROJECT BOUNDARY
 SPS1
 ODOUR EMISSION SOURCE (POINT SOURCE)

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility, and denies any liability, whatsoever, for any part, that less or relies on this drawing without AECOM's express written consent. All measurements must be obtained from the stated dimensions.

Plot File by: haiquan.zhao 11/14/2023
PATH: P:\PROJECTS\60670882\DRAWING\REPORT\A34\A34_526.dgn



NOTES:

- 1. FOR NOTES AND LEGEND REFER TO DRAWING NO. 60670882/A34/Appendix 3.10.1.
- 2. THIS DRAWING TO BE READ IN CONJUNCTION WITH DRAWING NOS. 60670882/A34/Appendix 3.10.1 TO 3.10.3.



PROJECT
項目

FIRST PHASE DEVELOPMENT OF THE NEW TERRITORIES NORTH – SAN TIN / LOK MA CHAU DEVELOPMENT NODE – INVESTIGATION

CLIENT
業主

CEDD 土木工程拓展署
Civil Engineering and Development Department

規劃署
Planning Department

CONSULTANT
顧問公司

AECOM Asia Company Ltd.
www.aecom.com

SUB-CONSULTANTS
分包工程師/顧問公司

ISSUE/REVISION

I/R	DATE	DESCRIPTION	CHK.
修訂	日期	內容摘要	校核


STATUS

階段

SCALE

比例

KEY PLAN



PROJECT NO. 項目編號
60670882

AGREEMENT NO. 協議編號
CE 20/2021

SHEET TITLE 圖紙名稱


LOCATION OF ODOUR EMISSION SOURCES (PROPOSED EPP, FWPF AND SPS)

SHEET NUMBER 圖紙編號
60670882/A34/Appendix 3.10.2

SHEET 2 OF 3

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility, and denies any liability whatsoever, for any part, that less or relies on this drawing without AECOM's express written consent. All measurements must be obtained from the stated dimensions.

ISO A1 594mm x 841mm
Approved:
Checked:
Designer:
Project Management Initials:
841700 N
841600 N
Plot File by: haiquan.zhao 11/4/2023
PATH: P:\PROJECTS\60670882\DRAWING\REPORT\A34\A34_527.dgn



NOTES:
 1. FOR NOTES AND LEGEND REFER TO DRAWING NO. 60670882/A34/Appendix 3.10.1.
 2. THIS DRAWING TO BE READ IN CONJUNCTION WITH DRAWING NOS. 60670882/A34/Appendix 3.10.1 TO 3.10.3.



PROJECT
 項目
 FIRST PHASE DEVELOPMENT OF THE NEW TERRITORIES NORTH – SAN TIN / LOK MA CHAU DEVELOPMENT NODE – INVESTIGATION

CLIENT
 業主
 土木工程拓展署
 Civil Engineering and Development Department
 規劃署
 Planning Department

CONSULTANT
 顧問公司
 AECOM Asia Company Ltd.
 www.aecom.com

SUB-CONSULTANTS
 分判工程師有限公司

ISSUE/REVISION
 修訂


I/R	DATE	DESCRIPTION	CHK.
修訂	日期	內容描述	核對

STATUS
 階段

SCALE
 比例
 A3 1 : 1000
 米可圖

DIMENSION UNIT
 尺寸單位
 METRES

KEY PLAN A3 1 : 150000
 索引圖



PROJECT NO.
 項目編號
 60670882

AGREEMENT NO.
 協議編號
 CE 20/2021

SHEET TITLE
 圖紙名稱
 LOCATION OF ODOUR EMISSION SOURCES (PROPOSED EPP, FWPF AND SPS)

SHEET NUMBER
 圖紙編號
 60670882/A34/Appendix 3.10.3

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as agreed by AECOM or as required by law. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that uses or relies on this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.

- ❑ The design of tanks and covers should minimise the need for regular access for maintenance and inspection as confined space entry systems will be required
- ❑ The vent volumes need to be adequate to ensure no odour escape and also to account for air quality inside the cover (occupational exposure, corrosion and explosion hazard).
- ❑ Ventilation rates will depend upon the exact process operations but for tanks the design flows are typically 0.5 – 12 air changes per hour based upon the empty tank volume or 120% of the maximum filling rate. In the case of thickener tanks, the volume may increase to 200% of the maximum fill rate
- ❑ The design will take account of the fill and empty rate, maximum rate of change in headspace, likely gaps and leakage, evolution rate of flammables to maintain <25% LEL for methane (10% is good design)
- ❑ Allowance should be made for emergency ventilation of the tanks
- ❑ One problem with tank covers is that they cannot be easily inspected therefore tend to be poorly maintained.

Additionally, guidance on the design of waste water treatment plants in BS EN 12255 advises designers to :-

- ❑ Locate sources requiring abatement close together to optimise abatement options and minimise costs
- ❑ Consider explosion risk, corrosion, access and health and safety.

14.2 Odour Abatement Equipment

The air which is exhausted from enclosures usually requires abatement to avoid odour nuisance. It is possible to establish performance criteria to reflect what constitutes best practicable means (bpm) in relation to abatement equipment. This can be specified as follows:-

Any odour abatement equipment installed on contained emissions (ventilation air from the process building) should have an odour removal efficiency of not less than 95%². Determination of the destruction efficiency should be by dynamic olfactometry based upon manual extractive sampling undertaken simultaneously at the inlet and outlet of the odour control equipment. At least three samples should be taken from both the inlet and outlet.

There is a wide range of odour abatement equipment that can be used to treat emissions of contained air from WWTW. There are many factors which will affect the choice of equipment including required odour removal efficiency, flow rate and inlet odour concentration, type of chemical species in the odour, variability in flow and load, space requirements and infrastructure (power, drainage etc.). The range of technologies available is detailed in the Environment Agency H4 Guidance Note on odour.

² Where the inlet odour concentrations are very low and the 95% destruction efficiency is difficult to demonstrate due to measurement reproducibility and equipment efficiency at low concentrations, the final discharge to air should contain less than 500 odour units/m³.

Scottish Executive Environment Group

Code of Practice on Assessment and Control of Odour Nuisance from Waste Water Treatment Works

April 2005
Paper 2005/9

It is important when evaluating the most appropriate control technology to consider both total cost (capital and operating) and environmental impact (such as energy use, chemical use and secondary pollutant generation). Often operating costs are closely linked with environmental impact (that is costs for energy, raw materials etc.) and wherever possible the most environmentally sustainable technique should be selected.

As odour abatement plant capacity is usually tightly specified (little spare capacity), the assumption is that all other measures are being correctly used – covers, doors, chemicals replenished etc. This therefore becomes a key management issue that should be included in the Odour Management Plan.

The site layout may permit a centralised plant or due to locational constraints it may be necessary to use more than one system for example on the inlet works and the sludge process. It may be economical to provide a number of smaller biofilters for individual sources but if the selected technology is wet scrubbing it may be more cost effective to provide a single system. In some cases it may be appropriate to divide the odour streams and use different technology based upon the load and characteristics of each system.

Table 2 below summarises the main types of abatement equipment and the odour abatement efficacy that may be achieved.

SYSTEM	CAPITAL	CONSUMABLES	EFFECTIVENESS
Biofilters	Moderate	Need space, fan energy, media replacement 3 – 5 years	High >95% - not able to rapidly adjust to changes in flow or load
Bioscrubbers	Moderate	Fan energy, effluent needs oxygenation	High >95% - can handle higher H ₂ S loads than biofilters
Activated sludge plant	Low additional	Needs fully aerobic sludge	90 – 95% for H ₂ S and NH ₃ ; may be ideal as a polishing stage
Wet scrubbers	High	Fan energy, pump energy, dosing chemicals and effluent disposal – high energy user	Single stage <80% but multiple stage - >98%
Dry scrubbing (carbon or impregnated media)	High	Media replacement is a high cost with strong odours, suffer with moisture loading	> 95% ; Widely used for passive sources. Need several seconds residence for treatment
Catalytic iron oxidation	Moderate	Low operating cost	Specific for H ₂ S – good for low flow high load
Thermal oxidation	High	Fan energy and support fuel	>98% ; good for dryer vents and VOC loads
Ozone	Moderate	Replacement of source and energy for fan and ozone generator	>90% on low concentrations – good for building vents
Counteractants and masking	Low	Replenishment of chemicals	Not an abatement method – may be suitable for short-term use

TABLE 2– ODOUR ABATEMENT

Experience in operation of peat and heather type biofilters has shown that they do not perform well when the flow or odour load from the process is variable although other media (shell-type material) appears to perform better for these applications. There has been a considerable amount

of biofilter and bioscrubber equipment installed at WWTW. The units range in size from 75 – 435,000m³/hr but are typically 1600 – 3000m³/hr. The suppliers tend to offer 95-98% odour removal, 95-99.9% H₂S removal and 300 ou_E/m³ in exhaust gases.

The industry approach is that emission sources which exhibit strong odour peaks are best treated in wet scrubbers or carbon systems as some bio systems have been overloaded previously. It is increasingly common to have scrubbers on the sludge processing operations (often 3 or 4-stage scrubbers are used).

Quantification of NH₃ Emission From Sidestream Anammox Process

The NH₃ emission from the sidestream anammox process is calculated as 13.4 ppm in total according to *Appendix A of Dynamic of nitric oxide and nitrous oxide emission during full-scale reject water treatment (Kampschreur, et. al, 2008)* (12 ppm from the nitrification reactor and 1.4 ppm from the anammox reactor, therefore a total of 13.4 ppm emission).

The ammonia and Total Kjeldahl Nitrogen (TKN) loading of the quoted process is also similar to STLMC EPP design. Therefore, the NH₃ gaseous emission from the quoted paper is considered representative of the STLMC EPP NH₃ gaseous emission and adopted in this calculation of NH₃ emission for STLMC EPP's anammox process.

Converting 13.4 ppm gas phase NH₃ to OU, by using $0.037 \text{ ppm NH}_3 = 1 \text{ OU/m}^3$ (Odour threshold of NH₃ is 0.037 ppm, reference from *Iowa State University Extension (May 2004). "The Science of Smell Part 1: Odor perception and physiological response" (PDF). PM 1963a*)

The OU concentration of gas phase NH₃ = $13.4 \text{ ppm NH}_3 / (0.037 \text{ ppm NH}_3 / (\text{OU/m}^3)) = 362 \text{ OU/m}^3$. This is corresponding to the WWTP studied by the reference paper which treated 773 m³ of influent per day.

The dewatering centrate flow for STLMC EPP is estimated to be 1,525 m³ per day so the OU concentration can be prorated as $362 / 773 \times 1525 = 714 \text{ OU/m}^3$.

The odour extraction air flow rate of the anammox process in STLMC EPP's design is 4,298 m³/hr, or $(4,298 \text{ m}^3/\text{hr} / (3600\text{s/hr})) = 1.19 \text{ m}^3/\text{s}$ while the total surface area of the sidestream treatment facility is 790 m².

Hence, the Specific Odour Emission Rate (SOER) of sidestream treatment in the proposed STLMC EPP due to NH₃ emission = $714 \text{ OU/m}^3 \times 1.19 \text{ m}^3/\text{s} / 790 \text{ m}^2 = 1.08 \text{ OU/m}^2\cdot\text{s}$.

The total SOER adopted for sidestream treatment = 1.65 (SOER value referenced from bioreactor of Shek Wu Hui STW) + 1.08 (due to NH₃ gas emission) = 2.73 OU/m²·s.

Reference:

Kampschreur, M. J.; van der Star, W.R.L.; Wielders, H.A.; Mulder, J.W.; Jetten, M.S.M.; van Loosdrecht, M.C.M. 2008. Dynamic of nitric oxide and nitrous oxide emission during full-scale reject water treatment. *Water Research* 42 (2008), p812 – 826

Iowa State University Extension (May 2004). "The Science of Smell Part 1: Odor perception and physiological response" (PDF). PM 1963a)