

Chemical Waste Treatment Centre
Operation Report
Jul 00 - Sep 00

I. INTRODUCTION

This Operation Report is prepared by EPD for the Environment and Planning Committee (EPC) of the Kwai Tsing District Council. It outlines the activities of the Chemical Waste Treatment Centre (CWTC) and provides a summary of environmental performance of the plant.

The environmental performance summary as shown in Section II of this report covers the result of environmental monitoring from July 2000 to September 2000.

II. ENVIRONMENTAL PERFORMANCE SUMMARY

Enviropace are required to undertake regular checks on environmental performance of the operation of the plant. These include the following:

- Effluent discharge monitoring
- Stack gas monitoring
- Stabilised residue monitoring

Effluent Discharge

Effluent from the CWTC treatment processes has to meet statutory and contractual discharge limits on pollutant concentration. Multiple processes are employed inside the CWTC to treat all liquid wastes to ensure a safe waste management system. These would facilitate immediate warning on any significant change detected in the composition of the effluent, such that prompt corrective response can be effected.

Effluent from the plant is discharged in batches. Each batch is sampled and analyzed, and discharges are permitted only if limits are met. Tables 1 to 3 show the summary of effluent quality from July 2000 to September 2000. No exceedances in effluent discharge limits were observed.

Stack Gas

Air emissions from the incineration system are closely monitored by a comprehensive management and monitoring programme to ensure that the system is operating safely and in an environmentally acceptable manner.

A continuous monitoring system on key parameters is installed in the incinerator stack to ensure combustion and air pollutant removal processes are functionally well. Furthermore, the incinerator is equipped with an automatic waste feed cut-off system. In the event that the continuous monitoring system picks up any potential sign of exceedance of any of the control parameters, waste feed to the incinerator will be stopped automatically.

The result for Stack Gas Monitoring from July 2000 to September 2000 are attached in Tables 4 to 6 and compliance in all stack gas control parameters has been achieved.

Stabilised Residue

All process residues at the CWTC are detoxified, chemically stabilized and physically immobilized to an environmentally benign state. Samples of the stabilized materials have to pass a series of analytical tests, proven to be innocuous before being sent to an off-site landfill for final disposal.

The summaries of result for Stabilized Residue from July 2000 to September 2000 are attached in Tables 7 to 9. All of the test parameters fell within the control limits and no exceedances occurred.

Table 1

Chemical Waste Treatment Centre
Effluent Discharge Summary (July 2000)

Parameters	Control Limits	Result	Mean
pH	6-10	7.4 – 9.7	N/A
Total Kjeldahl Nitrogen (mg/l)	100	< 96.517	N/A
Total Phosphate (mg/l)	10	< 1	N/A
Total Sulphate (mg/l)	2000	279.49 – 830.51	553.19
Total Sulphides (mg/l)	10	< 2.05	N/A
Total Cyanide (mg/l)	0.1	< 0.08	N/A
Total Suspended Solids (mg/l)	100	< 62.89	N/A
Oil and Grease (mg/l)	20	< 18.28	N/A
Total Phenols (mg/l)	0.5	< 0.498	N/A
Total Residual Chlorine (mg/l)	1	< 0.6	N/A
Anionic Detergents (mg/l)	15	< 2	N/A
Dissolved TOC (mg/l)	200	67.30 – 192.94	134.40
Temperature (°C)	43	34 – 42	N/A
Floatable Substances (mg/l)	Not to be detected	Not detected	Not detected
Toxic Metals :			
Arsenic (mg/l)	2	< 0.25	N/A
Barium (mg/l)	5	< 1.79	
Cadmium (mg/l)	0.1	< 0.1	
Chromium (mg/l)	1	< 0.3	
Copper (mg/l)	2	< 1.38	
Lead (mg/l)	2	< 1	
Manganese (mg/l)	5	< 0.2	
Mercury (mg/l)	0.05	< 0.05	
Nickel (mg/l)	2	< 1	
Silver (mg/l)	2	< 0.424	
Tin (mg/l)	5	< 1	
Zinc (mg/l)	2	< 1	
Total Toxic Metals # (mg/l)	10	< 7.80	
Boron (mg/l)	5	< 1.561	
Iron (mg/l)	10	< 2	N/A

Parameters	Control Limits	Result	Mean
Pesticides :			
Aldrin (mg/l)	0.01	< 0.01	N/A
BHCS (mg/l)	0.01	< 0.01	
DDT (mg/l)	0.01	< 0.01	
Semi-volatile Compounds :			
Benzo (A) Pyrene (mg/l)	0.1	< 0.1	N/A
Volatile Compounds :			
1,1,1-Trichloroethane (mg/l)	0.05	< 0.05	N/A
Polychlorinated Biphenyls :			
Total PCBs (mg/l)	0.003	< 0.003	N/A
Radioactive Substances :			
Gross (pc/l)	10000	< 10000	N/A
Radium-226 (pc/l)	30	< 30	
Strontium-90 (pc/l)	100	< 100	

Total toxic metals include: Arsenic, Barium, Cadmium, Chromium, Copper, Lead, Manganese, Mercury, Nickel, Silver, Tin, Zinc.

Table 2

Chemical Waste Treatment Centre
Effluent Discharge Summary (August 2000)

Parameters	Control Limits	Result	Mean
pH	6-10	7.4 – 9.7	N/A
Total Kjeldahl Nitrogen (mg/l)	100	< 99.312	N/A
Total Phosphate (mg/l)	10	< 1	N/A
Total Sulphate (mg/l)	2000	370.27-971.52	681.20
Total Sulphides (mg/l)	10	< 1.63	N/A
Total Cyanide (mg/l)	0.1	< 0.099	N/A
Total Suspended Solids (mg/l)	100	< 65.19	N/A
Oil and Grease (mg/l)	20	< 19.56	N/A
Total Phenols (mg/l)	0.5	< 0.40	N/A
Total Residual Chlorine (mg/l)	1	< 0.6	N/A
Anionic Detergents (mg/l)	15	< 2	N/A
Dissolved TOC (mg/l)	200	64.67-177.59	131.33
Temperature (°C)	43	33 – 43	N/A
Floatable Substances (mg/l)	Not to be detected	Not detected	Not detected
Toxic Metals :			
Arsenic (mg/l)	2	< 0.25	N/A
Barium (mg/l)	5	< 1	
Cadmium (mg/l)	0.1	< 0.1	
Chromium (mg/l)	1	< 0.3	
Copper (mg/l)	2	< 0.874	
Lead (mg/l)	2	< 1	
Manganese (mg/l)	5	< 0.2	
Mercury (mg/l)	0.05	< 0.05	
Nickel (mg/l)	2	< 1	
Silver (mg/l)	2	< 0.66	
Tin (mg/l)	5	< 1.068	
Zinc (mg/l)	2	< 1	
Total Toxic Metals # (mg/l)	10	< 7.174	
Boron (mg/l)	5	< 1.849	
Iron (mg/l)	10	< 2	

Parameters	Control Limits	Result	Mean
Pesticides :			
Aldrin (mg/l)	0.01	< 0.01	N/A
BHCS (mg/l)	0.01	< 0.01	
DDT (mg/l)	0.01	< 0.01	
Semi-volatile Compounds :			
Benzo (A) Pyrene (mg/l)	0.1	< 0.1	N/A
Volatile Compounds :			
1,1,1-Trichloroethane (mg/l)	0.05	< 0.05	N/A
Polychlorinated Biphenyls :			
Total PCBs (mg/l)	0.003	< 0.003	N/A
Radioactive Substances :			
Gross (pc/l)	10000	< 10000	N/A
Radium-226 (pc/l)	30	< 30	
Strontium-90 (pc/l)	100	< 100	

Total toxic metals include: Arsenic, Barium, Cadmium, Chromium, Copper, Lead, Manganese, Mercury, Nickel, Silver, Tin, Zinc.

Table 3

Chemical Waste Treatment Centre
Effluent Discharge Summary (September 2000)

Parameters	Control Limits	Result	Mean
pH	6-10	7.6 - 9.4	N/A
Total Kjeldahl Nitrogen (mg/l)	100	< 20	N/A
Total Phosphate (mg/l)	10	< 1	N/A
Total Sulphate (mg/l)	2000	620.65-1031.24	847.69
Total Sulphides (mg/l)	10	< 0.5	N/A
Total Cyanide (mg/l)	0.1	< 0.04	N/A
Total Suspended Solids (mg/l)	100	< 50.625	N/A
Oil and Grease (mg/l)	20	< 19.36	N/A
Total Phenols (mg/l)	0.5	< 0.34	N/A
Total Residual Chlorine (mg/l)	1	< 0.6	N/A
Anionic Detergents (mg/l)	15	< 2	N/A
Dissolved TOC (mg/l)	200	91.51-187.37	128.57
Temperature (°C)	43	34 – 39	N/A
Floatable Substances (mg/l)	Not to be detected	Not detected	Not detected
Toxic Metals :			
Arsenic (mg/l)	2	< 0.25	N/A
Barium (mg/l)	5	< 1	
Cadmium (mg/l)	0.1	< 0.1	
Chromium (mg/l)	1	< 0.3	
Copper (mg/l)	2	< 0.92	
Lead (mg/l)	2	< 1	
Manganese (mg/l)	5	< 0.2	
Mercury (mg/l)	0.05	< 0.05	
Nickel (mg/l)	2	< 1.203	
Silver (mg/l)	2	< 0.4	
Tin (mg/l)	5	< 1	
Zinc (mg/l)	2	< 1	
Total Toxic Metals # (mg/l)	10	< 7.22	
Boron (mg/l)	5	< 2.61	
Iron (mg/l)	10	< 2	N/A

Parameters	Control Limits	Result	Mean
Pesticides :			
Aldrin (mg/l)	0.01	< 0.01	N/A
BHCS (mg/l)	0.01	< 0.01	
DDT (mg/l)	0.01	< 0.01	
Semi-volatile Compounds :			
Benzo (A) Pyrene (mg/l)	0.1	< 0.1	N/A
Volatile Compounds :			
1,1,1-Trichloroethane (mg/l)	0.05	< 0.05	N/A
Polychlorinated Biphenyls :			
Total PCBs (mg/l)	0.003	< 0.003	N/A
Radioactive Substances :			
Gross (pc/l)	10000	< 10000	N/A
Radium-226 (pc/l)	30	< 30	
Strontium-90 (pc/l)	100	< 100	

Total toxic metals include: Arsenic, Barium, Cadmium, Chromium, Copper, Lead, Manganese, Mercury, Nickel, Silver, Tin, Zinc.

Table 4

Chemical Waste Treatment Centre
Stack Gas Monitoring Summary (July 2000)

Parameters	Control Limits	Result	Mean
Particulates (mg/m ³)	75	2.3 – 6.8	4.0
Chlorine and Compounds (as Cl ₂) (mg/m ³)	100	< 3.0	N/A
Fluorine and Compounds (as HF) (mg/m ³)	25	< 0.3	N/A
Hydrogen Sulphide (mg/m ³)	5	0.5 – 0.9	0.7
Acidity (as Sulphuric Acid) (mg/m ³)	100	< 3.4	N/A
Sulphur Dioxide (mg/m ³)	750	< 24.5	N/A
Hydrochloric Acid (mg/m ³)	38	7.5 – 13.3	16.6
Total Phosphorus (as P) (mg/m ³)	7.5	< 0.595	N/A
Hydrogen Fluoride (mg/m ³)	7.5	< 0.8	N/A
Hydrogen Bromide (mg/m ³)	7.5	< 0.8	N/A
Toxic Metals I :			
Mercury (mg/m ³)	3	< 0.007	N/A
Cadmium (mg/m ³)	3	< 0.050	
Antimony (mg/m ³)	3	< 0.500	
Toxic Metals II :			
Lead (mg/m ³)	10	< 0.595	N/A
Copper (mg/m ³)	10	< 0.069	
Arsenic (mg/m ³)	10	< 0.006	
Nickel (mg/m ³)	10	< 0.119	
Chromium (mg/m ³)	10	< 0.050	
Total of Toxic Metals I & II (mg/m ³)	10	< 1.396	N/A
Dioxin (ng/m ³)	0.1	0.0200	N/A

Table 5

Chemical Waste Treatment Centre
Stack Gas Monitoring Summary (August 2000)

Parameters	Control Limits	Result	Mean
Particulates (mg/m ³)	75	2.3 – 16.5	6.6
Chlorine and Compounds (as Cl ₂) (mg/m ³)	100	< 3.6	N/A
Fluorine and Compounds (as HF) (mg/m ³)	25	< 0.4	N/A
Hydrogen Sulphide (mg/m ³)	5	0.1	N/A
Acidity (as Sulphuric Acid) (mg/m ³)	100	< 8.1	N/A
Sulphur Dioxide (mg/m ³)	750	< 238.3	N/A
Hydrochloric Acid (mg/m ³)	38	4.7 – 35.6	16
Total Phosphorus (as P) (mg/m ³)	7.5	< 0.631	N/A
Hydrogen Fluoride (mg/m ³)	7.5	< 0.9	N/A
Hydrogen Bromide (mg/m ³)	7.5	< 2.1	N/A
Toxic Metals I :			
Mercury (mg/m ³)	3	< 0.026	N/A
Cadmium (mg/m ³)	3	< 0.053	
Antimony (mg/m ³)	3	< 0.532	
Toxic Metals II :			
Lead (mg/m ³)	10	< 0.631	N/A
Copper (mg/m ³)	10	< 0.073	
Arsenic (mg/m ³)	10	< 0.006	
Nickel (mg/m ³)	10	< 0.126	
Chromium (mg/m ³)	10	< 0.053	
Total of Toxic Metals I & II (mg/m ³)	10	< 1.483	N/A
Dioxin (ng/m ³)	0.1	0.0057	N/A

Table 6

Chemical Waste Treatment Centre
Stack Gas Monitoring Summary (September 2000)

Parameters	Control Limits	Result	Mean
Particulates (mg/m ³)	75	1.8 – 6.2	3.9
Chlorine and Compounds (as Cl ₂) (mg/m ³)	100	< 3.7	N/A
Fluorine and Compounds (as HF) (mg/m ³)	25	< 0.4	N/A
Hydrogen Sulphide (mg/m ³)	5	1.3	N/A
Acidity (as Sulphuric Acid) (mg/m ³)	100	4.5 – 5.3	5.0
Sulphur Dioxide (mg/m ³)	750	7.0 – 136.5	61.5
Hydrochloric Acid (mg/m ³)	38	13.6 – 28.1	19.7
Total Phosphorus (as P) (mg/m ³)	7.5	< 0.773	N/A
Hydrogen Fluoride (mg/m ³)	7.5	< 0.9	N/A
Hydrogen Bromide (mg/m ³)	7.5	< 0.8	N/A
Toxic Metals I :			
Mercury (mg/m ³)	3	< 0.018	N/A
Cadmium (mg/m ³)	3	< 0.065	
Antimony (mg/m ³)	3	< 0.653	
Toxic Metals II :			
Lead (mg/m ³)	10	< 0.773	N/A
Copper (mg/m ³)	10	< 0.089	
Arsenic (mg/m ³)	10	< 0.008	
Nickel (mg/m ³)	10	< 0.155	
Chromium (mg/m ³)	10	< 0.065	
Total of Toxic Metals I & II (mg/m ³)	10	< 1.820	N/A
Dioxin (ng/m ³)	0.1	0.0072	N/A

Table 7

Chemical Waste Treatment Centre
Stabilised Materials Summary (July 2000)

Parameters	Control Limits	Result	Mean
Section A			
pH (water)	8 (lower limit)	10.12 – 12.77	N/A
% Solids (%)	30 (lower limit)	40.48 – 89.27	69.07
Toxic Metals :			
Cadmium (ppm)	0.5	< 0.5	N/A
Mercury (ppm)	0.1	< 0.02	
Total Chromium (ppm)	10	< 6.219	
Copper (ppm)	-	< 5.947	
Nickel (ppm)	-	< 3.012	
Lead (ppm)	-	< 16.72	
Zinc (ppm)	-	< 17.47	
Total of copper, nickel, lead, zinc (ppm)	25	< 23.911	
Iron (ppm)	20	< 2.397	N/A
Sulphide (ppm)	10	< 1	N/A
Ammoniacal Nitrogen (ppm)	10	< 9.5	N/A
Cyanide (ppm)	5	< 1	N/A
Section B			
Volatile Organic Contents (ppm)	5000	< 15	N/A
Total Organic Halides (ppm)	10	< 2	N/A
Total Chloro Phenols (ppm)	2	< 2	N/A
Polychlorinated Biphenyls (ppm)	1	< 1	N/A
TCDD equivalent (ITEF method) (ppb)	1	< 1	N/A

Table 8

Chemical Waste Treatment Centre
Stabilised Materials Summary (August 2000)

Parameters	Control Limits	Result	Mean
Section A			
pH (water)	8 (lower limit)	9.35–12.8	N/A
% Solids (%)	30 (lower limit)	47.17 - 98.28	67.97
Toxic Metals :			
Cadmium (ppm)	0.5	< 0.5	N/A
Mercury (ppm)	0.1	< 0.02	
Total Chromium (ppm)	10	< 0.5	
Copper (ppm)	-	< 13.47	
Nickel (ppm)	-	< 2.837	
Lead (ppm)	-	< 16.79	
Zinc (ppm)	-	< 7.998	
Total of copper, nickel, lead, zinc (ppm)	25	< 24.692	
Iron (ppm)	20	< 1	N/A
Sulphide (ppm)	10	< 1	N/A
Ammoniacal Nitrogen (ppm)	10	< 9.14	N/A
Cyanide (ppm)	5	< 1	N/A
Section B			
Volatile Organic Contents (ppm)	5000	< 15	N/A
Total Organic Halides (ppm)	10	< 2	N/A
Total Chloro Phenols (ppm)	2	< 2	N/A
Polychlorinated Biphenyls (ppm)	1	< 1	N/A
TCDD equivalent (ITEF method) (ppb)	1	< 1	N/A

Table 9

Chemical Waste Treatment Centre
Stabilised Materials Summary (September 2000)

Parameters	Control Limits	Result	Mean
Section A			
pH (water)	8 (lower limit)	8.89–12.63	N/A
% Solids (%)	30 (lower limit)	48.97-98.33	67.86
Toxic Metals :			
Cadmium (ppm)	0.5	< 0.5	N/A
Mercury (ppm)	0.1	< 0.02	
Total Chromium (ppm)	10	< 3.635	
Copper (ppm)	-	< 18.6	
Nickel (ppm)	-	< 3.143	
Lead (ppm)	-	< 14.83	
Zinc (ppm)	-	< 15.9	
Total of copper, nickel, lead, zinc (ppm)	25	< 22.461	
Iron (ppm)	20	< 5.911	N/A
Sulphide (ppm)	10	< 1	N/A
Ammoniacal Nitrogen (ppm)	10	< 7.53	N/A
Cyanide (ppm)	5	< 1	N/A
Section B			
Volatile Organic Contents (ppm)	5000	< 15	N/A
Total Organic Halides (ppm)	10	< 2.1	N/A
Total Chloro Phenols (ppm)	2	< 2	N/A
Polychlorinated Biphenyls (ppm)	1	< 1	N/A
TCDD equivalent (ITEF method) (ppb)	1	< 1	N/A